

Louisville and Jefferson County Metropolitan Sewer District 700 West Liberty Street Louisville Kentucky 40203-1911 502-540-6000 www.msdlouky.org

April 10, 2012

Highland Avenue Louisville, Kentucky 40204

Subject: Integrated Overflow Abatement Plan (IOAP)

Public Input Meeting January 24, 2012

Response to comments

Dear

Thank you for taking the time to attend the meeting and submit your comments relative to I-64 & Grinstead Drive storage basin project. Your comment is summarized below, and your comment form is attached for reference.

Comment - How are we going to compensate in the floodplain for sewer basins?

Response to comment –MSD must adhere to regulatory requirements. If the project requires fill to be placed in the floodplain, or an above-grade structure to be constructed in the floodplain, compensation will be required onsite at a 1:1 ratio. If this requirement cannot be met on site then mitigation will be required within the watershed. Until the design is near completion, the amount of compensation and/or mitigation required cannot be determined.

This letter will be posted on MSD's Project WIN web page at the link www.msdlouky.org/projectwin.

Sincerely,


Steve Emly, PE

Interim Director of Engineering

Attachment: Comment Form







IOAP Public Outreach Meeting

(date)

To Be Completed by the Customer	·
Customer Name (Last, First)	
Address Highland Ave LOWSV	111e, Zip Code 40204
. U	Work Phone
LOCATION OF REQUEST	
Address Basin	Zip Code
Owner [] Tenant [] Other []	
HOW are We some to	Ompusede or sever basi
to be Completed by an MSD Representative	
To Be Completed by an MSD Representative MSD Responder:	
MSD Responder: D	