



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

April 26, 2010

Ms. Carolena Bentley
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

RE: Cedar Creek WQTC, KPDES No: KY0098540
Discharge Monitoring Report-March 2010

Dear Ms. Bentley:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Cedar Creek WQTC, KPDES No.: KY0098540 for the month of March 2010.

Also attached is the 2010 first quarterly Biomonitoring DMR.

There were no exceedences, bypass or overflow reports.

If you have any questions concerning the attached DMR's, please contact me at (502) 239-7574.

Sincerely,

A handwritten signature in black ink, reading "Duane V. Wright". The signature is written in a cursive style with a large, stylized "D" and "W".

Duane V. Wright
Process Supervisor Central Region

DVW/Cedar Creek 03.10.doc

Enclosures

cc: C. Roth (DOW Louisville)
T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME CEDAR CREEK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY CEDAR CREEK WQTC MSD

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)

DISCHARGE MONITORING REPORT (DMR)

KY0098540
 PERMIT NUMBER

001 1
 DISCHARGE NUMBER

MAJOR
 (SUBR LV)
 F - FINAL JEFFE
 NEW EXPANSION
 EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40291
 ATTN: DENNIS THOMMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
10	03	01	FROM	10	03	31

NOTE: Read instructions before completing this form

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****	***	9.0	*****	*****	(19) MG/L	0	1/1	GRAB
00300 1 0 0 EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	7.0 INST MIN	*****	*****	(19) MG/L		THREE/ WEEK	GRAB
PH	SAMPLE MEASUREMENT	*****	*****	***	6.7	*****	6.9	(12) SU	0	1/1	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	6.0 MINIMUM	*****	9.0 MAXIMUM	(12) SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	3864	4977	(26) LBS/DY	*****	106	126	(19) MG/L	0	3/7	COMPOS
00530 G 0 0 RAW SEW/INFLUENT	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/ WEEK	COMPOS
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	73	81	(26) LBS/DY	*****	2	2	(19) MG/L	0	3/7	COMPOS
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	1876 MO AVG	2815 MX WK AV	(26) LBS/DY	*****	30 MO AVG	45 MX WK AV	(19) MG/L		THREE/ WEEK	COMPOS
NITROGEN, AMMONIA TOTAL (AS N)	SAMPLE MEASUREMENT	592	650	(26) LBS/DY	*****	16	17	(19) MG/L	0	3/7	COMPOS
00610 G 0 0 RAW SEW/INFLUENT	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/ WEEK	COMPOS
NITROGEN, AMMONIA TOTAL (AS N)	SAMPLE MEASUREMENT	6	19	(26) LBS/DY	*****	0.2	0.5	(19) MG/L	0	3/7	COMPOS
00610 1 2 0 EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	625 MO AVG	938 MX WK AV	(26) LBS/DY	*****	10 MO AVG	15 MX WK AV	(19) MG/L		THREE/ WEEK	COMPOS
PHOSPHORUS, TOTAL (AS P)	SAMPLE MEASUREMENT	2	3	(26) LBS/DY	*****	0.1	0.1	(19) MG/L	0	3/7	COMPOS
00665 1 0 0 EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	125 MO AVG	156 MX WK AV	(26) LBS/DY	*****	2.0 MO AVG	2.5 MX WK AV	(19) MG/L		THREE/ WEEK	COMPOS
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1310. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.				TELEPHONE		DATE			
H J SCHARDEIN EXECUTIVE DIRECTOR						502 540-6000		10 04 27			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE		YEAR MO DAY			

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME CEDAR CREEK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY CEDAR CREEK WQTC MSD

LOCATION LOUISVILLE KY 40291
 ATTN: DENNIS THOMMASSON SR. METRO OPS

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0098540
 PERMIT NUMBER

001 1
 DISCHARGE NUMBER

MAJOR
 (SUBR LV)
 F - FINAL JEFFE
 NEW EXPANSION
 EFFLUENT
 [] No Discharge

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 10	03	01		10	03	31

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	4.30	5.56	(03) MGD	*****	*****	*****	***	0	CONTIN	CONTIN
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT DAILY MX	(03) MGD	*****	*****	*****	***		CONTIN	CONTIN
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	4	4	(13) 100ML	0	3/7	GRAB
	PERMIT MEASUREMENT	*****	*****	***	*****	200	400	(13) 100ML		THREE WEEK	GRAB
BOD, CARBONACEOUS 05 DAY, 20C 80082 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	3262	3781	(26) LBS/DY	*****	90	98	(19) MG/L	0	3/7	COMPOS
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE WEEK	COMPOS
BOD, CARBONACEOUS 05 DAY, 20C 80082 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	73	81	(26) LBS/DY	*****	2	2	(19) MG/L	0	3/7	COMPOS
	PERMIT MEASUREMENT	625	938	(26) LBS/DY	*****	10	15	(19) MG/L		THREE WEEK	COMPOS
BOD, CARB 5-DAY, 20 DEG C, PERCENT REMVL 80091 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	98	*****	*****	(23) CENT	0	CALCTD	CALCTD
	PERMIT MEASUREMENT	*****	*****	***	35	*****	*****	(23) CENT		CALCTD	CALCTD
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	98	*****	*****	(23) CENT	0	CALCTD	CALCTD
	PERMIT MEASUREMENT	*****	*****	***	35	*****	*****	(23) CENT		CALCTD	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER H J SCHARDEIN EXECUTIVE DIRECTOR	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under those statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.					TELEPHONE 502 540-6000		DATE 10 04 27			
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE					

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME CEDAR CREEK WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
8405 CEDAR CREEK RD
LOUISVILLE KY 40211
FACILITY CEDAR CREEK WQTC MSD

LOCATION LOUISVILLE KY 40291
ATTN: DENNIS THOMMASSON SR. METRO OPS

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
DISCHARGE MONITORING REPORT (DMR)

KY0098540
PERMIT NUMBER

001 Y
DISCHARGE NUMBER

MAJOR (SUBR LV)
F - FINAL JEFFE
METALS/BIOMONITORING/QUARTERLY
EFFLUENT
[] No Discharge

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 10	01	01	TO 10	03	31

NOTE: Read instructions before completing this form

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE			
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS						
HARDNESS, TOTAL (AS CaCO3) 00900 1 0 0	SAMPLE MEASUREMENT	*****	*****	***	*****	274	274	(19) MG/L	0	1/90	COMPOS			
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS			
CADMIUM, DISSOLVED (AS CD) 01025 1 0 0	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.0001	<0.0001	(19) MG/L	0	1/90	COMPOS			
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS			
COPPER, DISSOLVED (AS CU) 01040 1 0 0	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.002	<0.002	(19) MG/L	0	1/90	COMPOS			
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS			
LEAD, DISSOLVED (AS PB) 01049 1 0 0	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.004	<0.004	(19) MG/L	0	1/90	COMPOS			
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS			
ZINC, DISSOLVED (AS ZN) 01090 1 0 0	SAMPLE MEASUREMENT	*****	*****	***	*****	0.0368	0.0368	(19) MG/L	0	1/90	COMPOS			
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS			
ZINC TOTAL RECOVERABLE 01094 1 0 0	SAMPLE MEASUREMENT	*****	*****	***	*****	0.0368	0.0368	(19) MG/L	0	1/90	COMPOS			
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS			
CADMIUM TOTAL RECOVERABLE 01113 1 0 0	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.0001	<0.0001	(19) MG/L	0	1/90	COMPOS			
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS			
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.				TELEPHONE		DATE						
H J SCHARDEIN						502	540-6000	10	04	27				
EXECUTIVE DIRECTOR						AREA CODE	NUMBER	YEAR	MO	DAY				
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT												
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)														

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME CEDAR CREEK WQTC MSD

ADDRESS C/O CEDAR CREEK WQTC

8405 CEDAR CREEK RD

LOUISVILLE KY 40211

FACILITY CEDAR CREEK WQTC MSD

LOCATION LOUISVILLE KY 40291

ATTN: DENNIS THOMMASSON SR. METRO OPS

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)

DISCHARGE MONITORING REPORT (DMR)

KY0098540

PERMIT NUMBER

001 Y

DISCHARGE NUMBER

MONITORING PERIOD

FROM YEAR 10 MO 01 DAY 01 TO YEAR 10 MO 03 DAY 31

MAJOR
(SUBR LV)

F - FINAL

JEFFE

METALS/BIOMONITORING/QUARTERLY
EFFLUENT

[] No Discharge

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LEAD	SAMPLE	*****	*****	***	*****	<0.004	<0.004	(19)	0	1/90	COMPOS
TOTAL RECOVERABLE	MEASUREMENT			***				MG/L			
01114 1 0 0	PERMIT	*****	*****	***	*****	REPORT	REPORT	(19)		QTRLY	COMPOS
EFFLUENT GROSS VALUE	MEASUREMENT			***		MO AVG	DAILY MX	MG/L			
COPPER	SAMPLE	*****	*****	***	*****	<0.002	<0.002	(19)	0	1/90	COMPOS
TOTAL RECOVERABLE	MEASUREMENT			***				MG/L			
01119 1 0 0	PERMIT	*****	*****	***	*****	REPORT	REPORT	(19)		QTRLY	COMPOS
EFFLUENT GROSS VALUE	MEASUREMENT			***		MO AVG	DAILY MX	MG/L			
TOXICITY, FINAL CONC	SAMPLE	*****	*****	***	*****	*****	<1.0	(2G)	0	1/90	COMPOS
TOXICITY UNITS	MEASUREMENT			***				TOXCTY			
61406 1 0 0	PERMIT	*****	*****	***	*****	*****	1.0	(2G)		QTRLY	COMPOS
EFFLUENT GROSS VALUE	MEASUREMENT			***			DAILY MX	TOXCTY			
	SAMPLE										
	MEASUREMENT										
	PERMIT										
	MEASUREMENT										
	SAMPLE										
	MEASUREMENT										
	PERMIT										
	MEASUREMENT										
	SAMPLE										
	MEASUREMENT										
	PERMIT										
	MEASUREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

H J SCHARDEIN

EXECUTIVE DIRECTOR

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1316. (Penalties under those statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

502 540-6000

DATE

10 04 27

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME OF TREATMENT PLANT CEDAR CREEK WTP
 KPDES PERMIT NUMBER KY0098540

COUNTY JEFFERSON
 PLANT CAPACITY 7.5 MGD

MONTH OF: March 2010
 RECEIVING STREAM CEDAR CREEK

DATE	TOTAL FLOW (MILLION GALLONS)	PLANT CAPACITY															RECEIVING STREAM										CEDAR CREEK							
		RAW SEWAGE		pH		SETTLEABLE SOLIDS (mg/L)			DISSOLVED OXYGEN (mg/L)			SUSPENDED SOLIDS (mg/L)			5 DAY CBOD (mg/L)			ACTIVATED SLUDGE			AERATION BASIN				SLUDGE HANDLING				FINAL					
		GRIT REMOVED (CUBIC FEET)	SCREENINGS (CUBIC FEET)	RAW	FINAL	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	STREAM ABOVE	FINAL EFFLUENT	STREAM BELOW	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	GAUDAY X 1000	MLSS X 1000	WASTE D X 1000	DISSOLVED OXYGEN (mg/L)	MLSS (mg/L) X 1000	MLVSS (mg/L) X 1000	SETTLED SLUDGE VOLUME		GALLONS X 1000	RAW		HAULED		NH3-N (mg/L)	FECAL COLIFORM (COLONIES/100ML)	Total Phosphorus	
																								30 MIN.	60 MIN.		% DRY SOLIDS	% VOLATILE SOLIDS	% DRY SOLIDS	% VOLATILE SOLIDS				WITHDRAWN GALLONS X 1000
1	5.56			6.7	6.9				9			81		2	71		2	3369	4580	30	3.1	2055	1675	290	250							0.06	3	0.062
2	4.72			6.8	6.8				9			106		2	69		2	2537	5540	33	2.6	2395	1915	340	270							1.30	3	0.085
3	4.36			6.8	6.9				9			76		2	91		2	1771	5260	56	3.2	3005	2330	650	440							0.06	3	0.06
4	4.66			6.7	6.8				9									1705	7570	54	3.4	3550	2835	400	310									
5	4.23			6.7	6.9				9									1028	6200		3.1	2720	2210	380	280									
6	4.25			6.8	6.9				9									1721		52	2.9			400	330									
7	4.35			6.7	6.8				9									1725		62	3.3			420	350									
8	3.93			6.8	6.8				9			135		2	88		2	1680	5360	58	2.1	2765	2105	450	360							0.06	4	0.06
9	3.94			6.8	6.9				9			94		2	93		2	1725	5180	50	3.5	2650	2090	440	350							0.06	4	0.06
10	3.86			6.7	6.8				9			99		2	82		2	1765	5060	53	3.3	2775	2225	450	340							0.06	4	0.06
11	3.97			6.7	6.7				9									1712	4970	52	3.6	2695	2180	420	310									
12	4.27			6.8	6.8				9									1702	6180	56	3.6	2910	2330	470	330									
13	4.82			6.8	6.8				9									1790		58	3.5			460	310									
14	4.67			6.7	6.8				9									1649		64	3.7			460	320									
15	4.29			6.7	6.7				9			103		2	91		2	1585	5270	61	3.8	2765	2245	390	300							0.06	4	0.081
16	3.94			6.8	6.8				9			84		2	95		2	1677	5440	54	3.8	2755	2230	380	300							0.06	4	0.06
17	3.92			6.6	6.7				9			110		2	108		2	1720	5370	52	3.7	2760	2280	390	300							0.06	4	0.06
18	3.79			6.8	6.8				9									1771	5820	50	3.8	2835	2270	400	300									
19	3.80			6.7	6.7				9									1760	5610	52	3.4	2700	2195	400	320									
20	4.06			6.8	6.8				9									1740		51	3.4			390	300									
21	4.31			6.8	6.8				9									1780		52	3.4			390	310									
22	5.56			6.9	6.7				9			121		2	76		2		7250	58	3	2765	2350	380	300							0.06	4	0.06
23	4.51			6.8	6.8				9			104		2	94		2	1713	6040	44	3.7	2695	2325	360	300							0.06	4	0.06
24	4.21			6.9	6.8				9			154		2	122		2	1784	6020	64	3.7	2620	2230	380	300							0.06	4	0.06
25	4.27			6.8	6.7				9									1738	6160	55	3.8	2600	2195	370	310									
26	4.62			6.8	6.8				9									1760	5960	55	3.2	2680	2250	360	300									
27	4.47			6.7	6.8				9									1746		50	3.6			390	320									
28	4.10			6.8	6.8				9									1676		50	3.8			390	300									
29	4.32			6.8	6.7				9									1636	5200	56	3.5	2590	2175	370	300									
30	3.79			6.7	6.7				9									1742	5240	50	2.8	2585	2195	350	290									
31	3.87			6.7	6.7				10									1759																
Tot.	133.42																	53486																
Avg.	4.30			6.8	6.8				8.9			106		2	90		2	1782	5695	52.83	3.377	2721	2220	404	313.3							0.16	4	0.064

RESIDENTIAL
 COMMERCIAL
 INDUSTRIAL

INDUSTRIAL WASTE POPULATION EQUIVALENT

40989 19003 18047

FLOW CBOD TSS

OPERATOR

CERT. NO.

TOTAL NUMBER OF SEWER CONNECTIONS

SEWER CONNECTIONS 0 X 4 = 0 SEWERED POPULATION

PLANT TELEPHONE