



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

October 10, 2012

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

**RE: Cedar Creek WQTC, KPDES No: KY0098540
Discharge Monitoring Report-September 2012**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Cedar Creek WQTC, KPDES No.: KY0098540 for the month of September 2012.

Also attached are the third quarter biomonitoring DMR's.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMR's, please contact me at (502) 239-7574.

Sincerely,

A handwritten signature in cursive script that reads "Duane V. Wright".

Duane V. Wright
Process Supervisor Central Region

DVW/Cedar Creek 9.12.doc

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

NAME CEDAR CREEK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY CEDAR CREEK WQTC MSD

KY0098540
 PERMIT NUMBER

001 Y
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 METALS/BIOMONITORING/QUARTERLY EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40291
 ATTN: DENNIS THOMMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
12	07	01		12	09	31

NOTE: Read instructions before completing this form

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
HARDNESS, TOTAL (AS CaCO3) 00900 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	232	232	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
CADMIUM, DISSOLVED (AS CD) 01025 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	< 0.001	<0.001	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
COPPER, DISSOLVED (AS CU) 01040 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	< 0.006	<0.006	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
LEAD, DISSOLVED (AS PB) 01049 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	< 0.08	<0.08	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
ZINC, DISSOLVED (AS ZN) 01090 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.035	0.035	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
ZINC TOTAL RECOVERABLE 01094 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.037	0.037	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
CADMIUM TOTAL RECOVERABLE 01113 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	< 0.001	<0.001	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER GREG C. HEITZMAN INTERIM EXECUTIVE DIRECTOR TYPED OR PRINTED	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.					TELEPHONE 502 540-6000		DATE 12 10 15			
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)						SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>Greg C. Heitzman</i>		AREA CODE NUMBER		YEAR MO DAY	

NAME CEDAR CREEK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY CEDAR CREEK WQTC MSD

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0098540
 PERMIT NUMBER

001 Y
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 METALS/BIOMONITORING/QUARTERLY
 EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40291
 ATTN: DENNIS THOMMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
12	07	01		12	09	31

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
LEAD TOTAL RECOVERABLE 01114 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	< 0.08	<0.08	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
COPPER TOTAL RECOVERABLE 01119 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	< 0.006	<0.006	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
TOXICITY, FINAL CONC TOXICITY UNITS 61406 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	<1.00	(2G) TOXCTY	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	*****	1.0 DAILY MX	(2G) TOXCTY		QTRLY	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER GREG C. HEITZMAN INTERIM EXECUTIVE DIRECTOR	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under those statutes may include fines up to \$10,000 and/or maximum imprisonment of between 8 months and 5 years.)					TELEPHONE		DATE			
TYPED OR PRINTED						502 540-6000		12 10 15			
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY	

NAME OF TREATMENT PLANT CEDAR CREEK WTP

COUNTY JEFFERSON

MONTH OF: September 2012

KPDES PERMIT NUMBER KY0098540

PLANT CAPACITY 7.5 MGD

RECEIVING STREAM CEDAR CREEK

DATE	TOTAL FLOW (MILLION GALLONS)	RAW SEWAGE		SETTLABLE SOLIDS (mg/L)			DISSOLVED OXYGEN (mg/L)			SUSPENDED SOLIDS (mg/L)			5 DAY CBOD (mg/L)			ACTIVATED SLUDGE			AERATION BASIN						SLUDGE HANDLING					FINAL					
		GRIT REMOVED (CUBIC FEET)	SCREENINGS (CUBIC FEET)	RAW	FINAL	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	STREAM ABOVE	FINAL EFFLUENT	STREAM BELOW	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RETURN		WASTE D	DISSOLVED OXYGEN (mg/L)	MLSS (mg/L) x 1000	MLVSS (mg/L) x 1000	30 MIN.	60 MIN.	RAW			HAULED		NH3-N (mg/L)	FECAL COLIFORM (COLONIES/100ML)	Total Phosphorus		
																		GA/DA Y X 1000	MLSS x 1000							GA/DA Y X 1000	GALLONS X 1000	MLSS (mg/L) x 1000	MLVSS (mg/L) x 1000	GALLONS X 1000				% DRY SOLIDS	% VOLATILE SOLIDS
1	2.19			6.8	6.9				7.7								2.20	6160	60000	3.6	2810	2270	300	270											
2	2.87			6.7	6.8				7.9								2.06	6180	60000	3.4	2870	2160	290	270											
3	3.74			6.8	6.8	17.0			7.7		234		2	142		2	2.01	6350	60000	3.0	2730	1880	280	280							0.78	2	0.1		
4	2.82			7.0	6.9	17.0			8.2		106		2	97		2	2.09	5050	60000	3.4	2690	2210	270	270							0.45	2	0.1		
5	3.07			6.7	6.8	12.0			7.8		210		2	150		2	2.14	4780	60000	2.8	2740	2330	290	270							0.34	2	0.1		
6	3.41			6.7	6.8				7.4								2.12	5400	60000	3.6	2680	2120	270	250											
7	2.80			6.6	6.8				7.6								2.06	5020	60000	3.4	2730	2110	300	280											
8	5.60			6.7	6.8				7.4								2.12		60000	3.0															
9	4.07			6.7	6.9	25.0			7.7		430		2	165		2	2.67	4400	60000	2.2	2450	1890	290	270							0.22	2	0.128		
10	3.00			6.9	7.0	15.0			7.8		139		2	99		2	3.44	5230	60000	2.6	2870	2280	300	280							0.22	2	0.144		
11	3.19			6.7	6.9	18.0			8.6		112		2	78		2	3.62	4680	60000	2.9	2750	2190	310	280							0.62	2	0.14		
12	2.79			6.8	6.8				8.1								2.47	6650	60000	2.2	2970	2380	310	280											
13	2.19			6.8	6.8				8.0								1.30	4730	61000	2.1	2020	1610	240	220											
14	2.16			6.7	6.9				7.6								1.47	4930	60000	2.0	2450	2030	280	240											
15	2.20			6.8	6.8				7.4								1.40		60000	1.6			290	240											
16	2.27			6.7	6.9	7.0			7.8		124		2	100		2	1.28		60000	1.8			280	250							0.67	2	0.108		
17	2.13			6.8	6.8	12.0			7.9		234		2	141		2	1.12	4210	60000	2.2	2630	2110	330	290							2.40	2	0.1		
18	2.02			6.8	7.2	16.0			7.7		220		2	162		2	1.49	3980	60000	2.1	2510	2140	320	290							1.60	2	0.1		
19	1.90			6.7	7.0				7.8								1.56	4140	60000	2.0	2460	2040	320	280											
20	1.87			6.8	7.0				7.7								1.47	4940	60000	2.0	2410	1900	280	280											
21	1.87			6.9	6.9				7.8								1.41	4620	60000	2.6	2520	1960	270	270											
22	1.93			6.7	6.9				7.8								1.39		60000	2.2			250	250											
23	2.06			6.8	7.1	16.0			8.1		354		2	226		2	1.45		60000	2.7			260	260							0.34	2	0.1		
24	1.82			6.8	7.0	10.0			8.0		173		2	119		2	1.36	5240	60000	2.8	2700	2110	260	260							0.45	2	0.1		
25	2.24			6.7	6.8	14.0			7.6		336		2	164		2	1.42	5460	60000	2.4	2520	2050	300	270							0.39	2	0.1		
26	2.89			6.8	6.8				8.0								1.40	4760	60000	2.6	2480	2000	300	260											
27	4.41			6.8	6.8				8.7								1.46	9670	60000	3.2	2320	1920	290	250											
28	3.53			6.7	7.0				8.4								1.37	5740	60000	2.8	2460	1990	290	260											
29	3.27			6.9	6.9				8.1								1.32	6790	60000	2.1	2160	1530	270	230											
30	2.98			6.6	6.6				8.4								1.28	8010	60000	2.3	2300	1960	270	250											
31																																			
Tot.	83.29																53.95																		
Avg.	2.78			6.8	6.9	14.9			7.9		223		2	137		2	1.798	5484	60033	2.587	2569	2047	286.6	263.8							0.71	2	0.11		

RESIDENTIAL
COMMERCIAL
INDUSTRIAL

INDUSTRIAL WASTE POPULATION EQUIVALENT

26442
FLOW

18649
CBOD

24552
TSS

Joseph Shaun Smith
OPERATOR

20987
CERT. NO.

TOTAL NUMBER OF SEWER CONNECTIONS 0
SEWER CONNECTIONS 0 X 4 = 0 SEWERED POPULATION

502-239-7695
PLANT TELEPHONE

NAME CEDAR CREEK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY CEDAR CREEK WQTC MSD

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0098540
 PERMIT NUMBER

0012
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 NEW EXPANSION
 EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40291
 ATTN: DENNIS THOMMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
12	09	01		12	09	30

NOTE: Read instructions before completing this form

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
OXYGEN, DISSOLVED (DO)	*****	*****	***	7.4	*****	*****	(19) MG/L	0	1/1	GR		
00300 1 0 0	PERMIT MEASUREMENT	*****	*****	***	7.0	*****	(19) MG/L		THREE/WEEK	GRAB		
EFFLUENT GROSS VALUE					INST MIN							
PH	*****	*****	***	6.6	*****	7.2	(12) SU	0	1/1	GR		
00400 1 0 0	PERMIT MEASUREMENT	*****	*****	***	6.0	*****	(12) SU		THREE/WEEK	GRAB		
EFFLUENT GROSS VALUE					MINIMUM	MAXIMUM						
SOLIDS, TOTAL SUSPENDED	5119	7023	(26) LBS/DY	*****	223	288	(19) MG/L	0	3/7	CP		
00530 G 0 0	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L	THREE/WEEK	COMPOS		
RAW SEW/INFLUENT												
SOLIDS, TOTAL SUSPENDED	45	57	(26) LBS/DY	*****	2	2	(19) MG/L	0	3/7	CP		
00530 1 0 0	PERMIT MEASUREMENT	1876 MO AVG	2815 MX WK AV	(26) LBS/DY	*****	30 MO AVG	45 MX WK AV	(19) MG/L	THREE/WEEK	COMPOS		
EFFLUENT GROSS VALUE												
NITROGEN, AMMONIA TOTAL (AS N)	366	398	(26) LBS/DY	*****	17	21	(19) MG/L	0	3/7	CP		
00610 G 0 0	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L	THREE/WEEK	COMPOS		
RAW SEW/INFLUENT												
NITROGEN, AMMONIA TOTAL (AS N)	15	27	(26) LBS/DY	*****	0.7	2	(19) MG/L	0	3/7	CP		
00610 1 1 0	PERMIT MEASUREMENT	250 MO AVG	375 MX WK AV	(26) LBS/DY	*****	4 MO AVG	6 MX WK AV	(19) MG/L	THREE/WEEK	COMPOS		
EFFLUENT GROSS VALUE												
PHOSPHORUS, TOTAL (AS P)	3	4	(26) LBS/DY	*****	0.1	0.1	(19) MG/L	0	3/7	CP		
00665 1 0 0	PERMIT MEASUREMENT	63 MO AVG	94 MX WK AV	(26) LBS/DY	*****	1.0 MO AVG	1.5 MX WK AV	(19) MG/L	THREE/WEEK	COMPOS		
EFFLUENT GROSS VALUE												
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under those statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.							TELEPHONE		DATE		
GREG C. HEITZMAN INTERIM EXECUTIVE DIRECTOR								502	540-6000	12	10	15
TYPED OR PRINTED								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME CEDAR CREEK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY CEDAR CREEK WQTC MSD

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0098540
 PERMIT NUMBER

0012
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 NEW EXPANSION
 EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40291
 ATTN: DENNIS THOMMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
12	09	01		12	09	30

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
CP THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	2.78	5.60	(03) MGD	*****	*****	*****	***	0	CN	CN
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT DAILY MX	(03) MGD	*****	*****	*****	***		CONTINUOUS	CONTIN
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	2	2	(13) 100ML	0	3/7	GR
	PERMIT MEASUREMENT	*****	*****	***	*****	200 30DA GEO	400 7 DA GEO	(13) 100ML		THREE/WEEK	GRAB
BOD, CARBONACEOUS 05 DAY, 20C 80082 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	3049	3518	(26) LBS/DY	*****	137	170	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
BOD, CARBONACEOUS 05 DAY, 20C 80082 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	45	57	(26) LBS/DY	*****	2	2	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	625 MO AVG	938 MX WK AV	(26) LBS/DY	*****	10 MO AVG	15 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
BOD, CARB 5-DAY, 20 DEG C, PERCENT REMVL 80091 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	99	*****	*****	(23) CENT	0	1/30	CA
	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	99	*****	*****	(23) CENT	0	1/30	CA
	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER GREG C. HEITZMAN INTERIM EXECUTIVE DIRECTOR	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.				SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE		DATE		
TYPED OR PRINTED					<i>Greg C. Heitzman</i>		502 540-6000		12 10 15		
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)							AREA NUMBER		YEAR MO DAY		