



*Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org*

December 7, 2017

Cheryl Edwards
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Cedar Creek WQTC, KPDES No: KY0098540
Discharge Monitoring Report for November 2017.**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Cedar Creek WQTC, for the month of November 2017.

There were no exceedances, discharges or bypasses to report.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5849.

Sincerely,

A handwritten signature in cursive script that reads "Duane V. Wright".

Duane V. Wright
Process Supervisor

DVW/ Cedar Creek. 11/17.

Enclosures

Cc: V. Graves
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit			
Permit #:	KY0098540	Permittee:	Cedar Creek WQTC MSD
Major:	Yes	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 MUNICIPAL DISCHARGE
Facility:		Facility Location:	CEDAR CREEK WQTC MSD 8405 CEDAR CREEK RD LOUISVILLE, KY 40291

Report Dates & Status			
Monitoring Period:	From 11/01/17 to 11/30/17	DMR Due Date:	12/28/17
Status:		NetDMR Validated	

Considerations for Form Completion

Principal Executive Officer			
First Name:	James A.	Title:	Exec. Dir.
Last Name:	Parrott	Telephone:	502-540-6000

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	8.4					19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	7 INST MIN					19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	8			=	8.3	12 - SU	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	01/07 - Weekly	GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	127	=	208	26 - lb/d		=	3	=	4	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	1877 MO AVG	<=	2815 MX WK AV	26 - lb/d		<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=	246	=	447	19 - mg/L	01/07 - Weekly	CP - COMPOS			
					Permit Req.												0	01/07 - Weekly	24 - COMP24	
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	8	=	10	19 - mg/L	01/07 - Weekly	CP - COMPOS			
					Permit Req.												0	01/07 - Weekly	24 - COMP24	
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample	=	13	=	27	26 - lb/d		=	0.3	=	0.8	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	626 MO AVG	<=	939 MX WK AV	26 - lb/d		<=	10 MO AVG	<=	15 MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	2	--	Sample						=	0.5	=	0.6	19 - mg/L	01/07 - Weekly	CP - COMPOS			
					Permit Req.												0	01/07 - Weekly	24 - COMP24	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	4.982	=	6.265	03 - MGD								99/99 - Continuous	CN - CONTIN	
					Permit Req.													0	99/99 - Continuous	RE - Record (manual)
					Value NODI															
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	4.482	=	5.702	03 - MGD								99/99 - Continuous	CN - CONTIN	
					Permit Req.													0	99/99 - Continuous	RE - Record (manual)
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	10	=	73	13 - #/100mL	01/07 - Weekly	GR - GRAB			
					Permit Req.												0	01/07 - Weekly	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	123	=	156	26 - lb/d		=	3	=	3	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	626 MO AVG	<=	939 MX WK AV	26 - lb/d		<=	10 MO AVG	<=	15 MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample						=	218	=	331	19 - mg/L	01/07 - Weekly	CP - COMPOS			
					Permit Req.												0	01/07 - Weekly	24 - COMP24	
					Value NODI															
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample						=	99			23 - %	01/30 - Monthly	CA - CALCTD			
					Permit Req.												0	01/30 - Monthly	CA - CALCTD	
					Value NODI															
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample						=	99			23 - %	01/30 - Monthly	CA - CALCTD			
					Permit Req.												0	01/30 - Monthly	CA - CALCTD	
					Value NODI															

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments

Name	Type	Size
CC112017_COVER.pdf	pdf	381325
CC112017_MOR.pdf	pdf	47173

Report Last Saved By
Cedar Creek WQTC MSD

User: kevin.thompson@louisvillemsd.org
Name: Kevin Thompson
E-Mail: kevin.thompson@louisvillemsd.org
Date/Time: 2017-12-16 10:56 (Time Zone: -05:00)

Report Last Signed By

User: WRIGHTDUANE
Name: Duane Wright
E-Mail: duane.wright@louisvillemsd.org
Date/Time: 2017-12-18 09:00 (Time Zone: -05:00)

