



Safe, clean waterways

700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

November 13, 2018

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Cedar Creek WQTC, KPDES No: KY0098540
Discharge Monitoring Report for October 2018.**

Dear Mrs. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Cedar Creek WQTC, for the month of October 2018.

There were no exceedances, discharges or bypasses to report.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5849.

Sincerely,

Duane V. Wright
Process Supervisor

DVW/ Cedar Creek. 10/18.

Enclosures

Cc: V. Graves
R. Shaw

DMR Copy of Record

Permit			
Permit #:	KY0098540	Permittee:	Cedar Creek WQTC MSD
Major:	Yes	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 MUNICIPAL DISCHARGE
Facility:		Facility Location:	CEDAR CREEK WQTC MSD 8405 CEDAR CREEK RD LOUISVILLE, KY 40291

Report Dates & Status			
Monitoring Period:	From 10/01/18 to 10/31/18	DMR Due Date:	11/28/18
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	James A.	Title:	Exec. Dir.
Last Name:	Parrott	Telephone:	502-540-6000

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	9.4					19 - mg/L	01/07 - Weekly	GR - GRAB
					Permit Req.					>=	7 INST MIN					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample						=	8.1			=	8.2	12 - SU	01/07 - Weekly	GR - GRAB
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	01/07 - Weekly	GR - GRAB
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	140	=	174	26 - lb/d		=	3	=	3	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	1877 MO AVG	<=	2815 MX WK AV	26 - lb/d		<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI														
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=	312	=	420	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.												0	01/07 - Weekly	24 - COMP24
					Value NODI														
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	5	=	8	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.												0	01/07 - Weekly	24 - COMP24
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	17	=	23	26 - lb/d		=	0.4	=	0.5	19 - mg/L	01/07 - Weekly	24 - COMP24	
					Permit Req.	<=	250 MO AVG	<=	376 MX WK AV	26 - lb/d		<=	4 MO AVG	<=	6 MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample						=	0.4	=	0.6	19 - mg/L	01/07 - Weekly	24 - COMP24		
					Permit Req.												0	01/07 - Weekly	24 - COMP24
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	4.724	=	5.013	03 - MGD							99/99 - Continuous	CN - CONTIN	
					Permit Req.												0	99/99 - Continuous	RE - Record (manual)
					Value NODI														
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	3.922	=	4.297	03 - MGD							99/99 - Continuous	CN - CONTIN	
					Permit Req.												0	99/99 - Continuous	RE - Record (manual)
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	1	=	5	13 - #/100mL	01/07 - Weekly	GR - GRAB		
					Permit Req.												0	01/07 - Weekly	GR - GRAB
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	138	=	174	26 - lb/d		=	3	=	4	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	626 MO AVG	<=	939 MX WK AV	26 - lb/d		<=	10 MO AVG	<=	15 MX WK AV	19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample						=	206	=	395	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.												0	01/07 - Weekly	24 - COMP24
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample						=	99			23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.												0	01/30 - Monthly	CA - CALCTD
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample						=	99			23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.												0	01/30 - Monthly	CA - CALCTD
					Value NODI														

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments

Attachments

Name	Type	Size
CC102018_COVER.pdf	pdf	416401
CC102018_MOR.pdf	pdf	45932

Report Last Saved By
Cedar Creek WQTC MSD

User: kevin.thompson@louisvillemsd.org
Name: Kevin Thompson
E-Mail: kevin.thompson@louisvillemsd.org
Date/Time: 2018-11-21 10:02 (Time Zone: -05:00)

Report Last Signed By

User: WRIGHTDUANE
Name: Duane Wright
E-Mail: duane.wright@louisvillemsd.org
Date/Time: 2018-11-21 10:11 (Time Zone: -05:00)

