



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

September 22, 2010

Ms. Carolena Bentley
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

RE: Derek Guthrie WQTC, KPDES No: KY0078956
Discharge Monitoring Report
August 2010

Dear Ms. Bentley:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Derek Guthrie WQTC, for the month of August 2010.

There were no exceedances, bypasses or overflow reports for DRG WQTC for the month of August.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6031.

Sincerely,

John Kessel
Process Supervisor, West Region

JMK/West County 0810

Enclosures

cc: C. Roth
T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME **DEREK R. GUTHRIE WQTC MSD**
 ADDRESS **C/O CEDAR CREEK WQTC**
4522 ALGONQUIN PKWY
LOUISVILLE KY 40211
 FACILITY **DEREK R. GUTHRIE WQTC**

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0078956
 PERMIT NUMBER

0012
 DISCHARGE NUMBER

MAJOR
 (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL WASTEWATER
 EFFLUENT
 [] No Discharge

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	08	01		10	08	31

LOCATION **LOUISVILLE KY 40272**
 ATTN: **DENNIS THOMASSON SR. METRO OPS**

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
OXYGEN, DISSOLVED (DO) 00300 1 0 0	SAMPLE MEASUREMENT			***	5			(19) MG/L	0	01/01	GRAB	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	2 INST MIN	*****	*****	(19) MG/L		DAILY	GRAB	
BOD, 5-DAY (20 DEG. C) 00310 G 0 0	SAMPLE MEASUREMENT	45546	84622	(26) LBS/DY		275	475	(19) MG/L	0	01/01	CP	
RAW SEW/INFLUENT	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		DAILY	COMPOS	
BOD, 5-DAY (20 DEG. C) 00310 1 0 1	SAMPLE MEASUREMENT	1569	2794	(26) LBS/DY		9	15	(19) MG/L	0	01/01	CP	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	7506 MO AVG	11259 MX WK AV	(26) LBS/DY	*****	30 MO AVG	45 MX WK AV	(19) MG/L		DAILY	COMPOS	
PH 00400 1 0 0	SAMPLE MEASUREMENT			***	7.0		7.7	(12) SU	0	01/01	GR	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	6.0 MINIMUM	*****	9.0 MAXIMUM	(12) SU		DAILY	GRAB	
SOLIDS, TOTAL SUSPENDED 00530 G 0 0	SAMPLE MEASUREMENT	43868	51620	(26) LBS/DY		265	286	(19) MG/L	0	01/01	CP	
RAW SEW/INFLUENT	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		DAILY	COMPOS	
SOLIDS, TOTAL SUSPENDED 00530 1 0 1	SAMPLE MEASUREMENT	1082	1333	(26) LBS/DY		6	8	(19) MG/L	0	01/01	CP	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	7506 MO AVG	11259 MX WK AV	(26) LBS/DY	*****	30 MO AVG	45 MX WK AV	(19) MG/L		DAILY	COMPOS	
NITROGEN, AMMONIA TOTAL (AS N) 00610 G 0 0	SAMPLE MEASUREMENT	2818	2975	(26) LBS/DY		17	19	(19) MG/L	0	01/01	CP	
RAW SEW/INFLUENT	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		DAILY	COMPOS	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT, SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	10	09	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

NAME DEREK R. GUTHRIE WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
4522 ALGONQUIN PKWY
LOUISVILLE KY 40211
FACILITY DEREK R. GUTHRIE WQTC

KY0078956
PERMIT NUMBER

0012
DISCHARGE NUMBER

MAJOR (SUBR LV)
F - FINAL JEFFE
MUNICIPAL WASTEWATER
EFFLUENT
[] No Discharge

LOCATION LOUISVILLE KY 40272
ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	08	01		10	08	31

NOTE: Read instructions before completing this form

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	930	1071	(26) LBS/DY		5	7	(19) MG/L	0	01/01	CP	
	PERMIT MEASUREMENT	3253 MO AVG	4879 MX WK AV	(26) LBS/DY	*****	20 MO AVG	30 MX WK AV	(19) MG/L		DAILY	COMPOS	
NITROGEN, KJELDAHL TOTAL (AS N) 00625 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	1355	1637	(26) LBS/DY		7	9	(19) MG/L	0	01/07	CP	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		WEEKLY	COMPOS	
PHOSPHORUS, TOTAL (AS P) 00665 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	505	680	(26) LBS/DY		2.9	6	(19) MG/L	0	01/07	CP	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		WEEKLY	COMPOS	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	19.15	30.41	(03) MGD				***	0	CN	CN	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(03) MGD	*****	*****	*****	***		CONTINUOUS	CONTIN	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	20.61	32.72	(03) MGD				***	0	01/01	CN	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(03) MGD	*****	*****	*****	***		CONTINUOUS	CONTIN	
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			***			<0.010	(19) MG/L	0	01/01	GR	
	PERMIT MEASUREMENT	*****	*****	***	*****	*****	0.019 DAILY MX	(19) MG/L		DAILY	GRAB	
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			***		6	11	(13) 100ML	0	01/01	GR	
	PERMIT MEASUREMENT	*****	*****	***	*****	200 30DA GEO	400 7 DA GEO	(13) 100ML		DAILY	GRAB	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1310. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	10	09	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

PERMITTEE NAME/ADDRESS (include

Facility Name/Location if different)

NAME DEREK R. GUTHRIE WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
4522 ALGONQUIN PKWY
LOUISVILLE KY 40211
 FACILITY DEREK R. GUTHRIE WQTC

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0078956
 PERMIT NUMBER

001 2
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL WASTEWATER
 EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40272
 ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	08	01		10	08	31

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD, 5-DAY PERCENT REMOVAL 81010 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT			***	96			(23) CENT	0	01/30 MONTH	CAL	
	PERMIT MEASUREMENT	*****	*****	***	85 MO AVG	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT			***	97			(23) CENT	0	01/30 MONTH	CAL	
	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	10	09	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

PERMITTEE NAME/ADDRESS (include

Facility Name/Location if different)

NAME DEREK R. GUTHRIE WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 4522 ALGONQUIN PKWY
 LOUISVILLE KY 40211
 FACILITY DEREK R. GUTHRIE WQTC

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0078956
 PERMIT NUMBER

001 R
 DISCHARGE NUMBER

MAJOR
 (SUBR LV)
 F - FINAL JEFFE
 REASONABLE POTENTIAL
 EFFLUENT
 [] No Discharge

MONITORING PERIOD						
YEAR	MO	DAY		YEAR	MO	DAY
FROM 10	08	01	TO	10	08	31


LOCATION LOUISVILLE KY 40272
 ATTN: DENNIS THOMASSON SR. METRO OPS

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
CHROMIUM ,HEXAVALENT (AS CR) 01032 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			***		0.01	0.01	(19) MG/L	0	01/30	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		01/30	Comp
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 H J SCHARDEIN
 EXECUTIVE DIRECTOR
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.


 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
 502 540-6000
 AREA NUMBER
 DATE
 10 09 26
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Name of Sewage Treatment Plant: West County WTP Jefferson County Month of: August 2010
 KPDES Permit Number: KY0078958 Plant Capacity: 30 MGD Receiving Stream: Ohio River

Date	Total Flow (MG)	Raw Sewage		pH		Settleable Solids (mg/L)			Dissolved Oxygen (mg/L)			Suspended Solids (mg/L)			Total Solids (mg/L)			5-day BOD (mg/L)			Activated Sludge		Aeration Basin						Dig Sludge	Final									
		Grit Removed (cu ft)	Screenings (cu ft)	Raw	Final	Raw	Primary (or Sec)	Final	Stream Above	Final	Stream Below	Raw	Primary (or Sec)	Final	Raw	Primary (or Sec)	Final	Raw	Primary (or Sec)	Final	Million Gal/Day	MLSS mg/L X 1000	Gal/Day X 1000	Oxygen (mg/L) #1	Oxygen (mg/L) #2	MLSS (mg/L) X 1000 #1&2	MLVSS (mg/L) X 1000 #1&2	30 min. Settle.	SVI	% Solids	Phosphorus (mg/L)	TKN (mg/L)	Chlorine Residual (mg/L)	NH3-N (mg/L)	Fecal Coliform Col./100ml	Hexavalent Chromium	Hardness		
																																						Return	WAS
1	32.72			7.6	7.6				6.2		268	7		185		13		4490								1150	870	80.0	0.05			6.20	0.01	3.70	34				
2	23.71			7.3	7.3				6.8		284	7		318		12		2480								1150	880	70.0	0.08				0.01	5.20	4				
3	21.88			7.3	7.2				7.0		272	7		197		23		17200								1000	790	80.0	0.08	2.15		0.01	5.50	2					
4	20.57			8.2	7.1				6.1		310	5		612		18		2010								940	820	60.0	0.06			0.01	6.00	8					
5	20.72			7.6	7.7				6.4		246	9		794		16		2040								1010	810	70.0	0.07			0.01	5.30	6					
6	19.94			7.7	7.3				6.4		246	7		1020		13		1890								1070	810	70.0	0.07			0.01	7.20	606					
7	19.02			7.7	7.4				6.2		314	5		197		9		2040								1030	830	50.0	0.05			0.01	7.10	3					
8	18.51			7.4	7.4				6.0		278	7		293		10		2190								1050	870	50.0	0.05			8.50	0.01	6.80	2				
9	18.35			7.8	7.6				6.0		230	8		170		11		2140								1080	880	50.0	0.05			0.01	7.10	3					
10	18.36			7.6	7.5				6.0		336	6		227		12		2330								1030	880	80.0	0.08	1.73		0.01	6.80	15	0.01	214			
11	18.98			7.5	7.4				5.9		304	10		203		8		2220								1180	1040	80.0	0.07			0.01	6.80	34					
12	18.64			7.3	7.4				5.9		340	8		193		6		2270								1130	830	60.0	0.05			0.01	6.80	7					
13	18.71			7.3	7.2				5.9		244	7		194		4		2410								1210	800	70.0	0.08			0.01	6.00	10					
14	22.83			7.3	7.2				5.9		110	7		86		8		2350								1240	930	70.0	0.08			0.01	5.80	12					
15	31.24			7.2	7.1				5.7		204	8		148		10		2960								1110	910	60.0	0.05			6.30	0.01	4.30	9				
16	22.73			7.3	7.1				6.1		250	5		191		8		2750								1380	1060	90.0	0.07			0.01	4.50	5					
17	21.24			7.3	7.2				6.1		224	7		168		8		2710								1210	1010	90.0	0.07	1.82		0.01	4.60	7					
18	20.40			8.8	7.1				5.1		264	5		180		6		2740								1350	1120	80.0	0.08			0.01	4.40	4					
19	19.14			7.2	7.4				5.2		204	8		180		9		2850								1270	1020	80.0	0.08			0.01	4.80	4					
20	18.38			7.5	7.1				7.0		210	7		196		6		2410								1310	1070	80.0	0.08			0.01	6.00	7					
21	23.52			7.4	7.1				6.4		244	9		169		9		2410								1210	1030	80.0	0.07			0.01	5.20	8					
22	22.78			7.6	7.1				6.4		274	5		198		6		2800								1250	1090	80.0	0.08			5.70	0.01	4.30	2				
23	20.18			7.3	7.1				6.4		240	6		185		5		2450								1330	1040	80.0	0.08			0.01	4.30	2					
24	19.49			7.4	7.1				6.3		290	5		211		4		2590								1270	1040	80.0	0.08	5.83		0.01	3.90	3					
25	19.01			7.4	7.2				6.0		312	5		312		6		2460								1190	960	80.0	0.07			0.01	3.90	3					
26	18.58			7.5	7.1				6.0		132	4		148		4		2570								1080	1080	90.0	0.08			0.01	3.80	1					
27	18.29			7.4	7.2				6.3		322	4		487		4		2370								1310	940	90.0	0.07			0.01	5.90	8					
28	17.74			7.2	7.0				6.3		360	3		347		6		3080								990	740	80.0	0.08			0.01	5.80	2					
29	17.91			7.3	7.0				6.0		330	5		177		8		2810								1380	1100	80.0	0.08			6.70	0.01	5.30	2				
30	18.13			7.3	7.4				6.0		274	4		312		6		2410								1310	1070	90.0	0.07			0.01	5.50	2					
31	17.93			7.5	7.5				7.0		328	3		268		7		2510								1400	1180	100.0	0.07	2.78		0.01	5.50	10					
Total	639.6	0	0																																				
Avg.	20.63			7.5	7.3				6.2		265	6		275		9		2991.6	0.0	0.0						1180.97	953.87	75.16	0	2.86	6.68	0.01	5.41	6	0.01	214			

Total Number of Sewer Connections: 0
 Residential Connections: _____
 Commercial Connections: _____
 Industrial Connections: _____
 Sewer Connections X 4 = 0

Industrial Waste Population Equivalent
199489 Flow
278112 BOD
217262 TSS

Operator Kevin Thompson
 Cert. # #20683
 Phone # 540-6042