



*Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org*

February 24, 2011

Ms. Crystal Thompson
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

RE: Derek Guthrie WQTC, KPDES No: KY0078956
Discharge Monitoring Report
January 2011

Dear Ms. Thompson:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Derek Guthrie WQTC, for the month of January 2011.

Also included is an overflow flow report for the month of January.

There were no exceedences or bypass reports.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6031.

Sincerely,

A handwritten signature in black ink, appearing to read "J. Kessel", written in a cursive style.

John Kessel
Process Supervisor, West Region

JMK/West County 0111

Enclosures

cc: C. Roth
T. Singleton
R. Shaw



*Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com*

NAME **DEREK R. GUTHRIE WQTC MSD**
 ADDRESS **C/O CEDAR CREEK WQTC**
4522 ALGONQUIN PKWY
LOUISVILLE KY 40211
 FACILITY **DEREK R. GUTHRIE WQTC**

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0078956
 PERMIT NUMBER


001 2
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL WASTEWATER
 EFFLUENT
 [] No Discharge

LOCATION **LOUISVILLE KY 40272**
 ATTN: **DENNIS THOMASSON SR. METRO OPS**

MONITORING PERIOD							
FROM	YEAR	MO	DAY	TO	YEAR	MO	DAY
	11	01	01		11	01	31

NOTE: Read instructions before completing this form

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
OXYGEN, DISSOLVED (DO) 00300 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			***	7			(19) MG/L	0	01/01	GR	
	PERMIT MEASUREMENT	*****	*****	***	2 INST MIN	*****	*****	(19) MG/L		DAILY	GRAB	
BOD, 5-DAY (20 DEG. C) 00310 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	33335	37221	(26) LBS/DY		175	195	(19) MG/L	0	01/01	CP	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		DAILY	COMPOS	
BOD, 5-DAY (20 DEG. C) 00310 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	2965	4710	(26) LBS/DY		14	18	(19) MG/L	0	01/01	CP	
	PERMIT MEASUREMENT	7506 MO AVG	11259 MX WK AV	(26) LBS/DY	*****	30 MO AVG	45 MX WK AV	(19) MG/L		DAILY	COMPOS	
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			***	7.0		7.8	(12) SU	0	01/01	GR	
	PERMIT MEASUREMENT	*****	*****	***	6.0 MINIMUM	*****	9.0 MAXIMUM	(12) SU		DAILY	GRAB	
SOLIDS, TOTAL SUSPENDED 00530 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	40424	40716	(26) LBS/DY		213	241	(19) MG/L	0	01/01	CP	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		DAILY	COMPOS	
SOLIDS, TOTAL SUSPENDED 00530 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	2239	2520	(26) LBS/DY		11	14	(19) MG/L	0	01/01	CP	
	PERMIT MEASUREMENT	7506 MO AVG	11259 MX WK AV	(26) LBS/DY	*****	30 MO AVG	45 MX WK AV	(19) MG/L		DAILY	COMPOS	
NITROGEN, AMMONIA TOTAL (AS N) 00610 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	3024	3162	(26) LBS/DY		16	19	(19) MG/L	0	01/01	CP	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		DAILY	COMPOS	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	11	02	28
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME **DEREK R. GUTHRIE WQTC MSD**
 ADDRESS **C/O CEDAR CREEK WQTC**
4522 ALGONQUIN PKWY
LOUISVILLE KY 40211
 FACILITY **DEREK R. GUTHRIE WQTC**

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
DISCHARGE MONITORING REPORT (DMR)

KY0078956
 PERMIT NUMBER

001 2
 DISCHARGE NUMBER

MAJOR
 (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL WASTEWATER
 EFFLUENT
 [] No Discharge

LOCATION **LOUISVILLE KY 40272**
 ATTN: **DENNIS THOMASSON SR. METRO OPS**

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
11	01	01		11	01	31

NOTE: Read instructions before completing this form

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	1813	1893	(26) LBS/DY		9	10	(19) MG/L	0	01/01	CP
	PERMIT MEASUREMENT	3253 MO AVG	4879 MX WK AV	(26) LBS/DY	*****	20 MO AVG	30 MX WK AV	(19) MG/L		DAILY	COMPOS
NITROGEN, KJELDAHL TOTAL (AS N) 00625 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	2276	2718	(26) LBS/DY		11	12	(19) MG/L	0	01/07	CP
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		WEEKLY	COMPOS
PHOSPHORUS, TOTAL (AS P) 00665 1 0 1 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	336	382	(26) LBS/DY		1.8	2.1	(19) MG/L	0	01/07	CP
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		WEEKLY	COMPOS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	23.20	40.44	(03) MGD				***	0	CN	CN
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT Daily MAX	(03) MGD	*****	*****	*****	***		CONTINUOUS	CONTIN
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	23.46	43.33	(03) MGD				***	0	CN	CN
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT Daily MAX	(03) MGD	*****	*****	*****	***		CONTINUOUS	CONTIN
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			***			<0.010	(19) MG/L	0	01/01	GR
	PERMIT MEASUREMENT	*****	*****	***	*****	*****	0.019 DAILY MX	(19) MG/L		DAILY	GRAB
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT			***		1	2	(13) 100ML	0	01/01	GR
	PERMIT MEASUREMENT	*****	*****	***	*****	200 30DA GEO	400 7 DA GEO	(13) 100ML		DAILY	GRAB
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT, SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.					TELEPHONE		DATE			
H J SCHARDEIN EXECUTIVE DIRECTOR						502 540-6000		11 02 24			
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER				

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME DEREK R. GUTHRIE WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
4522 ALGONQUIN PKWY
LOUISVILLE KY 40211
 FACILITY DEREK R. GUTHRIE WQTC

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0078956
 PERMIT NUMBER

001 2
 DISCHARGE NUMBER


MAJOR (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL WASTEWATER
 EFFLUENT
 [] No Discharge

MONITORING PERIOD

FROM YEAR 11 MO 01 DAY 01 TO YEAR 11 MO 01 DAY 31

LOCATION LOUISVILLE KY 40272
 ATTN: DENNIS THOMASSON SR. METRO OPS

NOTE: Read instructions before completing this form

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
BOD, 5-DAY PERCENT REMOVAL 81010 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT			***	92			(23) CENT	0	01/30	CAL	
	PERMIT MEASUREMENT	*****	*****	***	85 MO AVG	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT			***	95			(23) CENT	0	01/30	CAL	
	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	11	02	24
TYPED OR PRINTED								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME DEREK R. GUTHRIE WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 4522 ALGONQUIN PKWY
 LOUISVILLE KY 40211
 FACILITY DEREK R. GUTHRIE WQTC

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0078956
 PERMIT NUMBER

001 R
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 REASONABLE POTENTIAL
 EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40272
 ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
11	01	01		11	01	31

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
CHROMIUM ,HEXAVALENT (AS CR)	SAMPLE MEASUREMENT			***		0.01	0.01	(19) MG/L	0	01/30	CP	
01032 1 0 0	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1007 AND 33 U.S.C. 1310. (Penalties under those statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	11	02	24
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YEAR	MO	DAY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)												

Name of Sewage Treatment Plant: West County WTP

Jefferson County

Month of: January 2011

Plant Capacity: 30 MGD

Receiving Stream: Ohio River

KPDES Permit Number: KY0078958

Date	Total Flow (MG)	Raw Sewage		pH		Settleable Solids (mg/L)			Dissolved Oxygen (mg/L)			Suspended Solids (mg/L)			Total Solids (mg/L)			5-day BOD (mg/L)			Activated Sludge		Aeration Basin						Dig Sludge		Final						
		Grift Removed (cu. ft.)	Screenings (cu. ft.)	Raw	Final	Raw	Primary (or Sec.)	Final	Stream Above	Final	Stream Below	Raw	Primary (or Sec.)	Final	Raw	Primary (or Sec.)	Final	Raw	Primary (or Sec.)	Final	Million Gal/Day	MLSS mg/L X 1000	Gal/Day X 1000	Oxygen (mg/L) #1	Oxygen (mg/L) #2	MLSS (mg/L) X 1000 #1a#2	MLVSS (mg/L) X 1000 #1a#2	80 min. Sett.S.	SVI	% Solids	Phosphorus (mg/L)	TKN (mg/L)	Chlorine Residual (mg/L)	NH3-N (mg/L)	Fecal Coliform /100ml	Hexavalent Chromium	Hardness
1	43.33			7.5	7.3			8.0		104		9				167		23		3810					1280	1080	100.0	0.08				0.01	8.30	1			
2	37.03			7.6	7.3			8.0		132		13				118		21		3720					1200	930	90.0	0.08			8.80	0.01	8.60	1			
3	29.25			7.6	7.6			8.0		138		11				129		31		3540					1310	1070	100.0	0.08				0.01	7.70	1			
4	25.55			7.5	7.5			8.0		210		12				251		25		2640					1420	1130	100.0	0.07	1.75			0.01	8.10	1			
5	24.54			8.0	7.5			8.0		230		8				118		7		3220					1380	1100	110.0	0.08				0.01	7.70	1			
6	23.45			7.6	7.6			8.0		192		8				157		10		3530					1330	1110	110.0	0.08				0.01	8.50	1			
7	22.43			7.6	7.3			8.0		188		10				128		9		3190					1310	1050	110.0	0.08				0.01	9.80	1			
8	21.82			7.6	7.3			8.0		212		13				148		11		2970					1520	1230	110.0	0.07				0.01	10.00	1			
9	20.84			7.7	7.5			8.0		258		10				217		15		2930					1310	1090	110.0	0.08				0.01	9.10	1			
10	20.36			7.5	7.4			8.0		254		10				258		11		2860					1390	1120	110.0	0.08				0.01	8.80	4			
11	19.78			7.8	7.5			8.0		238		10				183		8		2890					1380	1150	110.0	0.08	1.72	12.00		0.01	9.90	1	0.01	249	
12	19.88			7.6	7.5			8.0		244		8				182		7		2740					1300	1080	110.0	0.08				0.01	9.80	1			
13	19.23			7.6	7.5			9.0		298		8				215		10		2720					1370	1120	110.0	0.08				0.01	9.40	3			
14	19.20			7.5	7.5			8.0		186		8				170		10		2530					1350	1110	110.0	0.08				0.01	9.70	1			
15	19.91			7.5	7.4			8.0		258		10				218		15		2780					1280	1020	100.0	0.08				0.01	10.10	1			
16	19.43			7.6	7.5			8.0		206		10				206		14		2830					1570	1290	110.0	0.07				0.01	10.00	1			
17	19.03			7.5	7.5			7.0		280		10				178		14		2370					1280	1050	100.0	0.08				0.01	10.00	4			
18	22.75			7.8	7.4			8.0		258		13				184		17		2510					1200	1020	110.0	0.09	1.83			0.01	9.80	1			
19	25.88			9.4	7.3			8.0		198		17				135		14		2820					1390	1100	100.0	0.07		10.00		0.01	8.70	1			
20	23.50			7.7	7.7			8.0		182		12				141		14		2580					1320	1080	100.0	0.08				0.01	8.70	1			
21	23.33			7.6	7.4			7.5		192		14				143		21		2480					1070	880	100.0	0.09				0.01	9.50	4			
22	22.66			7.7	7.5			8.0		204		15				281		20		2700					1150	930	100.0	0.09				0.01	9.80	1			
23	21.23			7.8	7.4			8.0		222		17				182		15		2440					1150	940	100.0	0.09				0.01	9.50	1			
24	20.46			7.1	7.5			9.0		248		14				190		13		3020					1170	950	100.0	0.09				0.01	10.00	1			
25	21.48			7.0	7.1			8.0		210		12				215		16		2410					1170	940	100.0	0.09	2.13	11.00		0.01	9.00	2			
26	22.24			7.1	7.1			9.0		220		15				146		18		2850					1120	870	100.0	0.09				0.01	9.80	1			
27	22.61			7.8	7.8			9.0		284		8				200		11		2830					1140	930	100.0	0.09				0.01	9.90	2			
28	23.70			7.7	7.7			9.0		186		15				178		11		3580					1130	940	100.0	0.09				0.01	10.90	5			
29	25.14			7.6	7.7			9.0		228		14				140		13		1270					2750	1050	100.0	0.04				0.01	10.50	1			
30	24.28			7.8	7.7			9.0		188		12				137		13		2880					1230	1020	100.0	0.08		12.00		0.01	9.90	1			
31	23.08			7.7	7.7			9.0		190		10				173		11		3130					1230	990	100.0	0.08				0.01	10.00	1			
Total	###	0	0																																		
Avg.	23.46			7.6	7.5			8.2		213		11				175		14		2838.4						1328.71	1042.28	103.55	0	1.81	10.76	0.01	9.26	1	0.01	249	

Total Number of Sewer Connections: 0
 Residential Connections: _____
 Commercial Connections: _____
 Industrial Connections: _____
 Sewer Connections X 4 = 0

Industrial Waste Population Equivalent: _____
223458 Flow 201401 BOD 198828 TSS

Operator: Steve Patterson
 Cert. #: #5879
 Phone #: 540-8042



Report Selections: Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0078956	Facility ID MSD0277	Water Quality Treatment Center DEREK R. GUTHRIE	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-----------------------------	-------------------------------	---	---	-----------------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	64054	7014 JOHN PAUL LN		PENNSYLVANIA RUN	GROUND

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISDW: DRY WEATHER DISCHARGE	1193984	01/27/11 12:58 PM	SINGLETON	KESSEL	REPAIRED - ISSUE RESOLVED	01/27/11	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE - WATERS	01/27/11 01:07 PM	

Spot Inspections:

Discharge Amount:	225 GAL
Cause:	BREAKER FOR THE AIR COMPRESSOR THAT RUNS THE BUBBLER SYSTEM TRIPPED.
Clean Up:	MSD CLEANED & SANITIZED THE AREA. LIME WAS SPREAD AROUND THE AREA.
Control Zone:	TAPE & TEMPORARY SIGNS POSTED
Impact:	SEWAGE WATER OBSERVED
Repair:	VACTORED DISCHARGE SITE & WET WELL, REPAIRED ELECTRICAL SERVER & REPLACED AIR COMPRESSOR.

Notifications:

01/27/11 02:01 PM	DISPUB	TAPE & TEMPORARY SIGNS POSTED
01/27/11 01:02 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov