



Louisville and Jefferson County Metropolitan Sewer District  
700 West Liberty Street  
Louisville Kentucky 40203-1911  
502-540-6000  
[www.msdlouky.org](http://www.msdlouky.org)

September 16, 2013

Ms. Cheryl Edwards  
Kentucky Division of Water  
200 Fair Oaks Lane  
Frankfort, Kentucky 40601

RE: Derek Guthrie WQTC, KPDES No: KY0078956  
Discharge Monitoring Report  
August 2013

Dear Ms. Cheryl Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Derek Guthrie WQTC, for the month of August 2013.

There were no exceedences or bypasses reports during the month of August for the Derek Guthrie WQTC.

Also included are the overflow reports for the month of August.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6031.

Sincerely,

John Kessel  
Process Supervisor, West Region

JMK/West County 0113

Enclosures

cc: C. Roth  
T. Singleton  
R. Shaw



Beneficial Use of Louisville's Biosolids  
[www.louisvillegreen.com](http://www.louisvillegreen.com)



**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

**Attachments**

Name	Type	Size
DRG_MOR_082013.XLS	xls	113664
201308_DRGWQTC_Overflow.pdf	pdf	71952
DRG_Coverletter_092013.pdf	pdf	14714

**Report Last Saved By**

**DEREK R GUTHRIE WQTC MSD**

User: kessel@louisvillemtd.org

Date/Time: 2013-09-23 13:09 (Time Zone: -04:00)

Name: John Kessel

E-Mail: kessel@louisvillemtd.org



Report Selections: Last Full Month: 08/2013, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	79878	2423 LAMBORNE BLVD		POND CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISDW: DRY WEATHER DISCHARGE	1992894		8/6/13 3:30 pm	MARINO	MARINO	REPAIRED - ISSUE RESOLVED	08/07/2013	STRUCTURAL FAILURE	UNAUTHORIZED DISCHAGE - WATERS	08/07/13 01:35 AM	MAIN

**Discharge Reporting:**

Discharge Amount:	30,000 GAL
Cause:	STRUCTURE FAILURE OF MAIN SEWER
Clean Up:	MSD PERSONNEL CLEANED THE IMPACTED AREA
Control Zone:	PLACED TEMPORARY SIGNS ALSO CAUTION TAPE
Impact:	SEWAGE GOING INTO THE CREEK
Repair:	WORK ORDERS 1992573, FLUSHED AND REPAIRED THE MAIN SEWER
Public Notification:	ADVISED CUSTOMER ON SITE; ADVISED CUSTOMER BY DOOR CARD

**Notifications:**

7/26/13 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemad.org, eppc.ert@ky.gov, Sayre.Dennis@epamail.epa.gov, Charlie.Roth@ky.gov'
7/26/13 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemad.org, eppc.ert@ky.gov, Sayre.Dennis@epamail.epa.gov, Charlie.Roth@ky.gov'

Total Facilities Printed: 1

Total Work Orders Printed: 1