



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

January 12, 2015

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

RE: Derek Guthrie WQTC, KPDES No: KY0078956
Discharge Monitoring Report, December 2015

Dear Ms. Cheryl Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Derek Guthrie WQTC, for the month of December 2015.

There were no exceedence or bypass reports for the month of December for the Derek Guthrie WQTC.

Also included are the overflow reports for the month of December.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6031.
Sincerely,

A handwritten signature in black ink, appearing to read "J. Kessel", is written over a light blue horizontal line.

John Kessel
Process Supervisor, West Region

JMK/West County 12/15
Enclosures

cc: C. Roth
T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
2015_12_DRGWQTC_OverflowReport.pdf	pdf	117746
DRG_MOR_122015.xlsx	xlsx	45576
DRG_Cover.pdf	pdf	49059

Report Last Saved By

DEREK R GUTHRIE WQTC MSD

User: kevin.ries@louisvillemsd.org | Date/Time: 2016-01-15 13:14 (Time Zone: -05:00)
Name: Kevin Ries
E-Mail: kevin.ries@louisvillemsd.org

Name of Sewage Treatment Plant: West County WTP Jefferson County Month of: December 2015

KPDES Permit Number: KY0078956 Plant Capacity: 30 MGD Receiving Stream: Ohio River

Date	Total Flow (MG)	Raw Sewage		pH		Settleable Solids (mg/L)		Dissolved Oxygen (mg/L)		Suspended Solids (mg/L)			Total Solids (mg/L)			5-day BOD (mg/L)			Activated Sludge		Aeration Basin						Dig Sludge		Final									
		Grit Removed (cu. ft.)	Screenings (cu. ft.)	Raw	Final	Raw	Primary (or Sec.)	Final	Stream Above	Final	Stream Below	Raw	Primary (or Sec.)	Final	Raw	Primary (or Sec.)	Final	Raw	Primary (or Sec.)	Final	Million Gal/Day	MLSS mg/L X 1000	Gal/Day X 1000	Oxygen (mg/L) #1	Oxygen (mg/L) #2	MLSS (mg/L) X1000 #1	MLVSS (mg/L) X1000 #1	30 min. SettS.	SVI	% Solids	Phosphorus (mg/L)	TKN (mg/L)	Chlorine Residual (mg/L)	NH3-N (mg/L)	Fecal Coliform Col./100ml	Hexavalent Chromium	Hardness	
1	119.16			7.3	6.9				6.0				116		8				86		5					1440	1040	110.0	0.08					1.90	4			
2	75.16			7.2	7.5				7.2				184		4				164		8					1780	1300	150.0	0.08			2.50	0.01	1.60	6			
3	48.51			7.6	7.2				7.6				196		4				144		7					3830	2880	200.0	0.05				0.01	1.30	2			
4	37.00			7.2	7.3				7.7				195		4				270		8					3040	2250	170.0	0.06				0.01	1.10	5			
5	30.11			7.3	7.1				7.8				200		5				164		7					2690	1990	200.0	0.07				0.01	1.60	2			
6	27.28			7.3	7.1				7.6				590		4				144		8					2210	1640	200.0	0.09			2.80	0.01	1.90	2			
7	31.85			7.4	7.2				7.0				156		4				132		9					1020	764	180.0	0.18				0.01	2.50	3			
8	24.86			7.2	7.3				7.3				344		3				319		8					2560	1940	190.0	0.07	1.04			0.01	1.30	2		259	
9	23.56			7.4	7.4				7.4				380		3				281		6					2600	1970	190.0	0.07				0.01	1.00	2	0.003		
10	25.34			7.4	7.4				7.4				296		4				240		6					2420	1840	190.0	0.08				0.01	1.10	2			
11	22.41			7.2	7.1				7.2				390		4				367		5					2450	1880	180.0	0.07				0.01	0.62	4			
12	22.27			7.1	7.5				7.2				335		5				292		5					2510	1880	160.0	0.06				0.01	1.20	8			
13	22.27			7.2	7.2				7.1				304		4				218		5					1600	1200	170.0	0.11				0.01	1.40	7			
14	36.98			7.4	7.1				7.2				460		7				293		11					2820	2120	170.0	0.06				0.01	2.70	4			
15	25.92			7.1	7.0				7.0				284		7				207		8					3180	2360	160.0	0.05	3.38			0.01	0.73	4			
16	23.99			7.4	7.2				7.1				228		7				190		8					2680	1970	160.0	0.06			2.40	0.01	0.98	2			
17	22.16			7.2	7.3				7.0				448		6				332		6					2550	1930	170.0	0.07				0.01	1.30	5			
18	21.61			7.2	7.3				7.0				610		7				352		7					2540	1880	170.0	0.07				0.01	1.40	2			
19	20.88			7.1	7.2				7.0				390		7				366		8					2700	1860	160.0	0.06				0.01	2.00	3			
20	20.87			7.2	7.5				7.2				404		5				290		7					2330	1740	160.0	0.07				0.01	2.10	2			
21	22.90			7.2	7.1				7.0				600		3				397		5					2720	2060	170.0	0.06				0.01	2.40	2			
22	60.39			7.1	7.1				7.0				308		5				204		8					1810	1400	110.0	0.06	1.31			0.01	2.80	114			
23	39.78			7.3	7.3				7.0				376		10				184		10					5800	4290	150.0	0.03			3.30	0.01	1.80	3			
24	112.07			7.0	7.0				7.0				168		9				136		13					4800	3490	90.0	0.02				0.01	2.30	18			
25	64.68			7.1	7.2				7.3				160		7				160		11					2870	2220	90.0	0.03				0.01	3.00	4			
26	62.99			7.3	7.1				7.2				110		5				103		17					1310	990	100.0	0.08				0.01	3.70	3			
27	134.51			7.1	6.8				8.0				1020		29				457		26					930	730	70.0	0.08				0.01	2.80	3			
28	150.00			7.1	7.0				7.0				108		9				76		11					1310	920	90.0	0.07				0.01	1.50	2			
29	121.44			7.1	7.1				8.0				296		9				162		14					1690	1140	100.0	0.06	0.45	3.30		0.01	2.00	8			
30	78.20			7.4	7.4				7.0				126		12				88		20					1660	1150	100.0	0.06				0.01	3.20	6			
31	85.27			7.2	7.2				7.0				224		3				233		6					1830	1280	120.0	0.07				0.01	4.40	7			
Total	1614.41	0	0																		0.0		0.0															
Avg.	52.08			7.2	7.2				7.2				323		7				227		9					2441	1809.81	149.35	0	1.37	2.86	0.01	1.92	4	0.003	259		

Total Number of Sewer Connections: 0
 Residential Connections: _____
 Commercial Connections: _____
 Industrial Connections: _____
 Sewer Connections X 4 = 0

Industrial Waste Population Equivalent
495977 581108 667569
 Flow BOD TSS

Operator S. Patterson
 Cert. # #5879
 Phone # 502-540-6042

Report Selections: Period: 12/01/2015 00:00 thru 12/31/2015 23:59, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	25484	9317 LANTANA DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476651		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	01/13/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/28/15 07:40 AM	

Discharge Reporting:

Discharge Amount:	10,780 GAL
Cause:	RAIN EVENT CASUED A LACK OF SYSTEM CAPAITY
Clean Up:	MSD CLEANED & SANITIZED
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE ON THE GROUND
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED TO WARN THE PUBLIC.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 12/01/2015 00:00 thru 12/31/2015 23:59, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27116	10304 CAVEN AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2467174		12/01/2015	DAVIS	MATTHEWS	DOCUMENTED	11/15/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/01/15 10:25 PM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND BARRICADES
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

Notifications:

11/23/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/23/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 12/01/2015 00:00 thru 12/31/2015 23:59, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center				Receiving Stream of Treatment Center				Region	
KY0078956 (Cont'd)	MSD0277	DEREK R. GUTHRIE				OHIO RIVER				WEST	
<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476629		12/27/2015 1:50:00PM	SMITH	DAVIS	DOCUMENTED	11/15/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/29/15 04:00 AM	

Discharge Reporting:

Discharge Amount:	36,000 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS AND SIGNS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 12/01/2015 00:00 thru 12/31/2015 23:59, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	29948	6810 SANDSTONE BLVD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476624		12/27/2015	DAVIS	BOND JR	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/27/15 03:00 PM	

Discharge Reporting:

Discharge Amount:	1,875 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	NOTIFIED CUSTOMER ON SITE DOOR CARDS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 12/01/2015 00:00 thru 12/31/2015 23:59, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	31073	6808 SANDSTONE BLVD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476617		12/27/2015	DAVIS	BOND JR	DOCUMENTED	03/09/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/27/15 03:00 PM	

Discharge Reporting:

Discharge Amount:	1,875 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 12/01/2015 00:00 thru 12/31/2015 23:59, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	31074	6808 SANDSTONE BLVD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476621		12/27/2015	DAVIS	BOND JR	DOCUMENTED	02/24/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 03:00 PM	

Discharge Reporting:

Discharge Amount:	1,875 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 12/01/2015 00:00 thru 12/31/2015 23:59, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	60679	9114 CINDERELLA LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476648		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/28/15 08:40 AM	

Discharge Reporting:

Discharge Amount:	22,000 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE ON THE GROUND
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	MSD USED TEMPORARY SIGNS TO WARN THE PUBLIC

Notifications:

12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 12/01/2015 00:00 thru 12/31/2015 23:59, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	61266	4005 KIRBY LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476656		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	01/13/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/28/15 06:00 AM	

Discharge Reporting:

Discharge Amount:	53,750 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	MSD USED TEMPORARY SIGNS TO WARN PUBLIC

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 12/01/2015 00:00 thru 12/31/2015 23:59, treatment Plant: MSD0277 DEREK R. GUTHRIE, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD1010-PS	5006 LEA ANN WAY	LEA ANN WAY	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476660		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	12/15/2007	PUMPED OVERFLOW	UNAUTHORIZED DISCHAGE - WATERS	12/27/15 09:45 PM	

Discharge Reporting:

Discharge Amount:	1,990,000 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	MSD CLEANED AND SANITIZED THE AREA
Control Zone:	PERMANENT SIGNS POSTED
Impact:	SEWAGE PUMPED TO DITCH
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	PERMANENT SIGNS POSTED

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 8

Total Work Orders Printed: 9