



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

August 15, 2019

Ms. Crystal Dennis
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**Re: Derek Guthrie Water Quality Treatment Center
KPDES Permit No. KY0078956,
Discharge monitoring report for July 2019.**

Dear Ms. Crystal Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Derek Guthrie WQTC, KPDES No: KY0078956, for the month of July 2019.

There were no exceedances, overflows or bypass reports for the Derek Guthrie WQTC.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6031.

Sincerely,

Kevin Thompson
Process Supervisor, West Region

KLT/West County 07/19
Enclosures

cc: C. Roth
V. Graves
R. Shaw

81011 Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	97				23 - %		01/30 - Monthly	CA - CALCTD
				Permit Req.	>=	85 MO AV MN				23 - %	0	01/30 - Monthly	CA - CALCTD
				Value NODI									

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
201907_drg_coverletter.pdf	pdf	40144
201907_DRG_MOR.pdf	pdf	81565

Report Last Saved By

Derek R Guthrie WQTC MSD

User: staci.huber@louisvillemsd.org
 Name: Staci Huber
 E-Mail: staci.huber@louisvillemsd.org
 Date/Time: 2019-08-15 09:41 (Time Zone: -04:00)

Report Last Signed By

User: staci.huber@louisvillemsd.org
 Name: Staci Huber
 E-Mail: staci.huber@louisvillemsd.org
 Date/Time: 2019-08-16 13:02 (Time Zone: -04:00)

