



*Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org*

July 28, 2010

Ms Carolena Bentley
DMR Coordinator
200 Fair Oaks Lane
Frankfort, Kentucky 40601

RE: Floyds Fork WQTC, KPDES No: KY0102784
Discharge Monitoring Report for June 2010.

Dear Ms Bentley

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Floyds Fork WQTC for the month of June 2010.

Also included are the 2nd quarter biomonitoring DMR's.

There were no exceedences, bypass reports or overflow reports for the month of June at Floyds Fork WQTC.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5856.

Sincerely,

A handwritten signature in black ink, appearing to read "Duane V. Wright".

Duane V. Wright
Process Supervisor, Central Region

DJR/ Floyds Fork 0610

Enclosures

cc: C. Roth (DOW Louisville)
T. Singleton
R. Shaw



*Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com*

NAME FLOYDS FORK WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
FACILITY FLOYDS FORK WQTC MSD

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
DISCHARGE MONITORING REPORT (DMR)

KY0102784
 PERMIT NUMBER

001 1
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL DISCHARGE
 EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40245
ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 10	06	01	TO	10	06	30

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO) 00300 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	7	*****	*****	(19) MG/L	0	1/1	GR
	PERMIT MEASUREMENT	*****	*****	***	7 INST MIN	*****	*****	(19) MG/L		THREE/WEEK	GRAB
PH	SAMPLE MEASUREMENT	*****	*****	***	7.6	*****	8.6	(12) SU	0	1/1	GR
	PERMIT MEASUREMENT	*****	*****	***	6.0 MINIMUM	*****	9.0 MAXIMUM	(12) SU		THREE/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	3796	3913	(26) LBS/DY	*****	170	182	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	47	55	(26) LBS/DY	*****	2	2	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	813 MO AVG	1220 MX WK AV	(26) LBS/DY	*****	30 MO AVG	45 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
NITROGEN, AMMONIA TOTAL (AS N) 00610 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	348	375	(26) LBS/DY	*****	16	18	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	6	19	(26) LBS/DY	*****	0.3	0.9	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	54 MO AVG	81 MX WK AV	(26) LBS/DY	*****	2 MO AVG	3 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
PHOSPHORUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0.06	0.06	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	*****	*****	****	*****	1.0 MO AVG	1.5 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR							502	540-6000	10	07	25
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (include

Facility Name/Location if different)

NAME FLOYDS FORK WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
FACILITY FLOYDS FORK WQTC MSD

LOCATION LOUISVILLE KY 40245
ATTN: DENNIS THOMASSON SR. METRO OPS

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
DISCHARGE MONITORING REPORT (DMR)

KY0102784
 PERMIT NUMBER

001 1
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL DISCHARGE
 EFFLUENT
 [] No Discharge

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	06	01		10	06	30

NOTE: Read instructions before completing this form

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0	SAMPLE MEASUREMENT	2.72	4.20	(03) MGD	*****	*****	*****	***	0	CN	CN
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	REPORT MO AVG	REPORT DAILY MX	(03) MGD	*****	*****	*****	***		CONTINUOUS	CONTIN
COLIFORM, FECAL GENERAL 74055 1 0 0	SAMPLE MEASUREMENT	*****	*****	***	*****	5	9	(13) 100ML	0	3/7	GR
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	*****	200 30DA GEO	400 7 DA GEO	(13) 100ML		THREE/WEEK	GRAB
BOD, CARBONACEOUS 05 DAY, 20C 80082 G 0 0	SAMPLE MEASUREMENT	2308	2587	(26) LBS/DY	*****	104	129	(19) MG/L	0	3/7	CP
RAW SEW/INFLUENT	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
BOD, CARBONACEOUS 05 DAY, 20C 80082 1 0 0	SAMPLE MEASUREMENT	47	55	(26) LBS/DY	*****	2	2	(19) MG/L	0	3/7	CP
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	271 MO AVG	407 MX WK AV	(26) LBS/DY	*****	10 MO AVG	15 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
BOD, CARB 5-DAY, 20 DEG C, PERCENT REMVL 80091 K 0 0	SAMPLE MEASUREMENT	*****	*****	***	98	*****	*****	(23) CENT	0	1/30	CA
PERCENTREMOVAL	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0	SAMPLE MEASUREMENT	*****	*****	***	99	*****	*****	(23) CENT	0	1/30	CA
PERCENTREMOVAL	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER H J SCHARDEIN EXECUTIVE DIRECTOR	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.					TELEPHONE		DATE			
TYPED OR PRINTED						502 540-6000		10 07 25			
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY	

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME FLOYDS FORK WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
FACILITY FLOYDS FORK WQTC MSD

LOCATION LOUISVILLE KY 40245
ATTN: DENNIS THOMASSON SR. METRO OPS

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
DISCHARGE MONITORING REPORT (DMR)


KY0102784
 PERMIT NUMBER

001 X
 DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	06	01		10	06	30

MAJOR (SUBR LV)
 F - FINAL JEFFE
 MONTHLY METALS/BIOMONITORING EFFLUENT
 [] No Discharge

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
CADMIUM, DISSOLVED (AS CD) 01025 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.0001	<0.0001	(19) MG/L	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
COPPER, DISSOLVED (AS CU) 01040 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.002	<0.002	(19) MG/L	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
LEAD, DISSOLVED (AS PB) 01049 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.004	<0.004	(19) MG/L	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
ZINC, DISSOLVED (AS ZN) 01090 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.0365	0.0365	(19) MG/L	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
SAMPLE MEASUREMENT												
PERMIT MEASUREMENT												
SAMPLE MEASUREMENT												
PERMIT MEASUREMENT												
SAMPLE MEASUREMENT												
PERMIT MEASUREMENT												
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	10	07	25
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include

Facility Name/Location if different)

NAME FLOYDS FORK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY FLOYDS FORK WQTC MSD

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0102784
 PERMIT NUMBER

001 Y
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 QUARTERLY METALS/BIOMONITORING EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40245
 ATTN: DENNIS THOMASSON SR. METRO OPS


MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
10	04	01		10	06	30

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
HARDNESS, TOTAL (AS CaCO3) 00900 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	278	278	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS
ZINC TOTAL RECOVERABLE 01094 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.0365	0.0365	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
CADMIUM TOTAL RECOVERABLE 01113 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	< 0.0001	< 0.0001	(19) MG/L	0	1	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
LEAD TOTAL RECOVERABLE 01114 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	< 0.004	< 0.004	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS
COPPER TOTAL RECOVERABLE 01119 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.074	0.074	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
TOXICITY, FINAL CONC TOXICITY UNITS 61406 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	< 1.00	(2G) TOXCTY	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	*****	REPORT DAILY MX	(2G) TOXCTY		QTRLY	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 H J SCHARDEIN
 EXECUTIVE DIRECTOR
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under those statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.


 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE 502 540-6000
 DATE 10 07 25
 AREA CODE NUMBER YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME OF TREATMENT PLANT FLOYDS FORK

COUNTY JEFFERSON

MONTH OF: June 2010

KPDES PERMIT NUMBER KY0102784

PLANT CAPACITY 3.5 MGD

RECEIVING STREAM FLOYDS FORK

DATE	TOTAL FLOW (MILLION GALLONS)	RAW SEWAGE		pH		SETTLABLE SOLIDS (mg/L)			DISSOLVED OXYGEN (mg/L)			SUSPENDED SOLIDS (mg/L)			5 DAY CBOD (mg/L)			ACTIVATED SLUDGE			AERATION BASIN						SLUDGE HANDLING						FINAL			
		GRIT REMOVED (CUBIC FEET)	SCREENINGS (CUBIC FEET)	RAW	FINAL	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	STREAM ABOVE	FINAL EFFLUENT	STREAM BELOW	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	GAL/DAY X 1000	MLSS X 1000	GAL/DAY X 1000	DISSOLVED OXYGEN (mg/L)	MLSS (mg/L) X 1000	MLVSS (mg/L) X 1000	SETTLED SLUDGE VOLUME		RAW			HAULED			PHOSPHORUS, TOTAL (mg/L)	NH3-N (mg/L)	FECAL COLIFORMS (COLONIES/100ML)		
																								30 MIN.	60 MIN.	GALLONS X 1000	% DRY SOLIDS	% VOLATILE SOLIDS	% DRY SOLIDS	% VOLATILE SOLIDS	WITHDRAWN GALLONS X 1000					
1	2,570	5.1	5.1	7.5	8.2					8.9			142		2	115		2	1.63	4.37	34	3.9	2.94	2.02	320		49.85						0.06	0.73	4	
2	2,360	5.1	5.1	7.6	8.3					7.7			213		2	136		2	1.66	5.45	52	0.4	2.8	2.05	390		49.2						0.06	0.95	4	
3	2,300	5.1	5.1	7.6	8.2					8.2			190		2	136		2	1.45	7.11	62	0.3	2.97	2.21	360		50.4	1.44					0.08	1.10	4	
4	2,350	5.1	5.1	7.6	8.2					8.0									1.58	4.38	75	0.4	2.95	2.26	350		50.4									
5	2,440	5.1	5.1	7.6	8.2					8.1									1.48	5.01	40	0.4	3.03	2.59	360											
6	2,450	5.1	5.1	7.6	8.2					8.2									1.82	5.28	30	0.6	2.72	2.56	390											
7	2,230	5.1	5.1	7.7	8.4					8.1									1.51	5.04	60	0.6	2.27	1.56	350		31.5									
8	2,310	5.1	5.1	7.6	8.3					8.7			288		2	204		2	1.6	6.07		2.7	2.51	1.87	300		49.5						0.06	0.06	4	
9	4,200	5.1	5.1	7.6	8.3					8.1			64		2	50		2	1.47	6.68	44	0.7	2.48	1.84	350		55.5	1.41					0.06	0.06	4	
10	3,300	5.1	5.1	7.6	8.1					8.1			124		2	70		2	1.7	6.98	47	4	2.79	2.08	350		54.1						0.06	0.06	4	
11	2,760	5.1	5.1	7.6	8.3					8.4									1.81	6.29	44	4	2.57	1.94	350		45.2									
12	2,900	5.1	5.1	7.7	8.6					8.4									1.5	6.27		3.4	2.82	2.06	360											
13	2,690	5.1	5.1	7.7	7.6					8.2									1.76	5.2		2.8	2.63	1.94	3380											
14	3,290	5.1	5.1	7.8	8.4					8.6									1.72	5.79	71	1.4	2.76	2.07	390		50.4									
15	2,910	5.1	5.1	7.7	8.4					8.6			121		2	90		2	1.69	6.31	46	2.3	2.71	2	350		50.4						0.06	0.06	4	
16	3,160	5.1	5.1	7.6	8.3					7.4			187		2	79		2	1.71	7.21	70	1.9	2.61	1.94	350		50.4						0.06	0.06	4	
17	2,700	5.1	5.1	7.6	8.4					8.1			172		2	95		2	1.54	5.55	66	3	2.46	1.82	340		50.4	1.36					0.06	0.06	4	
18	2,630	5.1	5.1	7.6	8.4					8.0									1.6	5.26	53	2.7	2.54	1.85	350		50.4									
19	3,610	5.1	5.1	7.6	8.4					8.2									1.75	8.33	52	1.4	2.47	1.78	310											
20	3,130	5.1	5.1	7.7	8.4					8.3									1.76	6.25	50	3.8	2.52	1.83	300											
21	2,770	5.1	5.1	7.7	8.4					8.3									1.48	4.77	52	3.2	2.52	1.81	300		49.8									
22	2,770	5.1	5.1	7.6	8.5					8.4			253		2	78		2	1.73	4.35		2.4	2.57	2.05	300		49.2						0.06	0.06	4	
23	2,480	5.1	5.1	7.5	8.3					8.3			164		2	109		2	1.87	5.33	40	2.6	2.33	1.48	350		48.6	1.51					0.06	0.06	4	
24	2,470	5.1	5.1	7.6	8.4					8.2			118		2	89		2	1.81	6.04	40	2.9	3.49	2.78	320		43.8						0.06	0.06	50	
25	2,350	5.1	5.1	7.5	8.3					8.6									1.72	5.46	46	2.8	2.8	1.13	310		47.2									
26	2,420	5.1	5.1	7.5	8.4					8.3									1.87	6.95	40	2.6	2.48	2.37	330											
27	2,440	5.1	5.1	7.5	8.2					8.5									1.47	4.43	40	2.7	2.83	2.6	330											
28	2,680	5.1	5.1	7.4	8.2					8.2									1.72	4.6	21	0.6	2.58	1.8	320		50.4									
29	2,450	5.1	5.1	7.5	8.3					8.3									1.66	4.19		0.5	2.95	2.15	340		50.4									
30	2,330	5.1	5.1	7.6	8.4					8.3									1.65	3.99	25	0.6	3.04	2.16	350		50.4									
31																																				
Tot.	81.45	153	153							8.3			170		2	104		2	1.657	5.631	48	2.053	2.705	2.02	441.7		1077						0.06	0.27	5	
Avg.	2,715	5.1	5.1	7.6	8.3																							48.96	1.43							

RESIDENTIAL
COMMERCIAL
INDUSTRIAL

INDUSTRIAL WASTE POPULATION EQUIVALENT
25857 FLOW
13886 CBOD
18294 TSS

Earl Dunn
OPERATOR

7626
CERT. NO.

TOTAL NUMBER OF SEWER CONNECTIONS
SEWER CONNECTIONS 0 X 4 = 0 SEWERED POPULATION

502-241-9310
PLANT TELEPHONE