



MSD

Metropolitan Sewer District

Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

April 24, 2011

Crystal Thompson
DMR Coordinator
200 Fair Oaks Lane
Frankfort, Kentucky 40601

RE: Floyds Fork WQTC, KPDES No: KY0102784
Discharge Monitoring Report for March, 2011

Dear Ms. Thompson:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Floyds Fork WQTC for the month of March, 2011.

There were no exceedences ,or bypasses to report this month.

Enclosed is a overflow report, along with the 1st Quarter bio-monitoring (DMR)

If you have any questions concerning the attached DMR's, please contact me at (502)587-5856.

Sincerely,



Richard Mills
Process Supervisor, East Region

RM/ Floyds Fork 3.11

Enclosures

cc: C. Roth (DOW Louisville)
T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

NAME FLOYDS FORK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY FLOYDS FORK WQTC MSD

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0102784
 PERMIT NUMBER

0011
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL DISCHARGE
 EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40245
 ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
FROM 11	03	01	TO 11	03	31

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO) 00300 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	10	*****	*****	(19) MG/L	0	3/7	GR
	PERMIT MEASUREMENT	*****	*****	***	7 INST MIN	*****	*****	(19) MG/L		THREE/WEEK	GRAB
PH 00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	7.6	*****	8.3	(12) SU	0	3/7	GR
	PERMIT MEASUREMENT	*****	*****	***	6.0 MINIMUM	*****	9.0 MAXIMUM	(12) SU		THREE/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED 00530 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	4210	4929	(26) LBS/DY	*****	123	198	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	111	235	(26) LBS/DY	*****	3	4	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	813 MO AVG	1220 MX WK AV	(26) LBS/DY	*****	30 MO AVG	45 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
NITROGEN, AMMONIA TOTAL (AS N) 00610 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	405	466	(26) LBS/DY	*****	12	18	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 2 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	43	95	(26) LBS/DY	*****	0.9	1.5	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	136 MO AVG	203 MX WK AV	(26) LBS/DY	*****	5 MO AVG	7.5 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS
PHOSPHORUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0.4	0.5	(19) MG/L	0	3/7	CP
	PERMIT MEASUREMENT	*****	*****	****	*****	1.0 MO AVG	1.5 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 H J SCHARDEIN
 EXECUTIVE DIRECTOR
 TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under those statutes may include fines up to \$10,000 and/or maximum imprisonment of between 8 months and 5 years.

Richard Mills
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
 TELEPHONE 502 540-6000
 AREA CODE NUMBER
 DATE 11 04 26
 YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME FLOYDS FORK WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
8405 CEDAR CREEK RD
LOUISVILLE KY 40211
FACILITY FLOYDS FORK WQTC MSD

KY0102784
PERMIT NUMBER

001 1
DISCHARGE NUMBER

MAJOR (SUBR LV)
F - FINAL JEFFE
MUNICIPAL DISCHARGE EFFLUENT
[] No Discharge

LOCATION LOUISVILLE KY 40245

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
11	03	01	TO	11	03	31

NOTE: Read instructions before completing this form

ATTN: DENNIS THOMASSON SR. METRO OPS

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	4.01	11.06	(03) MGD	*****	*****	*****	***	0	CN	CN	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT DAILY MX	(03) MGD	*****	*****	*****	***		CONTINUOUS	CONTINUOUS	
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	35	192	(13) 100ML	0	3/7	GR	
	PERMIT MEASUREMENT	*****	*****	***	*****	200 30DA GEO	400 7 DA GEO	(13) 100ML		THREE/WEEK	GRAB	
BOD, CARBONACEOUS 05 DAY, 20C 80082 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	2098	2797	(26) LBS/DY	*****	65	112	(19) MG/L	0	3/7	CP	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
BOD, CARBONACEOUS 05 DAY, 20C 80082 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	90	117	(26) LBS/DY	*****	2	4	(19) MG/L	0	3/7	CP	
	PERMIT MEASUREMENT	271 MO AVG	407 MX WK AV	(26) LBS/DY	*****	10 MO AVG	15 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
BOD, CARB 5-DAY, 20 DEG C, PERCENT REMVL 80091 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	96	*****	*****	(23) CENT	0	1/30	CA	
	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	98	*****	*****	(23) CENT	0	1/30	CA	
	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	11	04	26
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MO	DAY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							Richard Mills				

NAME FLOYDS FORK WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
8405 CEDAR CREEK RD
LOUISVILLE KY 40211
FACILITY FLOYDS FORK WQTC MSD

KY0102784
PERMIT NUMBER

001 Y
DISCHARGE NUMBER

MAJOR
(SUBR LV)
F - FINAL JEFFE
QUARTERLY METALS/BIOMONITORING
EFFLUENT
[] No Discharge

LOCATION LOUISVILLE KY 40245
ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD							
YEAR	MO	DAY	TO	YEAR	MO	DAY	
FROM	11	01	01	TO	11	03	31

NOTE: Read instructions before completing this form

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
HARDNESS, TOTAL (AS CaCO3) 00900 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	270	270	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
ZINC TOTAL RECOVERABLE 01094 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.0143	0.0143	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
CADMIUM TOTAL RECOVERABLE 01113 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.001	<0.001	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
LEAD TOTAL RECOVERABLE 01114 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.005	0.005	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
COPPER TOTAL RECOVERABLE 01119 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.008	0.008	(19) MG/L	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS
TOXICITY, FINAL CONC TOXICITY UNITS 61406 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	<1.0	(2G) TOXCTY	0	1/90	CP
	PERMIT MEASUREMENT	*****	*****	***	*****	*****	REPORT DAILY MX	(2G) TOXCTY		QTRLY	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT MEASUREMENT										
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR							502	540-6000	11	04	26
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME OF TREATMENT PLANT FLOYDS FORK COUNTY JEFFERSON MONTH OF: March 2011
 KPDES PERMIT NUMBER KY0102784 PLANT CAPACITY 3.5 MGD RECEIVING STREAM FLOYDS FORK

DATE	TOTAL FLOW (MILLION GALLONS)	RAW SEWAGE		pH		SETTLEABLE SOLIDS (mg/L)			DISSOLVED OXYGEN (mg/L)			SUSPENDED SOLIDS (mg/L)			5 DAY CBOD (mg/L)			ACTIVATED SLUDGE			AERATION BASIN						SLUDGE HANDLING						FINAL		
		GRIT REMOVED (CUBIC FEET)	SCREENINGS (CUBIC FEET)	RAW	FINAL	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	STREAM ABOVE	FINAL EFFLUENT	STREAM BELOW	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	GAL/DAY X 1000	MLSS X 1000	WASTE X 1000	DISSOLVED OXYGEN (mg/L)	MLSS (mg/L) X 1000	MLVSS (mg/L) X 1000	30 MIN.	60 MIN.	RAW			HAULED			PHOSPHORUS TOTAL (mg/L)	NH3-N (mg/L)	FECAL COLIFORM (COLONIES/DRAWL)	
																										GALLONS X 1000	% DRY SOLIDS	% VOLATILE SOLIDS	% DRY SOLIDS	% VOLATILE SOLIDS	WITHDRAWN GALLONS X 1000				
1	5.78	2.48	2.48	7.4	7.8								11.6	89	2	35	2	1.65	7630	630	5	2260	1840	350								653	0.21	0.67	380
2	4.24	2.48	2.48	7.6	8.1								10.6	86	2	35	2	1.43	6530	60	4.9	2600	2110	400						1.61		693	0.20	0.06	87
3	3.83	2.48	2.48	7.5	8.2								11.2	99	2	46	2	1.59	5950	40	4.7	2320	1820	350							63	0.26	0.50	214	
4	3.53	2.48	2.48	7.6	8.0								11.9				1.05	5570	40	5.1	2320	1770	350							6.3					
5	5.38	2.48	2.48	7.4	7.9								11.5				1.51	6050	40	5	2460	1900	350							0					
6	5.71	2.48	2.48	7.6	8.0								11.2				1.47	6190	35	5.1	2870	1860	360							441					
7	4.23	2.48	2.48	7.3	7.7								12.2				1.53	5430	51	5.9	1880	1480	380							882					
8	2.30	2.48	2.48	7.5	7.9								11.4	107	3	56	2	1.52	5110	51	5.9	1950	1540	400						0	0.39	0.67	2750		
9	11.06	2.48	2.48	7.7	8.2								10.1	78	5	27	2	1.72	7950	52	0.5	2590	1240	250						189	0.52	2.50	1650		
10	7.45	2.48	2.48	7.6	8.0								11.1	68	3	29	2	1.79	6670	55	3.3	1960	1530	350						693	0.31	0.67	470		
11	4.97	2.48	2.48	7.7	8.0								11.4				1.58	6410	40	6.5	1970	1550	400						1.51		869				
12	4.20	2.48	2.48	7.4	7.8								10.9				1.51	5110	40	5.9	2000	1550	400							63			137		
13	3.75	2.48	2.48	7.3	7.7								11.2				1.45	5500	40	6.2	2010	1610	400							504			4		
14	3.91	2.48	2.48	7.7	8.2								11.5				1.43	3190	51	5	1910	1510	400							693			4		
15	4.33	2.48	2.48	7.5	8.0								11.2	118	2	70	2	1.45	5030	43	5.2	1880	1480	440						693	0.41	0.06	4		
16	3.98	2.48	2.48	7.7	8.2								10.9	113	2	73	2	1.36	5900	61	5.5	1900	1530	450						693	0.48	2.30	4		
17	3.66	2.48	2.48	7.7	8.2								10.3	123	2	68	7	1.4	5390	61	1.9	1600	1460	450					1.27		693	0.63	2.10	4	
18	3.32	2.48	2.48	7.6	8.1								10.1				1.32	4400	60	5.5	1710	1360	420							693					
19	3.47	2.48	2.48	7.5	8.0								11.1				1.31	3650	41	5.7	1620	1330	410							0					
20	3.41	2.48	2.48	7.2	7.6								11.0				1.36	3950	0	4.4	1620	1360	400							0					
21	3.20	2.48	2.48	7.7	8.1								10.4				1.22	4650	0	3.4	1840	1490	420							693					
22	3.07	2.48	2.48	7.6	8.1								10.9	177	2	104	2	1.3	4600	41	3.2	1870	1510	520						491	0.52	1.20	4		
23	3.02	2.48	2.48	7.7	8.3								10.0	161	3	125	2	1.25	4460	0	0.5	1930	1540	500					1.07		654	0.50	0.06	4	
24	2.91	2.48	2.48	7.7	8.3								10.4	255	3	106	2	1.25	4930	40	3	1920	1550	560						432	0.43	0.06	4		
25	2.83	2.48	2.48	7.6	8.1								10.6				1.37	3960	0	3.1	1960	1590	520							289					
26	2.96	2.48	2.48	7.7	8.3								10.3				1.34	5000	40	3	1980	1580	550							378					
27	2.95	2.48	2.48	7.7	8.1								10.5				1.37	4020	41	3	2110	1810	600							0					
28	2.73	2.48	2.48	7.5	8.0								11.5				1.18	4590	53	3.3	2110	1660	750							864					
29	2.71	2.48	2.48	7.5	8.0								11.6				1.04	4400	51	3.9	2160	1710	700							456					
30	2.73	2.48	2.48	7.5	8.1								11.5				1.53	4280	55	3.8	2160	1710	650							628					
31	2.70	2.48	2.48	7.5	8.0								11.3				1.38	4430	51	3.6	2150	1700	750							441					
Tot.	124.34	76.88	76.88														43.66													13847					
Avg.	4.01	2.48	2.48	7.6	8.0								11.0	123	3	65	2	1.408	5191	60.1	4.226	2052	1603	459				1.365		446.7	0.40	0.90	35		

RESIDENTIAL
 COMMERCIAL
 INDUSTRIAL

INDUSTRIAL WASTE POPULATION EQUIVALENT
 38200 FLOW
 12692 CBOD
 19567 TSS

michael carter sr OPERATOR
 6173 CERT. NO.

TOTAL NUMBER OF SEWER CONNECTIONS 0
 SEWER CONNECTIONS 0 X 4 = 0 SEWERED POPULATION

502-587-5867
 PLANT TELEPHONE



Report Selections: Excluding PPI, CSO, Excluding LAT and SSL, Result: WJS, Act Code: DISDW, DISREV

KPDES # KY0102784	Facility ID MSD0294	Water Quality Treatment Center FLOYDS FORK	Receiving Stream of Treatment Center FLOYDS FORK	Region CENT
-----------------------------	-------------------------------	--	--	-----------------------

Facility Type SMH Sewer Manhole	Facility ID 33003	Facility Address 815 TUCKER STATION RD	If Pump Station, Name of Pump Station:	Receiving Stream POPE LICK	Discharge to STREAM
---	-----------------------------	--	---	--------------------------------------	-------------------------------

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1220128	03/09/11 06:53 AM	GRIMES	COOPER II	DOCUMENTED	03/09/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/09/11 09:00 AM	MAIN

Spot Inspections:

Discharge Amount	20,000 GAL
Cause:	LACK OF SYSTEM CAPACITY - HEAVY RAIN
Clean Up:	CLEANED AND RESTORED IMPACTED AREA
Control Zone:	PLACED FLAGS AND TEMPORARY SIGNS
Impact	PAPER PRODUCTS OBSERVED
Repair:	THIS LOCATION IS INCLUDED IN IOAP

Notifications:

03/09/11 07:55 AM	DISPUB	MSD ADVISED CUSTOMER BY DOOR CARD AND SPOKE TO CUSTOMERS IN AREA
03/09/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Total Facilities Printed: 90
Total Work Orders Printed: 101