

MSD

Metropolitan Sewer District

Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

July 22, 2011

Cheryl Edwards
DMR Coordinator
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**RE: Floyds Fork WQTC, KPDES No: KY0102784
Discharge Monitoring Report for June 2011**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Floyds Fork WQTC for the month of June 2011.

Also attached are the second quarter Biomonitoring DMR's.

There were no exceedences, overflows or bypasses to report this month.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5856.

Sincerely,



Kevin Thompson
Process Supervisor, East Region

RM/ Floyds Fork 6.11

Enclosures

cc: C. Roth (DOW Louisville)
T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

Facility Name/Location if different)

DISCHARGE MONITORING REPORT (DMR)

NAME FLOYDS FORK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY FLOYDS FORK WQTC MSD

KY0102784
 PERMIT NUMBER

001 1
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL DISCHARGE EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40245
 ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
11	06	01		11	06	30

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
OXYGEN, DISSOLVED (DO) 00300 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	7	*****	*****	(19) MG/L	0	1/1	GR	
PH	PERMIT MEASUREMENT	*****	*****	***	7 INST MIN	*****	*****	(19) MG/L		THREE/WEEK	GRAB	
00400 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	7.4	*****	8.3	(12) SU	0	1/1	GR	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	***	6.0 MINIMUM	*****	9.0 MAXIMUM	(12) SU		THREE/WEEK	GRAB	
SOLIDS, TOTAL SUSPENDED 00530 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	3919	4909	(26) LBS/DY	*****	139	212	(19) MG/L	0	3/7	CP	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	70	110	(26) LBS/DY	*****	2	2	(19) MG/L	0	3/7	CP	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	813 MO AVG	1220 MX WK AV	(26) LBS/DY	*****	30 MO AVG	45 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
NITROGEN, AMMONIA TOTAL (AS N) 00610 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	505	534	(26) LBS/DY	*****	17	21	(19) MG/L	0	3/7	CP	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	15	42	(26) LBS/DY	*****	0.5	1	(19) MG/L	0	3/7	CP	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	54 MO AVG	81 MX WK AV	(26) LBS/DY	*****	2 MO AVG	3 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
PHOSPHORUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	0.2	0.2	(19) MG/L	0	3/7	CP	
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	****	*****	1.0 MO AVG	1.5 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	11	07	20
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT							AREA CODE	NUMBER	YEAR	MO	DAY
COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)												

Facility Name/Location (if different)

NAME **FLOYDS FORK WQTC MSD**
ADDRESS **C/O CEDAR CREEK WQTC**
8405 CEDAR CREEK RD
LOUISVILLE KY 40211
FACILITY **FLOYDS FORK WQTC MSD**

KY0102784
PERMIT NUMBER

001 1
DISCHARGE NUMBER

MAJOR
(SUBR LV)
F - FINAL JEFFE
MUNICIPAL DISCHARGE
EFFLUENT
[] No Discharge

LOCATION **LOUISVILLE KY 40245**

MONITORING PERIOD
FROM

YEAR	MO	DAY
11	06	01

 TO

YEAR	MO	DAY
11	06	30

ATTN: DENNIS THOMASSON SR. METRO OPS

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	3.59	9.69	(03) MGD	*****	*****	*****	***	0	CN	CN	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT DAILY MX	(03) MGD	*****	*****	*****	***		CONTINUOUS	CONTIN	
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	9	33	(13) 100ML	0	3/7	GR	
	PERMIT MEASUREMENT	*****	*****	***	*****	200 30DA GEO	400 7-DA GEO	(13) 100ML		THREE/WEEK	GRAB	
BOD, CARBONACEOUS 05 DAY, 20C 80082 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	2167	2474	(26) LBS/DY	*****	77	106	(19) MG/L	0	3/7	CP	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
BOD, CARBONACEOUS 05 DAY, 20C 80082 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	65	98	(26) LBS/DY	*****	2	2	(19) MG/L	0	3/7	CP	
	PERMIT MEASUREMENT	271 MO AVG	407 MX WK AV	(26) LBS/DY	*****	10 MO AVG	15 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
BOD, CARB 5-DAY, 20 DEG C, PERCENT REMVL 80091 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	97	*****	*****	(23) CENT	0	1/30	CA	
	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	98	*****	*****	(23) CENT	0	1/30	CA	
	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								502	540-6000	11	07	20
TYPED OR PRINTED								AREA CODE	NUMBER	YEAR	MO	DAY

Kevin Morgan
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
DISCHARGE MONITORING REPORT (DMR)

Facility Name/Location if different

NAME FLOYDS FORK WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
8405 CEDAR CREEK RD
LOUISVILLE KY 40211
FACILITY FLOYDS FORK WQTC MSD

KY0102784
PERMIT NUMBER


001 Y
DISCHARGE NUMBER

MAJOR (SUBR LV)
F - FINAL JEFFE
QUARTERLY METALS/BIOMONITORING EFFLUENT
[] No Discharge

LOCATION LOUISVILLE KY 40245
ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
11	06	01		11	06	30

NOTE: Read instructions before completing this form

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
HARDNESS, TOTAL (AS CaCO3) 00900 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	302	302	(19) MG/L	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
ZINC TOTAL RECOVERABLE 01094 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.024	0.024	(19) MG/L	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS	
CADMIUM TOTAL RECOVERABLE 01113 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.0006	0.0006	(19) MG/L	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS	
LEAD TOTAL RECOVERABLE 01114 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	<0.001	<0.001	(19) MG/L	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
COPPER TOTAL RECOVERABLE 01119 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.004	0.004	(19) MG/L	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		QTRLY	COMPOS	
TOXICITY, FINAL CONC TOXICITY UNITS 61406 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	<1.0	(2G) TOXCTY	0	1/90	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	*****	REPORT DAILY MX	(2G) TOXCTY		QTRLY	COMPOS	
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT, SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.							TELEPHONE		DATE		
H J SCHARDEIN EXECUTIVE DIRECTOR								592	540-6000	11	07	20
TYPED OR PRINTED								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA CODE	NUMBER	YEAR	MO

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

