



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

September 18, 2017

Cheryl Edwards
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Floyds Fork WQTC, KPDES No: KY0102784
Discharge Monitoring Report for August 2017.**


Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Floyds Fork WQTC, for the month of August 2017.

There were no exceedances, overflows or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6952.

Sincerely,



William Ford
Process Supervisor

WF/ Floyds Fork 08/17.

Cc: V. Teague
R. Shaw

DMR Copy of Record

Permit			
Permit #:	KY0102784	Permittee:	Floyds Fork WQTC MSD
Major:	Yes	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 MUNICIPAL DISCHARGE
Facility:		Facility Location:	FLOYDS FORK WQTC MSD 1100 BLUE HERON RD LOUISVILLE, KY 40245

Report Dates & Status			
Monitoring Period:	From 08/01/17 to 08/31/17	DMR Due Date:	09/28/17
Status:	NetDMR Validated		

Considerations for Form Completion

Principal Executive Officer			
First Name:	James A.	Title:	Executive Director
Last Name:	Parrott	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7				=	7				19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	>=	7 INST MIN									19 - mg/L	0	01/07 - Weekly	GR - GRAB	
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.2				=	7.4				12 - SU	0	01/07 - Weekly	GR - GRAB	
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM				12 - SU	0	01/07 - Weekly	GR - GRAB	
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	71	=	79	26 - lb/d	=	3	=	3		19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	1626 MO AVG	<=	2439 MX WK AV	26 - lb/d	<=	30 MO AVG	<=	45 MX WK AV		19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=	233	=	314		19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.							Req Mon MO AVG		Req Mon MX WK AV		19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	13	=	14		19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.							Req Mon MO AVG		Req Mon MX WK AV		19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	8	=	9	26 - lb/d	=	0.3	=	0.5		19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Permit Req.	<=	54.2 MO AVG	<=	81.3 MX WK AV	26 - lb/d	<=	1 MO AVG	<=	1.5 MX WK AV		19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	=	7.1	=	7.9	26 - lb/d	=	0.3	=	0.3		19 - mg/L	0	01/28 - Once Every 4 Weeks	CP - COMPOS	
					Permit Req.	<=	27.1 MO AVG	<=	40.7 MX WK AV	26 - lb/d	<=	.5 MO AVG	<=	.75 MX WK AV		19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	2.68	=	3.351	03 - MGD							0	99/99 - Continuous	CN - CONTIN	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD							0	99/99 - Continuous	RE - Record (manual)	
					Value NODI															
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	2.585	=	2.787	03 - MGD							0	99/99 - Continuous	CN - CONTIN	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD							0	99/99 - Continuous	RE - Record (manual)	
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	3	=	46		13 - #/100mL	0	01/07 - Weekly	GR - GRAB	
					Permit Req.						<=	130 30DA GEO	<=	240 7 DA GEO		13 - #/100mL	0	01/07 - Weekly	GR - GRAB	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	97	=	181	26 - lb/d	=	4	=	7		19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	325 MO AVG	<=	488 MX WK AV	26 - lb/d	<=	6 MO AVG	<=	9 MX WK AV		19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample						=	213	=	264		19 - mg/L	0	01/07 - Weekly	CP - COMPOS	
					Permit Req.							Req Mon MO AVG		Req Mon MX WK AV		19 - mg/L	0	01/07 - Weekly	24 - COMP24	
					Value NODI															
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample						=	98				23 - %	0	01/30 - Monthly	CA - CALCTD	
					Permit Req.							>=	85 MO AV MN				23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI															
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample						=	99				23 - %	0	01/30 - Monthly	CA - CALCTD	
					Permit Req.							>=	85 MO AV MN				23 - %	0	01/30 - Monthly	CA - CALCTD
					Value NODI															

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
082107_FF_MOR.pdf	pdf	100671
082017_FF_Coverletter.pdf	pdf	106843

Report Last Saved By

Floyds Fork WQTC MSD

User: kevin.thompson@louisvillemsd.org

Date/Time: 2017-09-18 09:43 (Time Zone: -04:00)

Name: Kevin Thompson

E-Mail: kevin.thompson@louisvillemsd.org

