



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

October 26, 2018

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Floyds Fork WQTC, KPDES No: KY0102784
Discharge Monitoring Report for September 2018.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Floyds Fork Water Quality Treatment Center for the month of September 2018.

We experienced two exceedances regarding our CBOD5 effluent limitations. One exceedance with our maximum weekly average loading limitations and one exceedance with our maximum weekly average concentration limitations.

Also, attached is an overflow report.

There were no bypasses to report.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6952.

Sincerely,

William Ford
Process Supervisor-Operations

WF/ Floyds Fork 09/18.

Cc: V. Teague
R. Shaw

DMR Copy of Record

Permit			
Permit #:	KY0102784	Permittee:	Floyds Fork WQTC MSD
Major:	Yes	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1 MUNICIPAL DISCHARGE
Facility:		Facility Location:	FLOYDS FORK WQTC MSD 1100 BLUE HERON RD LOUISVILLE, KY 40245

Report Dates & Status			
Monitoring Period:	From 09/01/18 to 09/30/18	DMR Due Date:	10/28/18
Status:		NetDMR Validated	

Considerations for Form Completion

Principal Executive Officer			
First Name:	James A.	Title:	Executive Director
Last Name:	Parrott	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	7					19 - mg/L	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	7 INST MIN					19 - mg/L	01/07 - Weekly	GR - GRAB	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.3			=	7.5	12 - SU	01/07 - Weekly	GR - GRAB	
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	01/07 - Weekly	GR - GRAB	
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	171	=	273	26 - lb/d		=	3	=	3	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	1626 MO AVG	<=	2439 MX WK AV	26 - lb/d		<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L	01/07 - Weekly	24 - COMP24	
					Value NODI														
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample						=	192	=	243	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.												01/07 - Weekly	24 - COMP24	
					Value NODI														
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample						=	8	=	13	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.												01/07 - Weekly	24 - COMP24	
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	12	=	16	26 - lb/d		=	0.3	=	0.5	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	54.2 MO AVG	<=	81.3 MX WK AV	26 - lb/d		<=	1 MO AVG	<=	1.5 MX WK AV	19 - mg/L	01/07 - Weekly	24 - COMP24	
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample	=	17.1	=	27.3	26 - lb/d		=	0.3	=	0.3	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.	<=	27.1 MO AVG	<=	40.7 MX WK AV	26 - lb/d		<=	0.5 MO AVG	<=	0.75 MX WK AV	19 - mg/L	01/07 - Weekly	24 - COMP24	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	5.25	=	9.089	03 - MGD							99/99 - Continuous	CN - CONTIN	
					Permit Req.													99/99 - Continuous	RE - Record (manual)
					Value NODI														
50050	Flow, in conduit or thru treatment plant	G - Raw Sewage Influent	0	--	Sample	=	4.78	=	8.721	03 - MGD							99/99 - Continuous	CN - CONTIN	
					Permit Req.													99/99 - Continuous	RE - Record (manual)
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample						=	1	=	1	13 - #/100mL	01/07 - Weekly	GR - GRAB		
					Permit Req.													01/07 - Weekly	GR - GRAB
					Value NODI														
X 80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	271	=	601	26 - lb/d		=	5	=	21	19 - mg/L	08/30 - Eight Every Month	CP - COMPOS	
					Permit Req.	<=	325 MO AVG	<=	488 MX WK AV	26 - lb/d		<=	6 MO AVG	<=	9 MX WK AV	19 - mg/L	01/07 - Weekly	24 - COMP24	
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample						=	139	=	197	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.													01/07 - Weekly	24 - COMP24
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample						=	96			23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.													01/30 - Monthly	CA - CALCTD
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample						=	98			23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.													01/30 - Monthly	CA - CALCTD
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter				

Code	Name	Monitoring Location	Field	Type	Description	Acknowledge
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quantity or Loading Sample Value 2	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. (Error Code: 1)	Yes

Comments

Attachments

Name	Type	Size
FFCoverLetter092018.pdf	pdf	102649
FFMOR092018.pdf	pdf	95055
September2018_OverflowReport_FloydsFork.pdf	pdf	104004

Report Last Saved By

Floyds Fork WQTC MSD

User: WILLIAM.FORD@LOUISVILLEMSD.ORG
Name: William Ford
E-Mail: william.ford@louisvillemsd.org
Date/Time: 2018-10-26 10:51 (Time Zone: -04:00)

Report Last Signed By

User: WILLIAM.FORD@LOUISVILLEMSD.ORG
Name: William Ford
E-Mail: william.ford@louisvillemsd.org
Date/Time: 2018-10-26 10:51 (Time Zone: -04:00)

DMR Copy of Record

Permit																				
Permit #:	KY0102784			Permittee:	Floyds Fork WQTC MSD				Facility:	FLOYDS FORK WQTC MSD										
Major:	Yes			Permittee Address:	700 W Liberty St Louisville, KY 40203				Facility Location:	1100 BLUE HERON RD LOUISVILLE, KY 40245										
Permitted Feature:	001 External Outfall			Discharge:	001-2 TOXICITY															
Report Dates & Status																				
Monitoring Period:	From 07/01/18 to 09/30/18			DMR Due Date:	10/28/18				Status:	NetDMR Validated										
Considerations for Form Completion																				
THREE 24-HOUR COMPOSITE SAMPLES ONE EACH COLLECTED EVERY OTHER DAY FOR A PERIOD OF 5 DAYS; IE - DAYS 1, 3 & 5																				
Principal Executive Officer																				
First Name:	James A.			Title:	Executive Director				Telephone:	502-540-6000										
Last Name:	Parrott																			
No Data Indicator (NODI)																				
Form NODI:	--																			
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units				
61406	Toxicity, final conc toxicity units	1 - Effluent Gross	0	--	Sample										<	1	2G - tox chronic		01/90 - Quarterly	24 - COMP24
					Permit Req.										<=	1 MAXIMUM	2G - tox chronic		01/90 - Quarterly	24 - COMP24
					Value NODI															
Submission Note																				
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																				
Edit Check Errors																				
No errors.																				
Comments																				
Attachments																				
No attachments.																				
Report Last Saved By																				
Floyds Fork WQTC MSD																				
User:	WRIGHTDUANE																			
Name:	Duane Wright																			
E-Mail:	duane.wright@louisvillemSD.org																			
Date/Time:	2018-10-26 10:53 (Time Zone: -04:00)																			
Report Last Signed By																				
User:	WILLIAM.FORD@LOUISVILLEMSD.ORG																			
Name:	William Ford																			
E-Mail:	william.ford@louisvillemSD.org																			
Date/Time:	2018-10-26 10:54 (Time Zone: -04:00)																			

Report Selections: Period: 09/01/2018 00:00 thru 09/30/2018 23:59, treatment Plant: MSD0294 FLOYDS FORK, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	110021	1005 CLASSIC WAY		LONG RUN	CATCH BASIN

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2984534		09/23/2018	GOODWIN	BRAZEL	REPAIRED - ISSUE RESOLVED	09/23/2018	MECHANICAL FAILURE	UNAUTHORIZED DISCHARGE - WATERS	09/23/18 12:20 AM	

Discharge Reporting:

Discharge Amount:	375 GAL
Cause:	ELECTRICAL PROBLEM WITH MSD EQUIPMENT/MSD1103-PS, FLOAT SWITCHES STUCK IN F.O.G. LAYER, WENT INTO HWW WITH NO PUMPS RUNNING AND NO ALARM.
Clean Up:	AREA DISINFECTED WITH LIME.
Control Zone:	PLACED TEMPORARY SIGNS AND CONES AROUND THE IMPACTED AREA.
Impact:	SEWAGE FOUND AROUND MANHOLE AND IN DRAINAGE DITCH.
Repair:	REPAIRED THE PUMP STATION BY BREAKING UP F.O.G. LAYER TO ALLOW FLOAT SWITCHES TO FUNCTION WO # 2984535.
Public Notification:	PLACED TEMPORARY SIGNS AND CONES AROUND THE IMPACTED AREA.

Notifications:

9/23/18 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
-----------------	--------	---



Report Selections: Period: 09/01/2018 00:00 thru 09/30/2018 23:59, treatment Plant: MSD0294 FLOYDS FORK, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	33003	815 TUCKER STATION RD		POPE LICK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2977412		09/09/2018	CRAWLEY	SMITH	DOCUMENTED	08/16/2018	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	09/09/18 02:45 AM	MAIN

Discharge Reporting:

Discharge Amount:	18,000 GAL
Cause:	LACK OF CAPACITY.
Clean Up:	DISCLEAN WORK ORDER #2977686 HAS BEEN CREATED.
Control Zone:	CAUSTION TAPE.
Impact:	DISCHARGE FROM MH.
Repair:	THIS IS INCLUDED IN THE IOAP.
Public Notification:	CONTROL ZONE W/CAUTION TAPE.

Notifications:

9/9/18 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
9/9/18 1:00 am	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION

Report Selections: Period: 09/01/2018 00:00 thru 09/30/2018 23:59, treatment Plant: MSD0294 FLOYDS FORK, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65516	12400 BRIERLY HILL PL		POPE LICK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2977405		09/08/2018	CRAWLEY	SMITH	DOCUMENTED	12/27/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	09/09/18 02:30 AM	MAIN

Discharge Reporting:

Discharge Amount:	18,000 GAL
Cause:	LACK OF CAPACITY.
Clean Up:	DISCLN WORK ORDER #2977690 HAS BEEN CREATED.
Control Zone:	CAUTION TAPE.
Impact:	DISCHARGE FROM MH.
Repair:	THIS IS INCLUDED IN THE IOAP.
Public Notification:	CONTROL ZONE WITH TAPE.

Notifications:

9/9/18 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
9/9/18 1:00 am	DISSNO	WAITING TO COMPLETE THE DISCHARGE INFORMATION

Report Selections: Period: 09/01/2018 00:00 thru 09/30/2018 23:59, treatment Plant: MSD0294 FLOYDS FORK, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD1171-PS	609 WOODLAKE DR	BECKLEY STATION RD	FLOYDS FORK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2976291		09/04/2018	GRAY JR	BINKLEY	REPAIRED - ISSUE RESOLVED	09/04/2018	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE - WATERS	09/04/18 07:49 PM	

Discharge Reporting:

Discharge Amount:	130 GAL
Cause:	FORCE MAIN BREAK.
Clean Up:	PIPE DISCHARGE SUBMERGED.
Control Zone:	INSIDE FENCE AREA.
Impact:	PUDDLE OF RAW WATER.
Repair:	PUMPS SHUT OFF, STATION HAULED.
Public Notification:	SIGNS.

Notifications:

9/5/18 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO:DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV
----------------	--------	---

Total Facilities Printed: 4

Total Work Orders Printed: 4

NAME OF TREATMENT PLANT FLOYDS FORK COUNTY JEFFERSON MONTH OF: September 2018
 KPDES PERMIT NUMBER KY0102784 PLANT CAPACITY 3.5 MGD RECEIVING STREAM FLOYDS FORK

DATE	TOTAL FLOW (MILLION GALLONS)	RAW SEWAGE		SETTLEABLE SOLIDS (mg/L)			DISSOLVED OXYGEN (mg/L)			SUSPENDED SOLIDS (mg/L)			5 DAY CBOD (mg/L)			ACTIVATED SLUDGE			AERATION BASIN						SLUDGE HANDLING				FINAL								
		GRIT REMOVED (CUBIC FEET)	SCREENINGS (CUBIC FEET)	RAW	FINAL	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	STREAM ABOVE	FINAL EFFLUENT	STREAM BELOW	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RETURN		WASTED	DISSOLVED OXYGEN (mg/L)	MLSS (mg/L) x 1000	MLVSS (mg/L) x 1000	SETTLED SLUDGE VOLUME		GALLONS x 1000	RAW		HAULED		PHOSPHORUS, TOTAL (mg/L)	NH3-N (mg/L)	ECOLI	Total Nitrogen	TOTAL FLOW (MILLION GALLONS)		
																		GAL/DAY x 1000	MLSS					GAL/DAY x 1000	90 MIN.		30 MIN.	% DRY SOLIDS	% VOLATILE SOLIDS	% DRY SOLIDS						% VOLATILE SOLIDS	WITHDRAWN GALLONS x 1000
1	4.360	2.48	2.48														0.79		30000	2.9			280		3000	3.74					0						3.74
2	3.660	2.48	2.48														0.85		30000	3.3			300		3000	3.07					0						3.07
3	3.560	2.48	2.48								212			185		2	0.83		40000	3.2			300		3000	3.02					0	0.30	0.47		12.03	3.02	
4	3.380	2.48	2.48	7.3	7.3				7.2								0.85	7120	40000	3.1	2250	1830	260		260	2.73					78500					2.73	
5	3.290	2.48	2.48	7.2													0.82	6620	40000	2.8	2300	1780	290		290	2.69					90800					2.69	
6	3.370	2.48	2.48	7.0													0.79	7600	40000	2.9	2050	1680	280		280	2.70					85800					2.7	
7	3.180	2.48	2.48	7.1													0.81	6360	40000	3.1	2220	1720	300		300	2.58					52800					2.58	
8	4.520	2.48	2.48	7.1													1.31	6980	40000	3.0	2330	1850	290		290	4.38					0					4.38	
9	10.920	2.48	2.48								75			59		5	2.15		40000	4.6			300		300	10.30					0	0.30	0.13		4.56	10.9	
10	6.550	2.48	2.48	7.5	7.4				7.2								1.90	8320	40000	4.7	2570	1980	300		300	5.42					56700					5.42	
11	5.260	2.48	2.48	7.2													1.13	6810	40000	3.6	2700	2030	310		310	4.14					90500					4.14	
12	3.990	2.48	2.48	7.3													0.79	10150	50000	2.8	2230	2010	260		260	3.54					74300					3.54	
13	3.570	2.48	2.48	7.2													1.33	7580	50000	3.9	2450	1960	300		300	3.23					74800					3.23	
14	3.370	2.48	2.48	7.3													0.97	7370	50000	3.1	2610	1970	320		320	2.96					38400					2.96	
15	3.370	2.48	2.48														0.86		40000	3.5			300		300	2.94					0					2.94	
16	3.430	2.48	2.48								236			3	197		0.78		40000	2.8			310		310	2.95					0					2.95	
17	3.306	2.48	2.48	7.2	7.3				7.2								0.88	6790	40000	2.9	2380	1830	300		300	2.74					72700					2.74	
18	3.020	2.48	2.48	7.1													0.86	6050	50000	2.8	2450	1930	300		300	2.70					57900					2.7	
19	3.000	2.48	2.48	7.2													0.72	5750	40000	2.9	2570	1980	300		300	2.64					48500					2.64	
20	2.950	2.48	2.48	7.2													0.69	7420	50000	3.2	2500	1940	330		330	2.60					47500					2.6	
21	3.610	2.48	2.48	7.1													0.76	6310	50000	3.0	2450	1960	330		330	3.03					47500					3.03	
22	4.600	2.48	2.48														0.84		40000	3.2			320		320	4.12					0					4.12	
23	9.480	2.48	2.48								243			3	116		2.40		40000	3.4			320		320	10.62					0	0.30	0.20		1.77	10.62	
24	14.000	2.48	2.48	7.2	7.5				7.1								3.11	6780	50000	5.5	2860	2250	300		300	13.89					36000					13.89	
25	12.190	2.48	2.48	7.2													2.62	5910	50000	6.1	1990	1560	300		300	11.19					76400					11.19	
26	11.540	2.48	2.48	7.1													3.26	9670	50000	6.3	2190	1660	250		250	10.62					59000					10.62	
27	6.850	2.48	2.48	7.0													2.65	7780	40000	5.6	2430	1820	250		250	6.03					79300					6.03	
28	4.960	2.48	2.48	7.1													2.68	6060	40000	6.5	2400	1870	300		300	4.58					90800					4.58	
29	4.300	2.48	2.48														2.55		40000	6.6			300		300	3.96					0					3.96	
30	4.020	2.48	2.48														2.43		40000	4.8			280		280	3.68					0					3.68	
31																																					
Tot.	157.61	74.4	74.4														42.79										143.4					1258200					143.39
Avg.	5.254	2.48	2.48	7.2	7.4				7.2		192			3	139		5	1.426	7181.5	42333.3	3.87	2397	1881	296		296	4.779					41940	0.30	0.27	1	7.95	4.780

RESIDENTIAL
COMMERCIAL
INDUSTRIAL

INDUSTRIAL WASTE POPULATION EQUIVALENT
50034 FLOW 35889 CBOD 39955 TSS

Randolph P. Kustes Jr.
OPERATOR

14555
CERT. NO.

TOTAL NUMBER OF SEWER CONNECTIONS
SEWER CONNECTIONS 0 X 4 = 0 SEWERED POPULATION

502-540-6000
PLANT TELEPHONE