



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

June 25, 2020

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Floyds Fork WQTC, KPDES No: KY0102784
Discharge Monitoring Report for May 2020.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Floyds Fork Water Quality Treatment Center for the month of May 2020.

There were no overflows, bypasses, or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)540-6952.

Sincerely,

William Ford
Process Supervisor-Operations

WEF/ Floyds Fork 05/20.

Cc: V. Teague
R. Shaw

81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	98.0							23 - %	01/30 - Monthly	CA - CALCTD
					Permit Req.	>=	85.0 MO AV MN							23 - %	01/30 - Monthly	CA - CALCTD
					Value NODI											

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
FFMAY2020Coverletter.pdf	pdf	26310.0
FFMOR052020.pdf	pdf	74705.0

Report Last Saved By

Floyds Fork WQTC MSD

User: staci.huber@louisvillemsd.org
 Name: Staci Huber
 E-Mail: staci.huber@louisvillemsd.org
 Date/Time: 2020-06-25 09:12 (Time Zone: -04:00)

Report Last Signed By

User: WILLIAM.FORD@LOUISVILLEMSD.ORG
 Name: William Ford
 E-Mail: william.ford@louisvillemsd.org
 Date/Time: 2020-06-25 10:41 (Time Zone: -04:00)

