

KPDES



KENTUCKY POLLUTANT
DISCHARGE ELIMINATION
SYSTEM

PERMIT

PERMIT NO.: KY0102784

AI NO.: 2158

**AUTHORIZATION TO DISCHARGE UNDER THE
KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM**

Pursuant to Authority in KRS 224,

Louisville & Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville, Kentucky, 40203

is authorized to discharge from a facility located at

Floyds Fork Water Quality Treatment Center
1100 Blue Heron Road
Louisville, Jefferson County, Kentucky

to receiving waters named

Floyds Fork

in accordance with effluent limitations, monitoring requirements and other conditions set forth in this permit.

This permit shall become effective on September 1, 2015.

This permit and the authorization to discharge shall expire at midnight, August 31, 2020.

July 10, 2015

Date Signed

A handwritten signature in black ink, appearing to read "Peter T. Goodmann".

**Peter T. Goodmann, Director
Division of Water**

**DEPARTMENT FOR ENVIRONMENTAL PROTECTION
Division of Water, 200 Fair Oaks Lane, Frankfort, Kentucky 40601**

THIS KPDES PERMIT CONSISTS OF THE FOLLOWING SECTIONS.

1. EFFLUENT AND MONITORING REQUIREMENTS 5

1.1. Compliance Monitoring Locations (Outfalls)..... 5

1.2. Effluent Limitations and Monitoring Requirements 5

1.3. Standard Effluent Requirements 6

1.4. Application Monitoring..... 6

2. COLLECTION SYSTEM REQUIREMENTS 11

2.1. Prohibitions 11

2.2. Capacity, Management, Operation and Maintenance (CMOM) Program 11

2.3. Pretreatment Program 14

3. STANDARD CONDITIONS..... 16

3.1. Duty to Comply..... 16

3.2. Duty to Reapply 16

3.3. Need to Halt or Reduce Activity Not a Defense 16

3.4. Duty to Mitigate 16

3.5. Proper Operation and Maintenance..... 16

3.6. Permit Actions 16

3.7. Property Rights 16

3.8. Duty to Provide Information 16

3.9. Inspection and Entry 16

3.10. Monitoring and Records..... 17

3.11. Signatory Requirement 17

3.12. Reporting Requirements 17

3.13. Bypass 19

3.14. Upset 20

4. WET TESTING REQUIREMENTS..... 22

4.1. Sampling Requirements 22

4.2. Test Requirements 22

4.3. Serial Dilutions 23

4.4. Controls..... 23

4.5. Test Methods..... 23

4.6. Reduction to Single Species Testing..... 23

4.7. Reduction in Monitoring Frequency 23

4.8. Reporting Requirements 24

4.9. Test Results..... 24

4.10. Accelerated Testing	24
4.11. WET TRE	24
5. OTHER CONDITIONS	27
5.1. Schedule of Compliance	27
5.2. Other Permits	27
5.3. Continuation of Expiring Permit.....	27
5.4. Antidegradation.....	27
5.5. Reopener Clause	27
5.6. Sludge Disposal	27
5.7. Certified Operators.....	27
5.8. Outfall Signage	28
6. MONITORING AND REPORTING REQUIREMENTS.....	30
6.1. KPDES Outfalls	30
6.2. Monthly Operating Reports (MORs)	30
6.3. Sufficiently Sensitive Analytical Methods.....	30
6.4. Certified Laboratory Requirements	30
6.5. Submission of DMRs.....	30

SECTION 1
EFFLUENT LIMITATIONS AND MONITORING
REQUIREMENTS

1. EFFLUENT AND MONITORING REQUIREMENTS

1.1. Compliance Monitoring Locations (Outfalls)

The following table lists the outfalls authorized by this permit, the latitude and longitude of each and the DOW assigned KPDES outfall number.

TABLE 1.					
No.	Treatment Provided	Latitude (N)	Longitude (W)	Receiving Waters	Description of Outfall
001	1M, 1R, 1T, 1U, 3L, 4I, 5X, 8E	38° 13' 32"	85° 28' 23"	Floyds Fork	Domestic (Sanitary) Wastewater [DSW]

1.2. Effluent Limitations and Monitoring Requirements

Beginning on the effective date and lasting through the term of this permit discharges from Outfall 001 shall comply with the effluent limitations

TABLE 2.										
EFFLUENT LIMITATIONS									MONITORING REQUIREMENTS	
Effluent Characteristic	STORET Code	Units	Loadings (lbs/day)		Concentrations				Frequency	Sample Type
			Monthly Average	Maximum Weekly Average	Minimum	Monthly Average	Maximum Weekly Average	Maximum		
Flow, Effluent	50050	MGD	Report	Report	N/A	N/A	N/A	N/A	Continuous	Continuous Recorder
Flow, Influent	50050	MGD	Report	Report	N/A	N/A	N/A	N/A	Continuous	Continuous Recorder
CBOD ₅ ¹ , Effluent	80082	mg/l	325	488	N/A	6 mg/l	9 mg/l	N/A	1/Week	24 Hr Composite
CBOD ₅ ¹ , Influent	80082	mg/l	N/A	N/A	N/A	Report	Report	N/A	1/Week	24 Hr Composite
CBOD ₅ ¹ , Percent Removal	80091	%	N/A	N/A	N/A	85	N/A	N/A	1/Month	Calculated ²
TSS, Effluent	00530	mg/l	1626	2439	N/A	30	45	N/A	1/Week	24 Hr Composite
TSS, Influent	00530	mg/l	N/A	N/A	N/A	Report	Report	N/A	1/Week	24 Hr Composite
TSS (Percent Removal)	81011	%	N/A	N/A	N/A	85	N/A	N/A	1/Month	Calculated ²
Ammonia (as mg/l NH ₃ N)										
May 1 – October 31	00610	mg/l	54.2	81.3	N/A	1 mg/l	1.5 mg/l	N/A	1/Week	24 Hr Composite
November 1 – April 30	00610	mg/l	163	244	N/A	3 mg/l	4.5 mg/l	N/A	1/Week	24 Hr Composite
E. Coli ³	51040	#/100 ml	N/A	N/A	N/A	130 ⁴	240 ⁵	N/A	1/Week	Grab

TABLE 2.										
EFFLUENT LIMITATIONS									MONITORING REQUIREMENTS	
Effluent Characteristic	STORET Code	Units	Loadings (lbs/day)		Concentrations				Frequency	Sample Type
			Monthly Average	Maximum Weekly Average	Minimum	Monthly Average	Maximum Weekly Average	Maximum		
Dissolved Oxygen	00300	mg/l	N/A	N/A	7	N/A	N/A	N/A	1/Week	Grab
pH	00400	SU	N/A	N/A	6.0	N/A	N/A	9.0	1/Week	Grab
Chronic WET ⁶	TT000	TU _c	N/A	N/A	N/A	N/A	N/A	1.00 TU _c	1/Quarter	(⁷)
Total Phosphorus	00665	mg/l	27.1	40.7	N/A	0.5 mg/l	0.75 mg/l	N/A	1/Week	24 Hr Composite
Total Nitrogen ⁸	00600	mg/l	N/A	N/A	N/A	Report	Report	N/A	1/Week	24 Hr Composite
The Design Flow of the POTW is 6.5 MGD. The Average Annual Flow of the POTW is 3.0 MGD										
¹ CBOD ₅ – Carbonaceous Biochemical Oxygen Demand, 5-day										
² Percent Removal is calculated using the following equation: $\text{Percent Removal} = \left[\frac{(\text{Monthly Average Influent} - \text{Monthly Average Effluent})}{\text{Monthly Average Influent}} \right] \times 100$										
³ E. Coli – Escherichia Coli Bacteria										
⁴ Thirty (30) day Geometric Mean										
⁵ Seven (7) day Geometric Mean										
⁶ WET – Whole Effluent Toxicity										
⁷ Three (3) 24-hour composite samples one each collected every other day for a period of five (5) days, i.e. days 1, 3, & 5										
⁸ Total Nitrogen is the summation of the analytical results for Total Nitrates, Total Nitrites, and Total Kjeldahl Nitrogen										

1.3. Standard Effluent Requirements

The discharges to waters of the Commonwealth shall not produce floating solids, visible foam or a visible sheen on the surface of the receiving waters.

1.4. Application Monitoring

POTWs are required to complete application Forms 1 and A which requires a minimum of 3 samples to be collected and analyzed. To ensure that sufficient samples are collected and analyzed DOW shall impose at a minimum annual sampling during years 2 through 4 of the permit term for those parameters required to be analyzed and reported on the application. The results of the application monitoring shall be submitted on an annual DMR and summarized on the renewal application. The permittee shall report the No Discharge (NODI) 9 – Conditional Monitoring Not Required This Period for years 1 and 5 of the permit.

TABLE 3.						
Effluent Characteristic	STORET Code	Units	Concentrations		Frequency	Sample Type
			Average	Maximum		
Temperature (May 1- October 31)	00011	°F	Report	Report	3/5 years	Grab
Temperature (November 1- April 30)	00011	°F	Report	Report	3/5 years	Grab
Total Kjeldahl Nitrogen (TKN)	51449	mg/l	Report	Report	3/5 years	Grab
Nitrate Plus Nitrite Nitrogen	51450	mg/l	Report	Report	3/5 years	Grab
Oil & Grease	00552	mg/l	Report	Report	3/5 years	Grab
Phosphorus (Total)	00665	mg/l	Report	Report	3/5 years	Grab
Total Dissolved Solids (TDS)	70296	mg/l	Report	Report	3/5 years	Grab
Antimony, Total Recoverable	01268	mg/l	Report	Report	3/5 years	Grab
Arsenic, Total Recoverable	00978	mg/l	Report	Report	3/5 years	Grab
Beryllium, Total Recoverable	00998	mg/l	Report	Report	3/5 years	Grab
Cadmium, Total Recoverable	01113	mg/l	Report	Report	3/5 years	Grab
Chromium, Total Recoverable	01118	mg/l	Report	Report	3/5 years	Grab
Copper, Total Recoverable	01119	mg/l	Report	Report	3/5 years	Grab
Lead, Total Recoverable	01114	mg/l	Report	Report	3/5 years	Grab
Mercury, Total Recoverable	71901	mg/l	Report	Report	3/5 years	Grab
Nickel, Total Recoverable	01074	mg/l	Report	Report	3/5 years	Grab
Selenium, Total Recoverable	00981	mg/l	Report	Report	3/5 years	Grab
Silver, Total Recoverable	01079	mg/l	Report	Report	3/5 years	Grab
Thallium, Total Recoverable	00982	mg/l	Report	Report	3/5 years	Grab
Zinc, Total Recoverable	01094	mg/l	Report	Report	3/5 years	Grab
Cyanide, Free (amenable to chlorination)	00722	mg/l	Report	Report	3/5 years	Grab
Phenolic Compounds, Total	70029	mg/l	Report	Report	3/5 years	Grab
Hardness, Total (as CaCO ₃)	00900	mg/l	Report	Report	3/5 years	Grab
Acrolein	34210	µg/l	Report	Report	3/5 years	Grab
Acrylonitrile	34215	µg/l	Report	Report	3/5 years	Grab
Benzene	34030	µg/l	Report	Report	3/5 years	Grab
Bromoform	32104	µg/l	Report	Report	3/5 years	Grab
Carbon tetrachloride	32102	µg/l	Report	Report	3/5 years	Grab
Chlorobenzene	34301	µg/l	Report	Report	3/5 years	Grab
Chlorodibromomethane	34306	µg/l	Report	Report	3/5 years	Grab
Chloroethane	85811	µg/l	Report	Report	3/5 years	Grab
2-Chloroethylvinyl ether (mixed)	34576	µg/l	Report	Report	3/5 years	Grab
Chloroform	32106	µg/l	Report	Report	3/5 years	Grab
Dichlorobromomethane	32101	µg/l	Report	Report	3/5 years	Grab
1,1-Dichloroethane	34496	µg/l	Report	Report	3/5 years	Grab

1,2-Dichloroethane	32103	µg/l	Report	Report	3/5 years	Grab
Trans-1,2-Dichloroethylene	34546	µg/l	Report	Report	3/5 years	Grab
1,1-Dichloroethylene	34501	µg/l	Report	Report	3/5 years	Grab
1,2-Dichloropropane	34541	µg/l	Report	Report	3/5 years	Grab
1,3-Dichloropropylene	77163	µg/l	Report	Report	3/5 years	Grab
Ethylbenzene (34371)	34371	µg/l	Report	Report	3/5 years	Grab
Methyl bromide (Bromomethane)	34413	µg/l	Report	Report	3/5 years	Grab
Methyl chloride (Chloromethane)	34418	µg/l	Report	Report	3/5 years	Grab
Methylene chloride	34423	µg/l	Report	Report	3/5 years	Grab
1,1,2,2-Tetrachloroethane	34516	µg/l	Report	Report	3/5 years	Grab
Tetrachloroethylene	34475	µg/l	Report	Report	3/5 years	Grab
Toluene	34010	µg/l	Report	Report	3/5 years	Grab
1,1,1-Trichloroethane	34506	µg/l	Report	Report	3/5 years	Grab
1,1,2-Trichloroethane	34511	µg/l	Report	Report	3/5 years	Grab
Trichloroethylene	39180	µg/l	Report	Report	3/5 years	Grab
Vinyl chloride	39175	µg/l	Report	Report	3/5 years	Grab
p-Chloro-m-cresol	82627	µg/l	Report	Report	3/5 years	Grab
2-Chlorophenol	34586	µg/l	Report	Report	3/5 years	Grab
2,4-Dichlorophenol	34601	µg/l	Report	Report	3/5 years	Grab
2,4-Dimethylphenol	34606	µg/l	Report	Report	3/5 years	Grab
4,6-Dinitro-o-cresol	34657	µg/l	Report	Report	3/5 years	Grab
2,4-Dinitrophenol	34616	µg/l	Report	Report	3/5 years	Grab
2-Nitrophenol	34591	µg/l	Report	Report	3/5 years	Grab
4-Nitrophenol	34646	µg/l	Report	Report	3/5 years	Grab
Pentachlorophenol	39032	µg/l	Report	Report	3/5 years	Grab
Phenol	34694	µg/l	Report	Report	3/5 years	Grab
2,4,6-Trichlorophenol	34621	µg/l	Report	Report	3/5 years	Grab
Acenaphthene	34205	µg/l	Report	Report	3/5 years	Grab
Acenaphthylene	34200	µg/l	Report	Report	3/5 years	Grab
Anthracene	34220	µg/l	Report	Report	3/5 years	Grab
Benzidine	39120	µg/l	Report	Report	3/5 years	Grab
Benzo(a)Anthracene	34526	µg/l	Report	Report	3/5 years	Grab
Benzo(a)pyrene	34247	µg/l	Report	Report	3/5 years	Grab
3,4-Benzofluoranthene	79531	µg/l	Report	Report	3/5 years	Grab
Benzo(ghi) perylene	34521	µg/l	Report	Report	3/5 years	Grab
Benzo(k)fluoranthene	34242	µg/l	Report	Report	3/5 years	Grab
Bis(2-chloroethoxy) methane	34278	µg/l	Report	Report	3/5 years	Grab
Bis(2-chloroethyl)ether	34273	µg/l	Report	Report	3/5 years	Grab

Bis(2-chloroisopropyl) ether	34283	µg/l	Report	Report	3/5 years	Grab
Bis(2-ethylhexyl) phthalate	39100	µg/l	Report	Report	3/5 years	Grab
4-Bromophenyl phenyl ether	34636	µg/l	Report	Report	3/5 years	Grab
Butyl benzyl phthalate	34292	µg/l	Report	Report	3/5 years	Grab
2-Chloronaphthalene	34581	µg/l	Report	Report	3/5 years	Grab
4-Chlorophenyl phenyl ether	34641	µg/l	Report	Report	3/5 years	Grab
Chrysene	34320	µg/l	Report	Report	3/5 years	Grab
Di-n-butyl phthalate	39110	µg/l	Report	Report	3/5 years	Grab
Dibenzo(a,h)Anthracene	34556	µg/l	Report	Report	3/5 years	Grab
1,2-Dichlorobenzene	34536	µg/l	Report	Report	3/5 years	Grab
1,3-Dichlorobenzene	34566	µg/l	Report	Report	3/5 years	Grab
1,4-Dichlorobenzene	34571	µg/l	Report	Report	3/5 years	Grab
3,3'-Dichlorobenzidine	34631	µg/l	Report	Report	3/5 years	Grab
Diethyl phthalate	34336	µg/l	Report	Report	3/5 years	Grab
Dimethyl phthalate	34341	µg/l	Report	Report	3/5 years	Grab
2,4-Dinitrotoluene	34611	µg/l	Report	Report	3/5 years	Grab
2,6-Dinitrotoluene	34626	µg/l	Report	Report	3/5 years	Grab
1,2-Diphenylhydrazine	34346	µg/l	Report	Report	3/5 years	Grab
Fluoranthene	34376	µg/l	Report	Report	3/5 years	Grab
Fluorene	34381	µg/l	Report	Report	3/5 years	Grab
Hexachlorobenzene	39700	µg/l	Report	Report	3/5 years	Grab
Hexachlorobutadiene	39702	µg/l	Report	Report	3/5 years	Grab
Hexachlorocyclo-pentadiene	34386	µg/l	Report	Report	3/5 years	Grab
Hexachloroethane	34396	µg/l	Report	Report	3/5 years	Grab
Indeno(1,2,3-cd)pyrene	34403	µg/l	Report	Report	3/5 years	Grab
Isophorone	34408	µg/l	Report	Report	3/5 years	Grab
Naphthalene	34696	µg/l	Report	Report	3/5 years	Grab
Nitrobenzene	34447	µg/l	Report	Report	3/5 years	Grab
N-Nitrosodi-N-propylamine	34428	µg/l	Report	Report	3/5 years	Grab
N-Nitrosodimethylamine (NDMA)	34438	µg/l	Report	Report	3/5 years	Grab
N-Nitrosodiphenylamine	34433	µg/l	Report	Report	3/5 years	Grab
Phenanthrene	34461	µg/l	Report	Report	3/5 years	Grab
Pyrene	34469	µg/l	Report	Report	3/5 years	Grab
1,2,4-Trichlorobenzene	34551	µg/l	Report	Report	3/5 years	Grab

SECTION 2

COLLECTION SYSTEM REQUIREMENTS

2. Collection System Requirements

2.1. Prohibitions

The following prohibitions apply to the collection system and its users:

- 1) There shall be no sanitary sewer overflows (SSOs);
- 2) No user shall introduce any pollutant or pollutants that will cause pass through or interference with the operation of the POTW and the collection system; or
- 3) No user shall introduce any of the following pollutants:
 - a. Pollutants which create a fire or explosion hazard, including but not limited to, wastestreams with a closed cup flashpoint of less than 140 °F (60 °C);
 - b. Pollutants which will cause corrosive structural damage or have a pH less than 5.0 standard units unless the POTW is designed to accommodate such pH levels;
 - c. Solid or viscous pollutants in amounts that would obstruct the flow to the POTW thus resulting in interference;
 - d. Any pollutant released in a discharge at such a volume or strength as to cause interference in the POTW;
 - e. Heat in such quantities that the temperature at the POTW treatment plant exceeds 104 °F (40 °C) unless the POTW requests and the Approval Authority grants alternate temperature limits;
 - f. Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass-through;
 - g. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems; and,
 - h. Any trucked or hauled waste except, at discharge points designated by the POTW

All POTW's, in cases where pollutants contributed by user(s) of the collection system are likely to result in reoccurring interference or pass-through, shall develop and enforce specific effluent limits for industrial user(s), and all other users, as appropriate, which, together with appropriate changes in the POTW treatment plant's facilities or operation, are necessary to ensure renewed and continued compliance with the POTW's KPDES permit or sludge use or disposal practices. POTW's with approved Pretreatment Programs meet this requirement.

2.2. Capacity, Management, Operation and Maintenance (CMOM) Program

2.2.1. Applicability

These conditions apply to all permittees with sewage infrastructure including the sewer system and wastewater treatment plant.

2.2.2. Goals

The goals of a comprehensive CMOM Program are:

- 1) To better manage, operate, and maintain the collection system;
- 2) Investigate capacity constrained areas of the collection system;
- 3) Proactively prevent or minimize SSOs;
- 4) Respond to SSO events; and
- 5) Proactively prevent or minimize the potential for the release of pollutants from ancillary activities through plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from storage areas.

To achieve these goals permittee shall complete a CMOM self-assessment using the checklist in the "Guide for Evaluating Capacity, Management, Operation, and Maintenance (CMOM) Programs at Sanitary Sewer Collection Systems," EPA 305-B-05-002 to determine the scope of the CMOM program.

The guide is available at: http://www.epa.gov/npdes/pubs/cmom_guide_for_collection_systems.pdf.

Upon completion of the checklist the permittee shall develop a proposed plan of action to achieve the goals of the CMOM program.

2.2.3. CMOM Plan

At a minimum the plan of action shall include the following:

- 1) Self-Assessment Summary (including recommended improvements and schedules);
- 2) Collection System Diagram;
- 3) Sewer Overflow Response Protocol (SORP);
- 4) Best Management Practices (BMPs); and
- 5) Any other constituent programs necessary to achieve the goals of the CMOM program (See <http://www.epa.gov/region04/water/wpeb/momproject/documents/r4prgguide.pdf> for additional guidance)

2.2.4. Collection System Diagram

The collection system diagram shall include the following:

- 1) Scale;
- 2) North arrow;
- 3) Date the map was drafted and most recent revision;
- 4) Street names;
- 5) Surface waters;
- 6) Service area boundaries;
- 7) Manholes and other access points (including structure IDs);
- 8) Sewer lines;
- 9) Pump stations (including structure IDs);
- 10) Wastewater treatment plants;
- 11) Permitted discharge points or outfalls (including CSO outfalls);
- 12) CSO regulators, for combined sewer systems; and
- 13) Locations of recurring SSOs that occurred within the last five (5) years prior to the effective date of this permit.

2.2.5. Sewer Overflow Response Protocol (SORP)

At a minimum the SORP shall include the following elements:

- 1) An overflow response procedure including designated responders for the permittee, response times, and cleanup methods;
- 2) A public advisory procedure;
- 3) A regulatory agency notification procedure.;
- 4) A manhole and pump station inspection schedule;
- 5) A procedure for addressing discharges to buildings caused by blockage, flow condition, or other malfunction in sewer infrastructure owned or operationally-controlled by the permittee; and
- 6) A requirement to include the structure ID for reported incidents.

2.2.6. Best Management Practices (BMPs)

BMPs are schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to implement the prohibitions listed in Section 2.1 of this permit. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw materials storage.

2.2.7. Implementation

Implementation shall be as soon as possible, but no later than one year from the effective date of the permit or as specified in the schedule of compliance for this permit.

2.2.8. Documentation

The permittee shall maintain all applicable CMOM program documents at the facility and make them available upon request to EEC personnel. Initial copies and modification thereof shall be sent to DOW upon request.

2.2.9. Modification

The permittee shall amend CMOM Programs documentation whenever there is a change in the facility or change in operation of the facility which materially affects the requirements specified in applicable documents.

2.2.10. Modification for Ineffectiveness

If any of the CMOM programs prove to be ineffective in achieving the general objective of preventing and eliminating SSOs and other unauthorized discharges, the permit, and/or specific CMOM programs shall be subject to modification to address deficiencies. If at any time following the issuance of this permit any of the CMOM programs are found to be inadequate pursuant to a state or federal site inspection or review, affected CMOM program documents shall be modified to incorporate such changes necessary to resolve concerns.

2.3. Pretreatment Program

DOW has approved the Pretreatment Program developed by the permittee on September 9, 1987.

The permittee shall:

- 1) Be responsible for the performance of all pretreatment requirements contained in 40 CFR Part 403;
- 2) Implement and enforce its approved POTW pretreatment program;
- 3) Enforce the requirements promulgated under Sections 307(b), 307(c), 307(d), and 402(b) of the Act;
- 4) Cause industrial users subject to federal categorical standards to achieve compliance no later than the date specified in those requirements or, in the case of a new industrial user, upon commencement of the discharge; and
- 5) Be subject to enforcement actions, penalties, fines, and other remedies by the Cabinet.

The pretreatment program and all of its elements are incorporated as enforceable conditions of the KPDES permit. The Cabinet may initiate enforcement action against a POTW and against an industrial user for noncompliance with applicable standards and requirements as provided in KRS 224.16-050(1), 224.70-110, and 224.73-120, and pursuant to the Clean Act.

During the 4th quarter of the reporting year DOW shall provide the permittee with instructions on the preparation and submittal of the Annual Pretreatment Program Report. The annual report shall be prepared in accordance with these instructions and shall be in the proper format and include sufficient detail such that DOW can ascertain compliance with the Pretreatment Program Requirements. The report is to be submitted to DOW's Surface Water Permits Branch no later than March 1st of the following calendar year. Annual reports not in the proper format, that do not include all the necessary elements, that are not sufficient detail, or are received after March 1st are incomplete and is a violation of the KPDES permit unless DOW has granted an extension.

SECTION 3

STANDARD CONDITIONS

3. STANDARD CONDITIONS

3.1. Duty to Comply

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of KRS Chapter 224 and is grounds for enforcement action; for permit termination, revocation and reissuance, modification, or denial of a permit renewal application. Any person who violates applicable statutes, who fails to perform any duty imposed, or who violates any determination, permit, administrative regulation, or order of the cabinet promulgated pursuant thereto shall be liable for a civil penalty as provided at KRS 224.99.010.

3.2. Duty to Reapply

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for a new permit.

3.3. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a permittee in an enforcement action, that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

3.4. Duty to Mitigate

The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

3.5. Proper Operation and Maintenance

The permittee shall at all times, properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

3.6. Permit Actions

This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, termination, notification of planned changes or anticipated noncompliance does not stay any permit condition.

3.7. Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege.

3.8. Duty to Provide Information

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Director upon request, copies of records required to be kept by this permit.

3.9. Inspection and Entry

The permittee shall allow the Director or an authorized representative (including an authorized contractor acting as a representative of the Director), upon presentation of credentials and other documents as may be required by law, to:

(1) Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;

- (2) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (3) Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- (4) Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by KRS 224, any substances or parameters at any location.

3.10. Monitoring and Records

- (1) Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- (2) Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities which shall be retained for a period of at least five (5) years (or longer as required by 401 KAR 5:065, Section 2(10)), the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Director at any time.
- (3) Records of monitoring information shall include:
 - (i) The date, exact place, and time of sampling or measurements;
 - (ii) The individual(s) who performed the sampling or measurements;
 - (iii) The date(s) analyses were performed;
 - (iv) The individual(s) who performed the analyses;
 - (v) The analytical techniques or methods used; and
 - (vi) The results of such analyses.
- (4) Monitoring must be conducted according to test procedures approved under 401 KAR 5:065, Section 2(8) unless another method is required under 401 KAR 5:065, Section 2(9) or (10).
- (5) KRS 224.99-010 provides that any person who knowingly violates KRS 224.70-110 or other enumerated statutes, or who knowingly renders inaccurate any monitoring device or method required to be maintained under this permit, shall be guilty of a Class D felony and, upon conviction, shall be punished by a fine of not more than \$25,000, or by imprisonment for not more than one (1) year, or both. Each day upon which a violation occurs shall constitute a separate violation.

3.11. Signatory Requirement

- (1) All applications, reports, or information submitted to the Director shall be signed and certified pursuant to 401 KAR 5:060, Section 4.
- (2) KRS 224.99-010 provides that any person who knowingly provides false information in any document filed or required to be maintained under KRS Chapter 224 shall be guilty of a Class D felony and upon conviction thereof, shall be punished by a fine not to exceed twenty-five thousand dollars (\$25,000), or by imprisonment, or by fine and imprisonment, for each separate violation. Each day upon which a violation occurs shall constitute a separate violation.

3.12. Reporting Requirements

3.12.1. Planned Changes

The permittee shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:

- (i) The alteration or addition to a permitted facility, may meet one of the criteria for determining whether a facility is a new source in KRS 224.16-050; or
- (ii) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under KRS 224.16-050; or
- (iii) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan.

3.12.2. Anticipated Noncompliance

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

3.12.3. Transfers

This permit is not transferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under KRS 224; see 401 KAR 5:070, Section 5; in some cases, modification or revocation and reissuance is mandatory.

3.12.4. Monitoring Reports

Monitoring results shall be reported at the intervals specified elsewhere in this permit.

- (i) Monitoring results must be reported on a DMR or forms provided or specified by the Director for reporting results of monitoring of sludge use or disposal practices.
- (ii) If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 401 KAR 5:065, Section 2(8), or another method required for an industry-specific waste stream under 401 KAR 5:065, Section 2(9) or (10), the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Director.
- (iii) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Director in the permit.

3.12.5. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit, shall be submitted no later than fourteen (14) days following each schedule date.

3.12.6. Twenty-four Hour Reporting

- (i) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within twenty-four (24) hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.
- (ii) The following shall be included as information which must be reported within twenty-four (24) hours under this paragraph:
 - (A) Any unanticipated bypass which exceeds any effluent limitation in the permit.
 - (B) Any upset which exceeds any effluent limitation in the permit.

(C) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in the permit to be reported within twenty-four (24) hours.

(iii) The Director may waive the written report on a case-by-case basis for reports under paragraph ii of this section if the oral report has been received within twenty-four (24) hours.

3.12.7. Other Noncompliance

The permittee shall report all instances of noncompliance not reported under Sections 3.12.1, 3.12.4, 3.12.5 and 3.12.6, at the time monitoring reports are submitted. The reports shall contain the information listed in Section 3.12.6.

3.12.8. Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to the Director, it shall promptly submit such facts or information.

3.13. Bypass

3.13.1. Definitions

(i) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.

(ii) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

3.13.2. Bypass Not Exceeding Limitations

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Section 3.13.1.

3.13.3. Notice

(i) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, and if possible at least ten days before the date of the bypass.

(ii) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in Section 3.12.6.

3.13.4. Prohibition of Bypass

(i) Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:

(A) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;

(B) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and

(C) The permittee submitted notices as required under Section 3.13.3.

(ii) The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the conditions listed above in Section 3.13.3.

3.14. Upset

3.14.1. Definition

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

3.14.2. Effect of an Upset

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations, if the requirements of Section 3.14.3 are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.

3.14.3. Conditions Necessary for a Demonstration of Upset

A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (i) An upset occurred and that the permittee can identify the cause(s) of the upset;
- (ii) The permitted facility was at the time being properly operated;
- (iii) The permittee submitted notice of the upset as required in Section 3.12.6; and
- (iv) The permittee complied with any remedial measures required under Section 3.4.

3.14.4. Burden of Proof

In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

SECTION 4

WET TESTING REQUIREMENTS

4. WET TESTING REQUIREMENTS

The permittee shall initiate, within thirty (30) days of the effective date of this permit, or continue the series of tests described below to evaluate wastewater toxicity of the discharge from Outfall 001.

4.1. Sampling Requirements

Tests shall be conducted on a minimum of three (3) 24-hour composite samples shall be collected at a frequency of one (1) 24-hour composite every other day. For example, the first sample would be used for test initiation on day 1 and for test solution renewal on day 2. The second sample would be used for test solution renewal on days 3 and 4. The third sample would be used for test solution renewal on days 5, 6, and 7. Each 24-hour composite shall be collected using a refrigerated automatic sampler. Each 24-hour composite sample shall consist of not less than forty-eight (48) discrete aliquots of effluent. Aliquots shall be of equal volume and time-proportional unless effluent flow is expected to vary by more than 10% from one hour to another or by 50% over the 24-hour collection period (as predicted from historical trends, significant rainfall events, etc.). With anticipated effluent flow variation of greater than 10% per hour or 50% overall, the frequency, and volume of each aliquot shall be flow-proportional. The lapsed time from collection of the last aliquot of the composite and its first use for test initiation or for test solution renewal shall not exceed 36 hours.

Samples shall be iced and maintained at not greater than 6 °C during collection, storage, transport and until used in the test by the laboratory.

4.2. Test Requirements

The Chronic WET test requirements consists of 1 short-term static-renewal water flea (Ceriodaphnia dubia) life-cycle test and 1 short-term static-renewal fathead minnow (Pimephales promelas) growth test on 100% effluent (1.00 TU_C) at the frequency specified. The test shall begin within 36 hours of the collection of the day 1 sample. The test shall be renewed daily using: samples collected on days 1, 3; and 5 in accordance with test method specified in the Test Methods Section below.

4.3. Serial Dilutions

Effluent concentrations for the tests must include the percent effluent required by the permit and at least four additional effluent concentrations as in the following table.

TABLE 4.					
Required Percent Effluent	Dilution 1 Percent	Dilution 2 Percent	Dilution 3 Percent	Dilution 4 Percent	Dilution 5 Percent
100	20	40	60	80	100

For a required percent effluent of 100%, test concentrations shall be 20%, 40%, 60%, 80% and 100%.

Selection of different effluent concentrations must be approved by DOW prior to testing. Controls shall be conducted concurrently with effluent testing using synthetic water.

4.4. Controls

Control tests shall be conducted concurrent with effluent testing using synthetic water. The analysis will be deemed reasonable and good only if the minimum control requirements are met.

Any test that does not meet the control acceptability criteria shall be repeated as soon as practicable within the monitoring period.

Within 30 days prior to initiating an effluent toxicity test, a reference toxicant test must be completed for the method used; alternatively, the reference toxicant test may be run concurrent with the effluent toxicity test.

For the Ceriodaphnia test: at least 80% survival of all control organisms and an average of fifteen (15) or more young per surviving female in the control solutions; and 60% of surviving control females must produce three broods.

For the fathead minnow test: at least 80% survival in controls and the average dry weight per surviving organism in control chambers equals or exceeds 0.25 mg.

4.5. Test Methods

All test organisms, procedures and quality assurance criteria used shall be in accordance with Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms (4th Edition), EPA-821-R-02-013, the most recent edition of this publication, or as approved in advance by DOW.

4.6. Reduction to Single Species Testing

After at least six (6) consecutive passing toxicity tests using both, the water flea and the fathead minnow, a request for testing with only the most sensitive species may be submitted to DOW. Upon approval, the most sensitive species may be considered as representative and all subsequent compliance tests may be conducted using only that species unless directed at any time by DOW to change or revert to both.

4.7. Reduction in Monitoring Frequency

The permittee may request a reduction in the frequency of WET testing from quarterly to annual upon demonstration that no test failures, incomplete tests, or invalid tests occurred during the following specified timeframes:

- 1) Existing facilities: four (4) consecutive quarters;
- 2) New or expanded facilities: eight (8) consecutive quarters.

New and expanded facilities are defined in the above Requirements Effective Dates Section of this permit. In the event of the failure of an annual test or non-submission by January 28th of the year following the completion of the test, the permittee will again be subject to quarterly WET testing.

4.8. Reporting Requirements

Results of all toxicity tests conducted with any species shall be reported according to the most recent format provided by DOW (See the Section for Submission of DMRs of this permit). Notification of failed test shall be made to DOW within five days of test completion. Test reports shall be submitted to DOW within thirty (30) days of completion. A control chart including the most recent reference toxicant test endpoints for the effluent test method (minimum of 5, up to 20 if available) shall be part of the report.

4.9. Test Results

If noncompliance occurs in an initial test, the permittee shall repeat the test using new samples. Results of this second round of testing will be used to evaluate the persistence of the toxic event and the possible need for a Toxicity Reduction Evaluation (TRE).

Noncompliance with the toxicity limit is demonstrated if the IC_{25} (inhibition concentration) for reproduction or growth is less than 100 % effluent. If noncompliance occurs in an initial test, the permittee must repeat the test using a new set of three (3) composite samples. Sampling must be initiated within fifteen (15) days of completing the failed test. The second round of testing shall include both species unless approved for only the most sensitive species by DOW.

4.10. Accelerated Testing

If the second round of testing also demonstrates noncompliance, the permittee will be required to perform accelerated testing as specified in the following paragraphs.

Complete four (4) additional rounds of testing to evaluate the frequency and degree of toxicity within sixty (60) days of completing the second failed round of testing. Results of the initial and second rounds of testing specified above plus the four (4) additional rounds of testing will be used in deciding if a TRE shall be required.

If results from any two (2) of six (6) rounds of testing show a significant noncompliance with the Toxicity limit, i.e., ≥ 1.2 times the TU, or results from any four of the six tests show toxicity as defined above, a TRE will be required.

The permittee shall provide written notification to DOW within five (5) days of completing the accelerated testing, stating that: (1) toxicity persisted and that a TRE will be initiated; or (2) that toxicity did not persist and normal testing will resume.

Should toxicity prove not to be persistent during the accelerated testing period, but reoccur within twelve (12) months of the initial failure at a level ≥ 1.2 times the TU, then a TRE shall be required.

4.11. WET TRE

Having determined that a TRE is required, the permittee shall initiate and/or continue at least monthly testing with both species until such time as a specific TRE plan is approved by DOW. A TRE plan shall be developed by the permittee and submitted to DOW within thirty (30) days of determining a TRE is required. The plan shall be developed in accordance with the most recent Environmental Protection Agency (EPA) and DOW guidance. Questions regarding this process may be submitted to DOW.

The TRE plan shall include Toxic Identification Evaluation (TIE) procedures, treatability studies, and evaluations of: chemical usage including changes in types, handling and suppliers; operational and process procedures; housekeeping and maintenance activities; and raw materials. The TRE plan will establish an implementation schedule to begin immediately upon approval by DOW, to have duration of at least six (6) months, and not to exceed twenty-four (24) months. The implementation schedule shall include quarterly progress reports being submitted to DOW, due the last day of the month following each calendar quarter.

Upon completion of the TRE, the permittee shall submit a final report detailing the findings of the TRE and actions taken or to be taken to prevent the reoccurrence of toxicity. This final report shall include: the

toxicant(s), if any are identified; treatment options; operational changes; and the proposed resolutions including an implementation schedule not to exceed one-hundred-eighty (180) days.

Should the permittee determine the toxicant(s) and/or a workable treatment prior to the planned conclusion of the TRE, the permittee will notify DOW within five (5) days of making that determination and take appropriate actions to implement the solution within one-hundred-eighty (180) days of that notification.

SECTION 5

OTHER CONDITIONS

5. OTHER CONDITIONS

5.1. Schedule of Compliance

The permittee shall attain compliance with all requirements of this permit on the effective date of this permit unless otherwise stated below:

All conditions of the Amended Consent Decree, in United States of America and The Commonwealth of Kentucky v. The Louisville and Jefferson County Metropolitan Sewer District, Civil Action No. 3:08-cv-00608-CRS, entered April 15, 2009, are hereby incorporated as enforceable conditions of this KPDES permit, including the submission of all required reports and plans by the dates specified by the Consent Decree.

5.2. Other Permits

This permit has been issued under the provisions of KRS Chapter 224 and regulations promulgated pursuant thereto. Issuance of this permit does not relieve the permittee from the responsibility of obtaining any other permits or licenses required by this Cabinet and other state, federal, and local agencies.

5.3. Continuation of Expiring Permit

This permit shall be continued in effect and enforceable after the expiration date of the permit provided the permittee submits a timely and complete application in accordance with 401 KAR 5:060, Section 2(4).

5.4. Antidegradation

For those discharges subject to the provisions of 401 KAR 10:030 Section 1(3)(b)5, the permittee shall install, operate, and maintain wastewater treatment facilities consistent with those identified in the approved regional facility plan.

5.5. Reopener Clause

This permit shall be modified, or alternatively revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved in accordance with 401 KAR 5:050 through 5:080, if the effluent standard or limitation so issued or approved:

- 1) Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
- 2) Controls any pollutant not limited in the permit.

The permit as modified or reissued under this paragraph shall also contain any other requirements of KRS Chapter 224 when applicable.

5.6. Sludge Disposal

The disposal or final use of sewage sludge generated during the treatment of domestic sewage by a POTW shall be disposed of in accordance with state and federal requirements [401 KAR Chapter 45 and 40 CFR 503].

5.7. Certified Operators

The wastewater treatment plant shall be under the primary responsibility of Class III Wastewater Treatment Plant Certified Operators or higher.

The collection system shall be under the primary responsibility of Class III Collection System Certified Operators or higher.

5.8. Outfall Signage

The KPDES permit establishes monitoring points, effluent limitations, and other conditions to address discharges from the permitted facility. In an effort to better document and clarify these locations the permittee should place and maintain a permanent marker at each of the monitoring locations.

SECTION 6

MONITORING AND REPORTING REQUIREMENTS

6. MONITORING AND REPORTING REQUIREMENTS

6.1. KPDES Outfalls

Discharge samples and measurements shall be collected at the compliance point for each KPDES Outfall identified in this permit. Each sample shall be representative of the volume and nature of the monitored discharge.

6.2. Monthly Operating Reports (MORs)

In addition to the monitoring of effluent as specified by the permit, the permittee shall conduct process control monitoring on a daily basis. Process control monitoring is that monitoring performed by the operators of the wastewater treatment plant to determine if the wastewater system is operating at its optimum efficiency. This monitoring includes but is not limited to influent and effluent quality and quantity monitoring, chemical usage, sludge monitoring including volume produced, wasted, and disposed, and monitoring of internal units such as aeration basins and oxidation ditches.

The data shall be recorded using the Microsoft EXCEL-based Monthly Operating Report (MOR) workbook available of the Department for Environmental Protection's Forms webpage at:

<http://dep.ky.gov/formslibrary/Pages/default.aspx>

The updated workbook shall be maintained on-site and made available upon request by Cabinet personnel.

6.3. Sufficiently Sensitive Analytical Methods

Analytical methods utilized to demonstrate compliance with the effluent limitations established in this permit shall be sufficiently sensitive to detect pollutant levels at or below the required effluent limit. It is the responsibility of the permittee to demonstrate compliance with permit parameter limitations by utilization of sufficiently sensitive analytical methods.

6.4. Certified Laboratory Requirements

All laboratory analyses and tests required to demonstrate compliance with the conditions of this permit shall be performed by EEC certified general wastewater laboratories.

6.5. Submission of DMRs

Monitoring results obtained during each monitoring period must be reported. The completed DMR for each monitoring period must be submitted no later than the 28th day of the month following the monitoring period for which monitoring results were obtained.

The completed DMR for each monitoring period must be entered into the DOW approved electronic system no later than midnight on the 28th day of the month following the monitoring period for which monitoring results were obtained.

For more information regarding electronic submittal of DMRs, please visit the Division's website at: <http://water.ky.gov/permitting/Pages/netDMRInformation.aspx> or contact the DMR Coordinator at (502) 564-3410.