



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

February 13, 2012

Cheryl Edwards
DMR Coordinator
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**RE: Hite Creek WQTC, KPDES No: KY0022420
Discharge Monitoring Report for January 2012.**

Dear Ms. Edwards:


Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Hite Creek WQTC, for the month of January 2012.

There were no exceedences or bypasses to report this month.

Also attached is an overflow report.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5856.

Sincerely,


Kevin Thompson
Process Supervisor, East Region

KT/Hite Creek. 01/12.

Enclosures

cc: C. Roth (DOW Louisville)
T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
DISCHARGE MONITORING REPORT (DMR)

NAME HITE CREEK WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
8405 CEDAR CREEK RD.
LOUISVILLE KY 40211
FACILITY HITE CREEK WQTC

KY0022420
PERMIT NUMBER


0012
DISCHARGE NUMBER

MAJOR (SUBR LV)
F - FINAL JEFFE
MUNICIPAL WASTEWATER
EFFLUENT
[] No Discharge

LOCATION LOUISVILLE KY 40241
ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	YEAR	MO	DAY	
12	01	01	TO	12	01	31

NOTE: Read instructions before completing this form

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE		
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS					
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****	***	10	*****	*****	(19) MG/L	0	1/1	GR		
00300 1 0 0	PERMIT MEASUREMENT	*****	*****	***	7	*****	*****	(19) INST MIN		THREE/WEEK	GRAB		
EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	7.0	*****	8.6	(12) SU	0	1/1	GR		
PH	PERMIT MEASUREMENT	*****	*****	***	6.0	*****	9.0	(12) MINIMUM MAXIMUM		THREE/WEEK	GRAB		
00400 1 0 0	SAMPLE MEASUREMENT	5114	6178	(26) LBS/DY	*****	181	203	(19) MG/L	0	3/7	CP		
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS		
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	129	166	(26) LBS/DY	*****	4	5	(19) MG/L	0	3/7	CP		
00530 G 0 0	PERMIT MEASUREMENT	1501	2252	(26) LBS/DY	*****	30	45	(19) MO AVG MX WK AV		THREE/WEEK	COMPOS		
RAW SEW/INFLUENT	SAMPLE MEASUREMENT	558	715	(26) LBS/DY	*****	19	22	(19) MG/L	0	3/7	CP		
SOLIDS, TOTAL SUSPENDED	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS		
00530 1 0 0	SAMPLE MEASUREMENT	56	117	(26) LBS/DY	*****	2	4	(19) MG/L	0	3/7	CP		
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	250	375	(26) LBS/DY	*****	5	7.5	(19) MO AVG MX WK AV		THREE/WEEK	COMPOS		
NITROGEN, AMMONIA TOTAL (AS N)	SAMPLE MEASUREMENT	12	15	****	*****	0.5	0.6	(19) MG/L	0	1/7	CP		
00610 G 0 0	PERMIT MEASUREMENT	*****	*****	****	*****	2.0	2.5	(19) MO AVG MX WK AV		THREE/WEEK	COMPOS		
RAW SEW/INFLUENT	SAMPLE MEASUREMENT	56	117	(26) LBS/DY	*****	2	4	(19) MG/L	0	3/7	CP		
NITROGEN, AMMONIA TOTAL (AS N)	PERMIT MEASUREMENT	250	375	(26) LBS/DY	*****	5	7.5	(19) MO AVG MX WK AV		THREE/WEEK	COMPOS		
00610 1 2 0	SAMPLE MEASUREMENT	12	15	****	*****	0.5	0.6	(19) MG/L	0	1/7	CP		
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	****	*****	2.0	2.5	(19) MO AVG MX WK AV		THREE/WEEK	COMPOS		
PHOSPHORUS, TOTAL (AS P)	SAMPLE MEASUREMENT	12	15	****	*****	0.5	0.6	(19) MG/L	0	1/7	CP		
00665 1 0 0	PERMIT MEASUREMENT	*****	*****	****	*****	2.0	2.5	(19) MO AVG MX WK AV		THREE/WEEK	COMPOS		
EFFLUENT GROSS VALUE	PERMIT MEASUREMENT	*****	*****	****	*****	2.0	2.5	(19) MO AVG MX WK AV		THREE/WEEK	COMPOS		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C 1001 AND 33 U.S.C 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)								TELEPHONE		DATE		
GREG HEITZMAN, PE INTERIM EXECUTIVE DIRECTOR	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT								502	540-6000	12	02	13
TYPED OR PRINTED									AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

NAME HITE CREEK WQTC MSD
ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD.
 LOUISVILLE KY 40211
FACILITY HITE CREEK WQTC

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0022420
 PERMIT NUMBER

001 2
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 MUNICIPAL WASTEWATER
 EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40241
ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
12	01	01		12	01	31

NOTE: Read instructions before completing this form

PARAMETER	MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	3.79	8.09	(03) MGD	*****	*****	*****	***	0	CN	CN	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT DAILY MX	(03) MGD	*****	*****	*****	***		CONTINUOUS	CONTIN	
COLIFORM, FECAL GENERAL 74055 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	16	36	(13) 100ML	0	3/7	GR	
	PERMIT MEASUREMENT	*****	*****	***	*****	200 30DA GEO	400 7 DA GEO	(13) 100ML		THREE/WEEK	GRAB	
BOD, CARBONACEOUS 05 DAY, 20C 80082 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	4004	4674	(26) LBS/DY	*****	140	160	(19) MG/L	0	3/7	CP	
	PERMIT MEASUREMENT	REPORT MO AVG	REPORT MX WK AV	(26) LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
BOD, CARBONACEOUS 05 DAY, 20C 80082 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	84	119	(26) LBS/DY	*****	3	4	(19) MG/L	0	3/7	CP	
	PERMIT MEASUREMENT	367 MO AVG	550 MX WK AV	(26) LBS/DY	*****	10 MO AVG	15 MX WK AV	(19) MG/L		THREE/WEEK	COMPOS	
BOD, CARB 5-DAY, 20 DEG C, PERCENT REMVL 80091 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	98	*****	*****	(23) CENT	0	1/31	CA	
	PERMIT MEASUREMENT	*****	*****	***	85 MO AVG	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENTREMOVAL	SAMPLE MEASUREMENT	*****	*****	***	98	*****	*****	(23) CENT	0	1/31	CA	
	PERMIT MEASUREMENT	*****	*****	***	85 MO MIN	*****	*****	(23) CENT		ONCE/MONTH	CALCTD	
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER GREG HEITZMAN, PE INTERIM EXECUTIVE DIRECTOR	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.							TELEPHONE		DATE		
TYPED OR PRINTED								502	540-6000	12	02	13
								AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

NAME HITE CREEK WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
8405 CEDAR CREEK RD.
LOUISVILLE KY 40211
 FACILITY HITE CREEK WQTC

KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM (KPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0022420
 PERMIT NUMBER

001 R
 DISCHARGE NUMBER

MAJOR (SUBR LV)
 F - FINAL JEFFE
 REASONABLE POTENTIAL EFFLUENT
 [] No Discharge

LOCATION LOUISVILLE KY 40241
 ATTN: DENNIS THOMASSON SR. METRO OPS

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
FROM 12	01	01		TO 12	01	31

NOTE: Read instructions before completing this form

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
CYANIDE, FREE (AMEN. TO CHLORINATION) 00722 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.01	0.01	(19) MG/L	0	1/31	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
HARDNESS, TOTAL (AS CaCO3) 00900 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	189	189	(19) MG/L	0	1/31	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
CHROMIUM, HEXAVALENT (AS CR) 01032 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.01	0.01	(19) MG/L	0	1/31	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
CADMIUM TOTAL RECOVERABLE 01113 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	***	*****	0.2	0.2	(19) MG/L	0	1/31	CP	
	PERMIT MEASUREMENT	*****	*****	***	*****	REPORT MO AVG	REPORT DAILY MX	(19) MG/L		ONCE/MONTH	COMPOS	
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
	SAMPLE MEASUREMENT											
	PERMIT MEASUREMENT											
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER GREG HEITZMAN, PE INTERIM EXECUTIVE DIRECTOR	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319. (Penalties under those statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)							TELEPHONE 502 540-6000		DATE 12 02 13		
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>Ken...</i>							AREA CODE	NUMBER	YEAR	MO	DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NAME OF TREATMENT PLANT HITE CREEK WTP COUNTY JEFFERSON MONTH OF: January 2012
 KPDES PERMIT NUMBER KY0022420 PLANT CAPACITY 4.4 MGD RECEIVING STREAM HITE CREEK

DATE	TOTAL FLOW (MILLION GALLONS)		RAW SEWAGE		pH	SETTLABLE SOLIDS (mg/L)			DISSOLVED OXYGEN (mg/L)			SUSPENDED SOLIDS (mg/L)			5 DAY CBOD (mg/L)			ACTIVATED SLUDGE			AERATION BASIN					SLUDGE HANDLING					FINAL						
	GRIT REMOVED (CUBIC FEET)	SCREENINGS (CUBIC FEET)	RAW	FINAL		RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	STREAM ABOVE	FINAL EFFLUENT	STREAM BELOW	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RAW	PRIMARY EFFLUENT	FINAL EFFLUENT	RETURN		MLVSS X 1000	MLSS X 1000	MLVSS X 1000	MLSS (mg/L) X 1000	MLVSS (mg/L) X 1000	SETTLED SLUDGE VOLUME	RAW		HAULED			NH3-N (mg/L)	FECAL COLIFORM (COLORES/100ML)	Phosphorus mg/L	Cadmium, Total Recoverable	Hardness as CaCO3	Chromium, Hexavalent	Cyanide, Free (Amenable)
					GAUDY X 1000													MLSS	60 MIN.							60 MIN.	CALLONS X 1000	# DRY SOLIDS	# VOLATILE SOLIDS	# DRY SOLIDS							
1	3,313			7.3	6.0			0.0	11.0								2.08	11.8	38.2	4.1	3,795	2.97	300														
2	3,313			7.0	10.0			0.0	12.0		192		4	149		2	2.03	8.29	52.6	7	4.13	3.17	400						81.9	0.9	17	0.503					
3	5,989	38	36	7.2	10.0			0.0	12.0		167		4	135		3	1.92	10.94	42.7	8.8	4.43	3,575	350					80.35	0.67	4							
4	3,134			7.1	12.0			0.0	11.0		187		3	121		2	2.02	10	39.4	4.6	3.85	3,145	340					73.7	0.5	90							
5	2,839			7.3	12.0			0.0	11.0								1.8	10.2	39.4	4.4	3,655	3	340				44.25										
6	2,815	36	36	7.4	10.0			0.0	11.0								2.52	19	32.9	4.3	3,995	3,095	350				68.2										
7	2,828			7.4	11.0			0.0	11.0								2.26	5.99	75.6	4.3	4.34	3.52	370				31.5										
8	2,551			7.4	10.0			0.0	11.0		204		3	161		2	1.86	10.83	42.7	4.3	4,225	3.48	350				49.8	0.34	4	0.581							
9	2,721			7.3	12.0			0.0	11.0		182		3	161		2	1.79	10.5	52.6	5.3	4,235	3.28	380				58.2	1.1	550		0.2	189	0.01				
10	2,625	38	38	7.0	11.0			0.0	11.0		223		3	158		2	2.21	10.92	59.2	6.5	4,415	3,385	350			1.38	78	73.2	2.2	4					0.011		
11	3,857			7.2	12.0			0.0	9.8								2.19	11.88	59.2	6.1	4.16	3,195	350				61.4										
12	4,488			8.8	10.0			0.0	10.0								2.16	11.9	65.7	5.1	4.04	3,105	330				82.8										
13	3,737	36	36	8.4	13.0			0.0	12.0								2.28	11.16	78.8	6.9	4.04	3,115	350				75.8										
14	3,218			7.2	13.0			0.0	11.0								1.79	12	78.8	4.8	3,895	3,005	340				72.85										
15	2,741			7.1	13.0			0.0	11.0								2.28	10.52	78.8	6	3,555	2,885	300				75.8										
16	2,783	38	38	7.4	14.0			0.0	12.0		210		4	126		2	2.34	9.98	92	7.6	4.58	3.58	400				74	0.78	1400	0.372							
17	3,797			7.4	14.0			0.0	11.0		165		7	120		3	2.23	6.81	108.4	6.5	3.61	2.18	250				94.5	2	8								
18	3,895			7.2	12.0			0.0	9.7		134		5	126		4	1.8	10.58	78.8	6.9	3.52	2.78	280				92.9	2.9	4								
19	3,691			7.2	13.0			0.0	11.0								2	10.6	52.8	6.3	3.18	2,505	240			1.08	78	91									
20	3,052	38	38	7.5	13.0			0.0	11.0								2.1	9.7	52.6	5.4	3,415	2,705	280				90.7										
21	2,989			7.4	12.0			0.0	11.0								2.07	8.21	65.7	7.2	3.79	2.98	340				63										
22	2,977			7.3	16.0			0.0	11.0		258		6	170		3	1.98	8.41	72.28	5.8	4.2	2.29	380				59	4.48	4	0.8							
23	4,555			7.8	12.0			0.0	9.9		108		4	111		4	2.08	11.64	32.9	4.4	3,355	2.68	280				74	4.2	10								
24	3,936	38	38	7.5	12.0			0.0	12.0		147		6	136		4	2.41	11.34	29.6	2.9	3.27	2.58	250				74	2.4	4								
25	3,919			7.8	10.0			0.0	11.0								2.6	10.88	36.2	3.9	3.94	3.03	300														
26	6,085			7.4	10.0			0.0	10.0								2.72	11.48	29.6	2.4	3.38	2.59	250														
27	8,093	38	38	7.5	10.0			0.0	11.0								2.82	13.62	19.7	6.7	2.7	2.1	200				30.7										
28	5,345			7.5	10.0			0.0	11.0								2.47	12.95	27	5.8	3.52	2.86	230				28.75										
29	4,389			7.8	10.0			0.0	11.0								2.2	12.89	28	4.5	3,505	2,725	260				25										
30	4,158			7.5	12.0			0.0	11.0								2.48	12.5	32.9	5.7	4.69	3.57	400				49.8										
31	4,094	36	36	7.3	12.0			0.0	12.0																												
Tot.	117.5	324	324						11.0		181		4	140		3	2,175	10.98	52.55	5,413	3,917	3,016	327.1				1828										
Avg.	3.79	38	38	7.4	11.5				11.0		181		4	140		3	2,175	10.98	52.55	5,413	3,917	3,016	327.1			1.24	78.67	82.98	1.87	18	0.51	0.20	189.00	0.01	0.01		

RESIDENTIAL	INDUSTRIAL WASTE POPULATION EQUIVALENT		Earl Dunn		7628	
COMMERCIAL	38087	25939	27283	OPERATOR	CERT. NO.	
INDUSTRIAL	0	0	0	502-241-9310		
TOTAL NUMBER OF SEWER CONNECTIONS	0			PLANT TELEPHONE		
SEWER CONNECTIONS	0	X 4	= 0			
SEWERED POPULATION						



Report Selections: Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022420	Facility ID MSD0202	Water Quality Treatment Center HITE CREEK	Receiving Stream of Treatment Center HITE CREEK	Region EAST
----------------------	------------------------	--	--	----------------

Facility Type SLS Sewer Lift Station	Facility ID MSD1082-PS	Facility Address 7511 MEADOWSTREAM CT	If Pump Station, Name of Pump Station: MEADOWSTREAM	Receiving Stream FLOYDS FORK	Discharge to GROUND
---	---------------------------	--	--	---------------------------------	------------------------

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1415915	01/27/12 04:00 AM	GREEN	OPS ASHIFT	DOCUMENTED	01/03/05	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE-WATER S	01/29/12 03:30 PM	

Spot Inspections:

Discharge Amount:	159,750 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TAPE & TEMPORARY SIGNS PLACED
Impact:	SEWAGE, DEBRIS & SOLIDS OBSERVED
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR

Notifications:

01/27/12 04:00 AM	DISPUB	MSD WARNED PUBLIC WITH TEMPORARY SIGNS & ADVISED PROPERTY OWNER TO AVOID CONTACT WITH SEWAGE
01/27/12 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
01/27/12 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov