



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

February 19, 2014

Cheryl Edward
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**RE: Hite Creek WQTC, KPDES No: KY0022420
Discharge Monitoring Report for January 2014.**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Hite Creek WQTC, for the month of January 2014.

There were no exceedences, bypasses or overflow's to report this month.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5856.

Sincerely,

A handwritten signature in black ink, appearing to read "Kevin Thompson", written over a horizontal dotted line.

Kevin Thompson
Process Supervisor, East Region

KT/ Hite Creek. 01/14.

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit			
Permit #:	KY0022420	Permittee:	HITE CREEK WQTC MSD
Major:	Yes	Permittee Address:	5512 HITT LN LOUISVILLE, KY 40201
Permitted Feature:	001 External Outfall	Discharge:	001-2 MUNICIPAL WASTEWATER
Facility:		Facility Location:	HITE CREEK WQTC MSD 5512 HITT LN LOUISVILLE, KY 40201

Report Dates & Status			
Monitoring Period:	From 01/01/14 to 01/31/14	DMR Due Date:	02/28/14
Status:	NetDMR Validated		

Considerations for Form Completion
USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

Principal Executive Officer			
First Name:	Greg	Title:	Executive Director
Last Name:	Heitzman	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7				=	7				19 - mg/L	01/01 - Daily	GR - GRAB	
					Permit Req.	>=	7 INST MIN								19 - mg/L	03/07 - Three Per Week	GR - GRAB		
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.3				=	8			12 - SU	01/01 - Daily	GR - GRAB		
					Permit Req.	>=	6 MINIMUM								12 - SU	03/07 - Three Per Week	GR - GRAB		
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	120	=	189	26 - lb/d	=	3	=	4	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.	<=	1501 MO AVG	<=	2252 MX WK AV	26 - lb/d	<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample	=	7333	=	9156	26 - lb/d	=	199	=	214	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d		Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample	=	11	=	20	26 - lb/d	=	0.3	=	0.5	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.	<=	250 MO AVG	<=	375 MX WK AV	26 - lb/d	<=	5 MO AVG	<=	7.5 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
00610	Nitrogen, ammonia total [as N]	G - Raw Sewage Influent	0	--	Sample	=	632	=	676	26 - lb/d	=	17	=	19	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d		Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	2	--	Sample	=		=			=	0.4	=	0.9	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.					<=	2 MO AVG	<=	3 MX WK AV	19 - mg/L	01/07 - Weekly	CP - COMPOS			
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	4.482	=	7.501	03 - MGD							99/99 - Continuous	CN - CONTIN	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD								99/99 - Continuous	CN - CONTIN
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample	=		=			=	2	=	2	13 - #/100mL	03/07 - Three Per Week	GR - GRAB		
					Permit Req.					<=	200 30DA GEO	<=	400 7 DA GEO	13 - #/100mL	03/07 - Three Per Week	GR - GRAB			
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	85	=	118	26 - lb/d	=	2	=	3	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.	<=	500 MO AVG	<=	751 MX WK AV	26 - lb/d	<=	10 MO AVG	<=	15 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	G - Raw Sewage Influent	0	--	Sample	=	4778	=	4887	26 - lb/d	=	132	=	153	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d		Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample	=	98								23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.	>=	85 MO AV MN								23 - %	01/30 - Monthly	CA - CALCTD		
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample	=	98								23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.	>=	85 MO MIN								23 - %	01/30 - Monthly	CA - CALCTD		
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments		
Name	Type	Size
201401_HiteCreek_coverletter.pdf	pdf	16446
201401_HiteCreek_MOR.pdf	pdf	41403

Report Last Saved By
HITE CREEK WQTC MSD

User:	kevin.thompson@louisvillemsd.org	Date/Time:	2014-02-24 08:26 (Time Zone: -05:00)
Name:	Kevin Thompson		
E-Mail:	kevin.thompson@louisvillemsd.org		

DMR Copy of Record

Permit																		
Permit #:	KY0022420				Permittee:	HITE CREEK WQTC MSD				Facility:	HITE CREEK WQTC MSD							
Major:	Yes				Permittee Address:	5512 HITT LN LOUISVILLE, KY 40201				Facility Location:	5512 HITT LN LOUISVILLE, KY 40201							
Permitted Feature:	001 External Outfall				Discharge:	001-R REASONABLE POTENTIAL												
Report Dates & Status																		
Monitoring Period:	From 01/01/14 to 01/31/14				DMR Due Date:	02/28/14				Status:	NetDMR Validated							
Considerations for Form Completion																		
Principal Executive Officer																		
First Name:	Greg				Title:	Executive Director				Telephone:	502-540-6000							
Last Name:	Heitzman																	
No Data Indicator (NODI)																		
Form NODI:	--																	
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type	
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units		
00722	Cyanide, free [amen. to chlorination]	1 - Effluent Gross	0	--	Sample					<	0.005			<	0.005	19 - mg/L	01/30 - Monthly	CP - COMPOS
					Permit Req.											19 - mg/L	01/30 - Monthly	CP - COMPOS
					Value NODI													
00900	Hardness, total [as CaCO3]	1 - Effluent Gross	0	--	Sample					=	162			=	162	19 - mg/L	01/30 - Monthly	CP - COMPOS
					Permit Req.											19 - mg/L	01/30 - Monthly	CP - COMPOS
					Value NODI													
01032	Chromium, hexavalent [as Cr]	1 - Effluent Gross	0	--	Sample					<	0.01			<	0.01	19 - mg/L	01/30 - Monthly	CP - COMPOS
					Permit Req.											19 - mg/L	01/30 - Monthly	CP - COMPOS
					Value NODI													
01113	Cadmium, total recoverable	1 - Effluent Gross	0	--	Sample					=	0.00104			=	0.00104	19 - mg/L	01/30 - Monthly	CP - COMPOS
					Permit Req.											19 - mg/L	01/30 - Monthly	CP - COMPOS
					Value NODI													
Submission Note																		
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																		
Edit Check Errors																		
No errors.																		
Comments																		
Attachments																		
No attachments.																		
Report Last Saved By																		
HITE CREEK WQTC MSD																		
User:	kevin.thompson@louisvillemsd.org								Date/Time:	2014-02-24 08:27 (Time Zone: -05:00)								
Name:	Kevin Thompson																	
E-Mail:	kevin.thompson@louisvillemsd.org																	

