



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

June 2, 2015

Cheryl Edward
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**RE: Hite Creek WQTC, KPDES No: KY0022420
Discharge Monitoring Report for May 2015.**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Hite Creek WQTC, for the month of May 2015.

There were no exceedances, bypasses or discharges to report this month.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5856.

Sincerely,

A handwritten signature in cursive script that reads "Duane V. Wright".

Duane V. Wright
Process Supervisor, East Region

DVW/ Hite Creek. 05/15.

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit			
Permit #:	KY0022420	Permittee:	HITE CREEK WQTC MSD
Major:	Yes	Permittee Address:	5512 HITT LN LOUISVILLE, KY 40201
Permitted Feature:	001 External Outfall	Discharge:	001-2 MUNICIPAL WASTEWATER
Facility:		Facility Location:	HITE CREEK WQTC MSD 5512 HITT LN LOUISVILLE, KY 40201

Report Dates & Status			
Monitoring Period:	From 05/01/15 to 05/31/15	DMR Due Date:	06/28/15
Status:	NetDMR Validated		

Considerations for Form Completion
USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

Principal Executive Officer			
First Name:	Greg	Title:	Exec. Dir.
Last Name:	Heitzman	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	8									19 - mg/L	01/01 - Daily	GR - GRAB	
					Permit Req.	>=	7 INST MIN									19 - mg/L	03/07 - Three Per Week	GR - GRAB	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7					=	8		12 - SU	01/01 - Daily	GR - GRAB		
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM			12 - SU	03/07 - Three Per Week	GR - GRAB		
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	141	=	238	26 - lb/d		=	5	=	7	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.	<=	1501 MO AVG	<=	2252 MX WK AV	26 - lb/d		<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample	=	7594	=	8082	26 - lb/d		=	244	=	267	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d			Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	9	=	12	26 - lb/d		=	0.3	=	0.4	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.	<=	100 MO AVG	<=	150 MX WK AV	26 - lb/d		<=	2 MO AVG	<=	3 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total [as N]	G - Raw Sewage Influent	0	--	Sample	=	708	=	750	26 - lb/d		=	23	=	23	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d			Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample	=		=				=	0.5	=	0.9	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.						<=	1 MO AVG	<=	1.5 MX WK AV	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	3.663	=	4.022	03 - MGD							99/99 - Continuous	CN - CONTIN	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	CN - CONTIN
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample							=	9	=	50	13 - #/100mL	03/07 - Three Per Week	GR - GRAB	
					Permit Req.							<=	200 30DA GEO	<=	400 7 DA GEO	13 - #/100mL	03/07 - Three Per Week	GR - GRAB	
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	130	=	184	26 - lb/d		=	4	=	6	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.	<=	500 MO AVG	<=	751 MX WK AV	26 - lb/d		<=	10 MO AVG	<=	15 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
80082	BOD, carbonaceous, 05 day, 20 C	G - Raw Sewage Influent	0	--	Sample	=	6295	=	7306	26 - lb/d		=	202	=	236	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d			Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample							=	98			23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.							>=	85 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD	
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample							=	98			23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.							>=	85 MO MIN			23 - %	01/30 - Monthly	CA - CALCTD	
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
HC052015_COVER.pdf	pdf	45793
HC052015_MOR.pdf	pdf	63558

Report Last Saved By

HITE CREEK WQTC MSD

User: kevin.ries@louisvillemsd.org	Date/Time: 2015-06-24 08:31 (Time Zone: -04:00)
Name: Kevin Ries	
E-Mail: kevin.ries@louisvillemsd.org	

DMR Copy of Record

Permit																			
Permit #:	KY0022420				Permittee:	HITE CREEK WQTC MSD				Facility:	HITE CREEK WQTC MSD								
Major:	Yes				Permittee Address:	5512 HITT LN LOUISVILLE, KY 40201				Facility Location:	5512 HITT LN LOUISVILLE, KY 40201								
Permitted Feature:	001 External Outfall				Discharge:	001-R REASONABLE POTENTIAL													
Report Dates & Status																			
Monitoring Period:	From 05/01/15 to 05/31/15				DMR Due Date:	06/28/15				Status:	NetDMR Validated								
Considerations for Form Completion																			
Principal Executive Officer																			
First Name:	Greg				Title:	Exec. Dir				Telephone:	502-540-6000								
Last Name:	Heitzman																		
No Data Indicator (NODI)																			
Form NODI:	--																		
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00722	Cyanide, free [amen. to chlorination]	1 - Effluent Gross	0	--	Sample					<	0.005			<	0.005	19 - mg/L	03/30 - Three Per Month	CP - COMPOS	
					Permit Req.												01/30 - Monthly	CP - COMPOS	
					Value NODI														
00900	Hardness, total [as CaCO3]	1 - Effluent Gross	0	--	Sample					=	177			=	182	19 - mg/L	02/30 - Twice Per Month	CP - COMPOS	
					Permit Req.												01/30 - Monthly	CP - COMPOS	
					Value NODI														
01032	Chromium, hexavalent [as Cr]	1 - Effluent Gross	0	--	Sample					<	0.004			<	0.004	19 - mg/L	02/30 - Twice Per Month	CP - COMPOS	
					Permit Req.												01/30 - Monthly	CP - COMPOS	
					Value NODI														
01113	Cadmium, total recoverable	1 - Effluent Gross	0	--	Sample					<	0.000201			<	0.000201	19 - mg/L	01/30 - Monthly	CP - COMPOS	
					Permit Req.												01/30 - Monthly	CP - COMPOS	
					Value NODI														
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Attachments																			
Name										Type				Size					
HC052015_COVER.pdf										pdf				45793					
Report Last Saved By																			
HITE CREEK WQTC MSD																			
User:	wrightd				Date/Time:	2015-06-24 08:29 (Time Zone: -04:00)													
Name:	Duane Wright																		
E-Mail:	duane.wright@louisvillemsd.org																		

