



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

July 22, 2015

Cheryl Edward
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**RE: Hite Creek WQTC, KPDES No: KY0022420
Discharge Monitoring Report for June 2015.**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Hite Creek WQTC, for the month of June 2015.

Also attached is a discharge report and the 2nd quarter biomonitoring DMR

There were no exceedances or bypasses to report this month.

As of July 13, 2015, MSD staff moved the influent sampler to collect samples before the bar screens due to flooding conditions at the previous location.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5856.

Sincerely,

Duane V. Wright
Process Supervisor, East Region

DVW/ Hite Creek. 06/15.

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit			
Permit #:	KY0022420	Permittee:	HITE CREEK WQTC MSD
Major:	Yes	Permittee Address:	5512 HITT LN LOUISVILLE, KY 40201
Facility:		Facility Location:	HITE CREEK WQTC MSD 5512 HITT LN LOUISVILLE, KY 40201
Permitted Feature:	001 External Outfall	Discharge:	001-2 MUNICIPAL WASTEWATER

Report Dates & Status			
Monitoring Period:	From 06/01/15 to 06/30/15	DMR Due Date:	07/28/15
Status:	NetDMR Validated		

Considerations for Form Completion
USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

Principal Executive Officer			
First Name:	Greg	Title:	Exec. Dir.
Last Name:	Heitzman	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	8									19 - mg/L	01/01 - Daily	GR - GRAB	
					Permit Req.	>=	7 INST MIN									19 - mg/L	03/07 - Three Per Week	GR - GRAB	
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7					=	8		12 - SU	01/01 - Daily	GR - GRAB		
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM			12 - SU	03/07 - Three Per Week	GR - GRAB		
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	114	=	139	26 - lb/d		=	4	=	4	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.	<=	1501 MO AVG	<=	2252 MX WK AV	26 - lb/d		<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample	=	7557	=	8825	26 - lb/d		=	238	=	277	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d			Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	7	=	8	26 - lb/d		=	0.2	=	0.3	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.	<=	100 MO AVG	<=	150 MX WK AV	26 - lb/d		<=	2 MO AVG	<=	3 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
00610	Nitrogen, ammonia total [as N]	G - Raw Sewage Influent	0	--	Sample	=	715	=	735	26 - lb/d		=	23	=	25	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d			Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample	=						=	0.2	=	0.4	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Permit Req.							<=	1 MO AVG	<=	1.5 MX WK AV	19 - mg/L	01/07 - Weekly	CP - COMPOS	
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	4.223	=	7.393	03 - MGD							99/99 - Continuous	CN - CONTIN	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	CN - CONTIN
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample							=	3	=	4	13 - #/100mL	03/07 - Three Per Week	GR - GRAB	
					Permit Req.							<=	200 30DA GEO	<=	400 7 DA GEO	13 - #/100mL	03/07 - Three Per Week	GR - GRAB	
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	94	=	102	26 - lb/d		=	3	=	3	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.	<=	500 MO AVG	<=	751 MX WK AV	26 - lb/d		<=	10 MO AVG	<=	15 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample	=	6502	=	6916	26 - lb/d		=	206	=	225	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d			Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample							=	99			23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.							>=	85 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD	
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample							=	98			23 - %	01/30 - Monthly	CA - CALCTD	
					Permit Req.							>=	85 MO MIN			23 - %	01/30 - Monthly	CA - CALCTD	
					Value NODI														

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments

Name	Type	Size
HC062015_COVER.pdf	pdf	48121
HC062015_MOR.pdf	pdf	62240
2015_6_HiteCreek_OverflowReport.pdf	pdf	69272

Report Last Saved By

HITE CREEK WQTC MSD

User: kevin.ries@louisvillemsd.org	Date/Time: 2015-07-24 10:54 (Time Zone: -04:00)
Name: Kevin Ries	
E-Mail: kevin.ries@louisvillemsd.org	

DMR Copy of Record

Permit																			
Permit #:	KY0022420				Permittee:	HITE CREEK WQTC MSD				Facility:	HITE CREEK WQTC MSD								
Major:	Yes				Permittee Address:	5512 HITT LN LOUISVILLE, KY 40201				Facility Location:	5512 HITT LN LOUISVILLE, KY 40201								
Permitted Feature:	001 External Outfall				Discharge:	001-R REASONABLE POTENTIAL													
Report Dates & Status																			
Monitoring Period:	From 06/01/15 to 06/30/15				DMR Due Date:	07/28/15				Status:	NetDMR Validated								
Considerations for Form Completion																			
Principal Executive Officer																			
First Name:	Greg				Title:	Exec. Dir.				Telephone:	502-540-6000								
Last Name:	Heitzman																		
No Data Indicator (NODI)																			
Form NODI:	--																		
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00722	Cyanide, free [amen. to chlorination]	1 - Effluent Gross	0	--	Sample					<	0.005			<	0.005	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.													01/30 - Monthly	CP - COMPOS
					Value NODI														
00900	Hardness, total [as CaCO3]	1 - Effluent Gross	0	--	Sample					=	182			=	182	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.													01/30 - Monthly	CP - COMPOS
					Value NODI														
01032	Chromium, hexavalent [as Cr]	1 - Effluent Gross	0	--	Sample					<	0.004			<	0.004	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.													01/30 - Monthly	CP - COMPOS
					Value NODI														
01113	Cadmium, total recoverable	1 - Effluent Gross	0	--	Sample					<	0.000201			<	0.000201	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.													01/30 - Monthly	CP - COMPOS
					Value NODI														
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Attachments																			
Name										Type				Size					
HC062015_COVER.pdf										pdf				48121					
Report Last Saved By																			
HITE CREEK WQTC MSD																			
User:	kevin.ries@louisvillemtd.org				Date/Time:	2015-07-24 10:52 (Time Zone: -04:00)													
Name:	Kevin Ries																		
E-Mail:	kevin.ries@louisvillemtd.org																		

Report Selections: Period: 06/01/2015 00:00 thru 06/30/2015 23:59, treatment Plant: MSD0202 HITE CREEK, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD1085-PS	7520 KAVANAUGH RD	KAVANAUGH ROAD	HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2376587		06/26/2015	GREEN	OPS BSHIFT CENTRAL	DOCUMENTED	05/11/2003	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	06/27/15 02:30 AM	

Discharge Reporting:

Discharge Amount:	3,800 GAL
Cause:	POWER OUTAGE DUE TO RAIN EVENT
Clean Up:	NO DEBRIS
Control Zone:	TEMPORARY SIGNS PLACED
Impact:	SEWAGE OBSERVED
Repair:	GENERATOR PLACED UNTIL POWER RESTORED #2378792
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

Notifications:

6/26/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
6/26/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 1

Total Work Orders Printed: 1