



700 West Liberty Street | Louisville, KY 40203-1911  
Phone: 502.540.6000 | LouisvilleMSD.org

July 11, 2017

Cheryl Edwards  
300 Sower Blvd., 3rd Floor  
Frankfort, Kentucky 40601

**RE: Hite Creek WQTC, KPDES No: KY0022420  
Discharge Monitoring Report for June 2017.**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Hite Creek WQTC, for the month of June 2017.

Biomonitoring report for 2<sup>nd</sup> qtr attached.

There were no exceedances, overflows or bypasses.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Staci Huber  
Process Supervisor

SH/ Hite Creek. 06/17.

Cc: V. Teague  
R. Shaw

**DMR Copy of Record**

<b>Permit</b>			
<b>Permit #:</b>	<b>KY0022420</b>	<b>Permittee:</b>	Hite Creek WQTC MSD
<b>Major:</b>	Yes	<b>Permittee Address:</b>	700 W Liberty St Louisville, KY 40203
<b>Permitted Feature:</b>	001 External Outfall	<b>Discharge:</b>	<b>001-2</b> MUNICIPAL WASTEWATER
<b>Facility:</b>		<b>Facility Location:</b>	HITE CREEK WQTC MSD 5512 HITT LN LOUISVILLE, KY 40285

<b>Report Dates &amp; Status</b>			
<b>Monitoring Period:</b>	<b>From 06/01/17 to 06/30/17</b>	<b>DMR Due Date:</b>	<b>07/28/17</b>
<b>Status:</b>	<b>NetDMR Validated</b>		

**Considerations for Form Completion**  
USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

<b>Principal Executive Officer</b>			
<b>First Name:</b>	James A	<b>Title:</b>	Executive Director
<b>Last Name:</b>	Parrott	<b>Telephone:</b>	502-540-6000

**No Data Indicator (NODI)**  
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7				=	7				19 - mg/L	17/30 - 17 Per Month	GR - GRAB	
					Permit Req.	>=	7 INST MIN								19 - mg/L	03/07 - Three Per Week	GR - GRAB		
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample	=	7.3				=	7.8			12 - SU	17/30 - 17 Per Month	GR - GRAB		
					Permit Req.	>=	6 MINIMUM				<=	9 MAXIMUM			12 - SU	03/07 - Three Per Week	GR - GRAB		
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	229	=	306	26 - lb/d	=	6	=	8	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.	<=	1501 MO AVG	<=	2252 MX WK AV	26 - lb/d	<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample	=	7211	=	8377	26 - lb/d	=	210	=	263	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d		Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	24	=	50	26 - lb/d	=	0.7	=	1	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.	<=	100 MO AVG	<=	150 MX WK AV	26 - lb/d	<=	2 MO AVG	<=	3 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
00610	Nitrogen, ammonia total [as N]	G - Raw Sewage Influent	0	--	Sample	=	820	=	839	26 - lb/d	=	23	=	25	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d		Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample	=		=			=	0.6	=	0.9	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.					<=	1 MO AVG	<=	1.5 MX WK AV	19 - mg/L	01/07 - Weekly	CP - COMPOS			
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	4.412	=	6.406	03 - MGD							99/99 - Continuous	CN - CONTIN	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							0	99/99 - Continuous	CN - CONTIN
					Value NODI														
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample						=	13	=	23	13 - #/100mL	03/07 - Three Per Week	GR - GRAB		
					Permit Req.					<=	200 30DA GEO	<=	400 7 DA GEO	13 - #/100mL	03/07 - Three Per Week	GR - GRAB			
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	284	=	377	26 - lb/d	=	8	=	11	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.	<=	500 MO AVG	<=	751 MX WK AV	26 - lb/d	<=	10 MO AVG	<=	15 MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample	=	7121	=	8069	26 - lb/d	=	203	=	221	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d		Req Mon MO AVG		Req Mon MX WK AV	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Value NODI														
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample						=	96			23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.					>=	85 MO AV MN			23 - %	01/30 - Monthly	CA - CALCTD			
					Value NODI														
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample						=	97			23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.					>=	85 MO MIN			23 - %	01/30 - Monthly	CA - CALCTD			
					Value NODI														

**Submission Note**  
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
No errors.

**Comments**

**Attachments**

Name	Type	Size
062017_HC_Coverletter.pdf	pdf	92784
062017_HC_MOR.pdf	pdf	93024

**Report Last Saved By**

**Hite Creek WQTC MSD**

User:	WRIGHTDUANE	Date/Time:	2017-07-25 10:10 (Time Zone: -04:00)
Name:	Duane Wright		
E-Mail:	duane.wright@louisvillemsd.org		

## DMR Copy of Record

Permit																			
Permit #:	KY0022420				Permittee:	Hite Creek WQTC MSD				Facility:	HITE CREEK WQTC MSD								
Major:	Yes				Permittee Address:	700 W Liberty St Louisville, KY 40203				Facility Location:	5512 HITT LN LOUISVILLE, KY 40285								
Permitted Feature:	001 External Outfall				Discharge:	001-R REASONABLE POTENTIAL													
Report Dates & Status																			
Monitoring Period:	From 06/01/17 to 06/30/17				DMR Due Date:	07/28/17				Status:	NetDMR Validated								
Considerations for Form Completion																			
Principal Executive Officer																			
First Name:	James A				Title:	Executive Director				Telephone:	502-540-6000								
Last Name:	Parrott																		
No Data Indicator (NODI)																			
Form NODI:	--																		
Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00722	Cyanide, free [amen. to chlorination]	1 - Effluent Gross	0	--	Sample					<	0.005			<	0.005	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.													01/30 - Monthly	CP - COMPOS
					Value NODI														
00900	Hardness, total [as CaCO3]	1 - Effluent Gross	0	--	Sample					=	189			=	189	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.													01/30 - Monthly	CP - COMPOS
					Value NODI														
01032	Chromium, hexavalent [as Cr]	1 - Effluent Gross	0	--	Sample					<	0.005			<	0.005	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.													01/30 - Monthly	CP - COMPOS
					Value NODI														
01113	Cadmium, total recoverable	1 - Effluent Gross	0	--	Sample					=	0.25			=	0.25	19 - mg/L		01/30 - Monthly	CP - COMPOS
					Permit Req.													01/30 - Monthly	CP - COMPOS
					Value NODI														
Submission Note																			
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.																			
Edit Check Errors																			
No errors.																			
Comments																			
Attachments																			
Name										Type				Size					
062017_HC_Coverletter.pdf										pdf				111906					
Report Last Saved By																			
Hite Creek WQTC MSD																			
User:	WRIGHTDUANE				Date/Time:	2017-07-25 10:11 (Time Zone: -04:00)													
Name:	Duane Wright																		
E-Mail:	duane.wright@louisvillemtd.org																		



