



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.587.0603 | Fax: 502.540.6106 | louisvillemsd.org

August 13, 2019

Crystal Dennis
300 Sower Blvd., 3rd Floor
Frankfort, Kentucky 40601

**RE: Hite Creek WQTC, KPDES No: KY0022420
Discharge Monitoring Report for July 2019.**

Dear Ms. Dennis:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operator Report (MOR) for the Hite Creek WQTC, for the month of July 2019.

There were no bypasses, overflows or exceedances.

If you have any questions concerning the attached DMR's, please contact me at (502)587-5858.

Sincerely,

Staci Huber
Process Supervisor

SH/ Hite Creek. 07/19.

Cc: V. Teague
R. Shaw

DMR Copy of Record

Permit			
Permit #:	KY0022420	Permittee:	Hite Creek WQTC MSD
Major:	Yes	Permittee Address:	700 W Liberty St Louisville, KY 40203
Permitted Feature:	001 External Outfall	Discharge:	001-1A SANITARY WASTEWATER
Facility:		Facility Location:	HITE CREEK WQTC MSD 5512 HITT LN LOUISVILLE, KY 40285

Report Dates & Status			
Monitoring Period:	From 07/01/19 to 07/31/19	DMR Due Date:	08/28/19
Status:	NetDMR Validated		

Considerations for Form Completion
Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

Principal Executive Officer			
First Name:	James A	Title:	Executive Director
Last Name:	Parrott	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	8					19 - mg/L	03/07 - Three Per Week	GR - GRAB		
					Permit Req.					>=	7 INST MIN					19 - mg/L	03/07 - Three Per Week	GR - GRAB		
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	7			=	7.3	12 - SU	03/07 - Three Per Week	GR - GRAB		
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	03/07 - Three Per Week	GR - GRAB		
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	142	=	187	26 - lb/d			=	5	=	7	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.	<=	1502 MO AVG	<=	2253 MX WK AV	26 - lb/d			<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L	03/07 - Three Per Week	24 - COMP24	
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample							=	315	=	433	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.															
					Value NODI															
00600	Nitrogen, total [as N]	1 - Effluent Gross	0	--	Sample							=	15	=	21	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.															
					Value NODI															
00600	Nitrogen, total [as N]	G - Raw Sewage Influent	0	--	Sample							=	39	=	43	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.															
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample							=	0.3	=	0.4	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.															
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	1	--	Sample							=	0.6	=	1.3	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.															
					Value NODI															
00665	Phosphorus, total [as P]	G - Raw Sewage Influent	1	--	Sample							=	5.1	=	6.02	19 - mg/L	01/07 - Weekly	CP - COMPOS		
					Permit Req.															
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	3.131	=	3.302	03 - MGD								99/99 - Continuous	CN - CONTIN	
					Permit Req.															
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample							=	2	=	11	13 - #/100mL	03/07 - Three Per Week	GR - GRAB		
					Permit Req.															
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	138	=	198	26 - lb/d			=	5	=	7	19 - mg/L	03/07 - Three Per Week	CP - COMPOS	
					Permit Req.	<=	501 MO AVG	<=	751 MX WK AV	26 - lb/d			<=	10 MO AVG	<=	15 MX WK AV	19 - mg/L	03/07 - Three Per Week	24 - COMP24	
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	G - Raw Sewage Influent	0	--	Sample							=	245	=	310	19 - mg/L	03/07 - Three Per Week	CP - COMPOS		
					Permit Req.															
					Value NODI															
80091	BOD, carb-5 day, 20 deg C, percent removal	K - Percent Removal	0	--	Sample							=	98			23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.															
					Value NODI															
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample							=	98			23 - %	01/30 - Monthly	CA - CALCTD		
					Permit Req.															
					Value NODI															

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
HC_Coverletter_072019.pdf	pdf	36548
HC_MOR_072019.pdf	pdf	84355

Report Last Saved By

Hite Creek WQTC MSD

User: kevin.thompson@louisvillemsd.org
Name: Kevin Thompson
E-Mail: kevin.thompson@louisvillemsd.org
Date/Time: 2019-08-15 08:29 (Time Zone: -04:00)

Report Last Signed By

User: staci.huber@louisvillemsd.org
Name: Staci Huber
E-Mail: staci.huber@louisvillemsd.org
Date/Time: 2019-08-15 09:37 (Time Zone: -04:00)

