



700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

March 22, 2011

Crystal Thompson
Permit Support Section
Surface Water Permits Branch
Division of Water
200 Fair Oaks Lane 4th Floor
Frankfort, KY 40601

Re: **Morris Forman Water Quality Treatment Center**
KPDES Permit No. KY0022411

Dear Ms. Thompson:

In accordance with the provisions of the KPDES Permit referenced above, the monthly operating report and the monthly Discharge Monitoring Report (DMR) for the reporting period February 1st to February 28th are enclosed. All permit requirements were met for the month of February, 2011.

Should you have any questions, please contact me at (502) 540-6793.

Sincerely,

A handwritten signature in cursive script, reading "Alex E. Novak".

Alex E. Novak, P.E.
Director of Operations

paw

MFDMR0211.doc

Enclosures

cc: C. Roth, DOW-Louisville A. Vicory, ORSANCO



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

NATIONAL POLLUTION DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved.
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)
NAME MSD MORRIS FORMAN WQTC
ADDRESS C/O LOUISVILLE/JEFF CO MSD
4522 ALGONQUIN PKWY
LOUISVILLE, KY 40211-2497
FACILITY MSD MORRIS FORM WQTC
LOCATION LOUISVILLE, KY 40211

KY0022411	0011
PERMIT NUMBER	DISCHARGE NUMBER

MAJOR (SUBR LV)
F - FINAL JEFFE
MUNICIPAL DISCHARGE
EFFLUENT
*** NO DISCHARGE *** ☐

MONITORING PERIOD						
YEAR	MONTH	DAY	TO	YEAR	MONTH	DAY
11	02	01		11	02	28

ATTN: ALEX E NOVAK, OPER DIR

Parameter		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
NITROGEN, AMMONIA TOTAL (AS N) 00810 G 0 0 RAW SEW/INFLUENT	SAMPLE MEASUREMENT	10221	11244	(26)	*****	12.7	16.7	(19)	0	28/28	COMPOS
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT MX WK AV	LBS/DY	*****	REPORT MO AVG	REPORT MX WK AV	MG/L		DAILY	COMPOS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 E 0 0 SEC/BIOLOGICAL PROCESS COMPLET	SAMPLE MEASUREMENT	103.5	169.4	(03)	*****	*****	*****	****	0	28/28	CONTIN
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT DAILY MX	MGD	*****	*****	*****	****		CONTINUOUS	CONTIN
CHLORINE, TOTAL RESIDUAL 50060 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	0.010	(19)	0	28/28	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	0.019 DAILY MX	MG/L		DAILY	GRAB
COLIFORM, FECAL GENERAL 74055 1 1 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	9	30	(13)	0	28/28	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	1000 30DA GEO	2000 7 DA GEO	#/ 100ML		DAILY	GRAB
BOD, 5-DAY PERCENT REMOVAL 81010 K 0 0 PERCENT REMOVAL	SAMPLE MEASUREMENT	*****	*****	****	94	*****	*****	(23)	0	ONCE/MONTH	CALCTD
	PERMIT REQUIREMENT	*****	*****	****	85 MO MIN	*****	*****	PERCENT		ONCE/MONTH	CALCTD
SOLIDS, SUSPENDED PERCENT REMOVAL 81011 K 0 0 PERCENT REMOVAL	SAMPLE MEASUREMENT	*****	*****	****	96	*****	*****	(23)	0	ONCE/MONTH	CALCTD
	PERMIT REQUIREMENT	*****	*****	****	85 MO MIN	*****	*****	PERCENT		ONCE/MONTH	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
NAME/TITLE PRINCIPLE EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.								Telephone		DATE
H. J. SCHARDEIN, JR. EXECUTIVE DIRECTOR	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT								502 540-6000		11-03-22
									AREA	NUMBER	YEAR - MO - DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
G - INFLUENT
E - SECONDARY EFFLUENT
F - SECONDARY BYPASS AFTER PRIMARY TREATMENT.

NATIONAL POLLUTION DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

Form Approved.
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Address if Different)


NAME MSD MORRIS FORMAN WQTC
ADDRESS C/O LOUISVILLE/JEFF CO MSD
4522 ALGONQUIN PKWY
LOUISVILLE, KY 40211-2497
FACILITY MSD MORRIS FORM WQTC
LOCATION LOUISVILLE, KY 40211

KY0022411	001 B
PERMIT NUMBER	DISCHARGE NUMBER

MAJOR
(SUBR LV)
F - FINAL JEFFE
SECONDARY BYPASS
EFFLUENT
*** NO DISCHARGE *** ☐

MONITORING PERIOD					
YEAR	MONTH	DAY	YEAR	MONTH	DAY
11	02	01	11	02	28

ATTN: ALEX E NOVAK, OPER DIR

Parameter		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BOD, 5-DAY (20 DEG. C) 00310 F 0 0 PRI/PRLM PRCS CMPLT	SAMPLE MEASUREMENT	*****	*****	****	*****	191	252	(19)	0	10/28	COMPOS
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MO AVG	REPORT MX WK AV	MG/L		WHEN DISCHG	COMPOS
BOD, 5-DAY (20 DEG. C) 00310 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	44	59	(19)	0	10/28	COMPOS
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MO AVG	REPORT MX WK AV	MG/L		WHEN DISCHG	COMPOS
SOLIDS, TOTAL SUSPENDED 00530 F 0 0 PRI/PRLM PRCS CMPLT	SAMPLE MEASUREMENT	*****	*****	****	*****	197	232	(19)	0	10/28	COMPOS
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MO AVG	REPORT MX WK AV	MG/L		WHEN DISCHG	COMPOS
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	60	94	(19)	0	10/28	COMPOS
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MO AVG	REPORT MX WK AV	MG/L		WHEN DISCHG	COMPOS
NITROGEN, AMMONIA TOTAL (AS N) 00610 F 0 0 PRI/PRLM PRCS CMPLT	SAMPLE MEASUREMENT	*****	*****	****	*****	12.6	21.0	(19)	0	10/28	COMPOS
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MO AVG	REPORT MX WK AV	MG/L		WHEN DISCHG	COMPOS
NITROGEN, AMMONIA TOTAL (AS N) 00610 1 0 0 EFFLUENT GROSS VALUE	SAMPLE MEASUREMENT	*****	*****	****	*****	11.1	20.0	(19)	0	10/28	COMPOS
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MO AVG	REPORT MX WK AV	MG/L		WHEN DISCHG	COMPOS
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 F 0 0 PRI/PRLM PRCS CMPLT	SAMPLE MEASUREMENT	38.10	50.82	(03)	*****	*****	*****	****	0	10/28	CONTIN
	PERMIT REQUIREMENT	REPORT MO AVG	REPORT MX WK AV	MGD	*****	*****	*****	****		WHEN DISCHG	CONTIN
NAME/TITLE PRINCIPLE EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.								Telephone	DATE	
H. J. SCHARDEIN, JR. EXECUTIVE DIRECTOR	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT								502 540-6000	11-03-22	
								AREA	NUMBER	YEAR - MO - DAY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

MONITORING DURING PERIODS OF SECONDARY BYPASS IN ADDITION TO REGULAR MONITORING.

1 - FINAL EFFLUENT

F - SECONDARY BYPASS AFTER PRIMARY TREATMENT.

DATE	WASTEWATER FLOWS (Million Gallons)			TEMP (DEGF)		pH		SETS (M/L)		TSS (mg/L)		TS (mg/L)		D.O. (mg/L)		5-DAY BOD (mg/L)			RETURN SLUDGE FLOW TSS TVSS			AERATION BASIN					ACTIVE		CHLORINATION			FINAL EFFLUENT	
	Final Sec.			raw	final	raw	final	raw	final	raw	final	raw	final	final	raw	prim. final	final		FLOW MG	TSS g/L	TVSS g/L	D.O. mg/L	MLSS g/L	MLVSS g/L	SET	SVI	Sludge Wasted MG	Primary Sludge MG	Chlorine Dosage KLBS	Resid mg/L	Fecal Coliform #/100 ml	NH3-N mg/L	Pump. Hours
	Effluent	Effluent	Bypass																														
2/1	153.5	113.8	39.7	59	59	7.3	6.4	17.0	7.0	502	191			6.8	353	337	92		30.8	13.5	11.8	12.1	4.4	3.9	277	63	1.38	0.33	3.20	0.010	3	19	0.00
2/2	175.2	135.1	40.1	55	55	7.1	6.4	12.0	3.0	342	107			9.6	224	177	68		29.8	13.2	11.1	17.0	3.3	2.7	222	67	1.36	0.38	3.98	0.010	80	11	0.00
2/3	113.2	113.2	0.0	55	55	7.5	6.8	18.0	0.1	342	32			10.7	365	239	24		30.4	14.1	11.8	15.0	4.9	4.2	249	51	1.37	0.39	3.98	0.010	25	13	11.00
2/4	111.3	111.3	0.0	55	55	7.5	6.7	18.0	0.1	364	16			6.7	352	228	15		29.9	16.2	13.4	14.3	4.0	3.4	267	66	1.39	0.40	1.68	0.010	18	12	24.00
2/5	141.7	128.8	12.9	57	57	7.6	6.8	12.0	0.3	232	50			6.8	237	187	35		29.9	15.9	13.3	13.4	3.8	3.3	230	81	1.26	0.31	2.29	0.010	430	11	24.00
2/6	104.6	104.6	0.0	55	55	7.5	6.8	11.0	0.1	288	23			8.4	224	206	12		29.9	16.4	13.8	17.1	4.1	3.5	242	58	1.31	0.25	2.29	0.010	6	13	24.00
2/7	147.3	121.1	26.2	56	58	7.4	6.8	12.0	0.2	264	29			8.5	266	216	43		30.0	15.1	11.9	14.5	3.3	2.5	237	73	1.20	0.27	2.98	0.010	4	14	14.00
2/8	108.0	108.0	0.0	58	58	7.4	6.7	14.0	0.1	288	19			8.7	308	230	15		30.2	15.9	13.5	18.1	3.8	3.3	233	63	1.10	0.32	2.98	0.010	10	11	0.00
2/9	98.3	98.3	0.0	55	55	7.3	6.7	13.0	0.1	378	15			7.7	268	211	16		29.9	15.8	13.2	13.4	3.4	2.9	263	78	1.14	0.22	1.45	0.010	6	13	0.00
2/10	91.6	91.6	0.0	55	55	7.4	6.7	16.0	0.1	348	7			6.9	342	218	13		29.6	15.4	12.8	13.7	3.9	3.4	247	84	1.07	0.37	1.42	0.010	4	15	0.00
2/11	91.5	91.5	0.0	55	55	7.5	6.7	13.0	0.1	310	17			8.0	286	218	15		29.0	16.8	15.4	14.1	4.7	4.5	273	59	0.98	0.31	1.56	0.010	2	17	0.00
2/12	85.3	85.3	0.0	58	58	7.4	6.7	12.0	0.2	370	29			7.4	280	240	20		29.4	15.1	11.9	15.1	3.3	2.5	283	87	0.97	0.29	1.56	0.010	4	14	0.00
2/13	81.7	81.7	0.0	59	59	7.4	6.7	9.0	0.1	288	41			7.6	232	187	40		29.2	15.7	13.2	16.1	4.3	3.6	270	83	1.10	0.14	1.45	0.010	2	16	0.00
2/14	83.0	83.0	0.0	59	59	7.4	6.9	5.5	0.1	398	14			8.8	308	172	13		28.7	12.8	10.8	15.8	4.8	4.1	244	55	1.00	0.27	1.44	0.010	2	18	0.00
2/15	80.5	80.5	0.0	60	60	7.4	6.8	20.0	0.1	460	12			7.4	341	243	11		28.8	14.7	12.9	14.2	4.2	3.7	269	64	0.90	0.34	1.36	0.010	4	20	0.00
2/16	80.9	80.9	0.0	64	64	7.3	6.8	9.0	0.1	492	19			7.8	427	328	17		28.5	13.7	11.7	12.4	4.2	3.7	283	67	0.94	0.37	1.31	0.010	4	21	0.00
2/17	81.8	81.8	0.0	65	65	7.2	6.8	19.0	0.1	598	16			6.5	486	311	17		28.8	14.4	12.5	14.8	4.7	4.1	284	59	0.98	0.38	1.55	0.010	2	21	0.00
2/18	77.2	77.2	0.0	61	61	7.2	6.7	16.0	0.1	562	15			7.5	440	308	15		28.9	14.5	12.3	13.2	4.2	3.6	313	76	1.00	0.27	1.55	0.010	2	21	0.00
2/19	69.2	69.2	0.0	62	62	7.4	6.7	18.0	0.1	442	15			7.3	404	274	13		29.1	11.8	10.1	13.0	3.8	3.3	326	85	1.05	0.27	1.50	0.010	10	21	0.00
2/20	76.7	76.7	0.0	61	61	7.1	6.7	20.0	0.1	434	12			8.1	332	241	11		29.1	13.8	11.8	13.0	4.8	4.2	318	68	1.08	0.20	1.51	0.010	2	20	0.00
2/21	98.9	89.0	7.9	64	64	7.4	6.7	18.0	0.1	584	24			7.2	370	252	23		28.7	14.1	11.9	12.4	6.1	5.1	288	49	1.10	0.23	2.44	0.010	2	20	0.00
2/22	92.8	92.8	0.0	62	62	7.5	6.8	18.0	0.1	388	14			7.1	322	232	12		30.2	14.2	11.6	13.2	4.3	3.8	267	67	1.15	0.22	2.44	0.010	4	18	13.00
2/23	93.9	93.9	0.0	60	60	7.3	6.8	19.0	0.1	508	16			7.1	370	205	14		28.4	13.1	11.3	11.4	4.3	3.6	274	65	1.22	0.24	1.47	0.010	2	19	24.00
2/24	182.6	121.7	40.9	63	63	7.3	6.7	17.0	1.0	592	75			7.8	378	286	54		29.9	13.8	11.8	13.5	4.5	3.9	292	67	1.13	0.27	4.59	0.010	2	15	24.00
2/25	210.0	139.4	70.6	55	55	7.6	6.9	4.5	1.0	170	38			7.9	117	127	43		30.1	15.6	12.7	17.2	3.5	2.8	219	64	1.02	0.27	8.24	0.010	213	5	24.00
2/26	161.9	141.0	20.9	56	56	7.4	7.3	4.0	0.1	138	26			10.2	143	119	23		30.2	15.7	12.8	15.2	3.4	2.9	237	69	1.14	0.13	6.24	0.010	85	5	24.00
2/27	169.8	142.9	26.9	57	57	7.0	7.0	4.0	0.1	124	26			8.8	123	110	20		30.3	16.4	13.8	15.7	3.9	3.5	242	62	1.13	0.12	2.52	0.010	144	7	24.00
2/28	238.7	144.9	94.8	59	59	7.4	6.4	5.5	0.1	278	33			9.8	88	101	41		30.0	15.8	12.5	18.0	3.4	2.7	210	63	1.05	0.22	3.11	0.010	580	5	24.00
Total	3280.1	2899.2	380.9																828.3														254.00
Average	117.1	103.5	13.6	59	59	7.4	6.7	13.4	0.5	374	33			8.0	299	222	26		29.6	14.8	12.4	14.5	4.1	3.5	264	65	1.12	0.28	2.50	0.010	9	15	0.00

SEWER CONNECTIONS

130404 TIMES 4 = 521616 SEWER POPULATION

IND. WASTER POPULATION EQ
 CUSTOMERS 322
 FLOW 594064
 BOD 1198809
 TSS 1219708

Authorized Agent

[Signature]

Certification No. 4663

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
----------------------	------------------------	---	--	----------------

Facility Type SMH Sewer Manhole	Facility ID 02933	Facility Address 7900 SHELBYVILLE RD	If Pump Station, Name of Pump Station:	Receiving Stream MIDDLE FORK BEARGRASS CREEK	Discharge to STREAM
------------------------------------	----------------------	---	--	--	------------------------

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1211626	02/24/11 11:59 PM	CLARK	GRIFFITH	DOCUMENTED	03/04/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 10:24 AM	

Spot Inspections:

Discharge Amount:	64,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213851
Control Zone:	BARRICADES, CAUTION TAPE, TEMP SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	LOCATION INCLUDED IN THE ISSDP SUBMITTED ON 21-31-08

Notifications:

02/25/11 06:35 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMPORARY SIGNS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
--------------------------------------	-------------------------------	--	---	-----------------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	02935	7900 SHELBYVILLE RD		MIDDLE FORK BEARGRASS CREEK	STREAM

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211625	02/24/11 11:57 PM	CLARK	GRIFFITH	DOCUMENTED	03/19/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 10:21 AM	

Spot Inspections:

Discharge Amount:	32,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213843
Control Zone:	BARRICADES, CAUTION TAPE, TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	LOCATION INCLUDED IN ISSDP SUBMITTED ON 12-32-08

Notifications:

02/25/11 06:31 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMPORARY SIGNS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08426	4315 PRUITT CT		SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1212169	02/25/11 01:46 AM	JOHNSON JR	GRIFFITH	DOCUMENTED	02/25/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 01:00 PM	

Spot Inspections:

Discharge Amount:	22,300 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213786
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMP SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 08:32 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)		Facility ID MSD0278		Water Quality Treatment Center MORRIS FORMAN		Receiving Stream of Treatment Center OHIO RIVER		Region WEST			
Facility Type		Facility ID		Facility Address		If Pump Station, Name of Pump Station:		Receiving Stream		Discharge to	
SMH Sewer Manhole		08427		4313 PRUITT CT				SOUTH FORK BEARGRASS CREEK		GROUND	
<u>Activity Code / Description</u>		<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE		1212173	02/25/11 01:40 AM	JOHNSON JR	GRIFFITH	DOCUMENTED	02/25/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 12:45 PM	

Spot Inspections:

Discharge Amount:	6,200 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213777
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMP SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT DEBRIS OBSERVED AROUND DISCHARGE
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 08:41 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1215536	02/28/11 01:30 PM	JOHNSON JR	GRIFFITH	DOCUMENTED	02/25/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 12:45 PM	

Spot Inspections:

Discharge Amount:	16,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DICLN WO# 1216103
Control Zone:	BARRICADE, CAUTION TAPE, TEMP SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPCT OBSERVED ROUND DISCHARGE
Repair:	LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/28/11 05:42 PM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID DISCHARGE
02/28/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08431	4339 PRUITT CT		SOUTH FORK BEARGRASS CREEK	GROUND

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1212165	02/25/11 02:16 AM	JOHNSON JR	GRIFFITH	DOCUMENTED	02/25/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 01:30 PM	

Spot Inspections:

Discharge Amount:	10,250 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213793
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMPORARY SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 08:28 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1215576	02/28/11 01:36 PM	JOHNSON JR	GRIFFITH	DOCUMENTED	02/25/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 01:30 PM	

Spot Inspections:

Discharge Amount:	41,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1215653
Control Zone:	BARRICADE, CAUTION TAPE, TEMP SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT DEBRIS OBSERVED
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/28/11 07:24 PM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMP SIGN TO AVOID CONTACT WITH DISCHARGE
02/28/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08935-SM	1001 BRECKENRIDGE LN		MIDDLE FORK BEARGRASS CREEK	STREAM

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211553	02/24/11 10:41 PM	GRIFFITH	GRIFFITH	DOCUMENTED	11/29/01	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/26/11 12:27 AM	

Spot Inspections:

Discharge Amount:	7,494,807 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	CLEAN UP NOT POSSIBLE DUE TO MAGNITUDE OF STORM
Control Zone:	MSD PROPERTY. PERMANENT SIGNS
Impact:	NO IMPACT OBSERVED-PIPE SUBMERGED
Repair:	LOCATION INCLUDED IN THE SANITARY SEWER DISCHARGE PLAN SUBMITTED ON DECEMBER 31, 2008

Notifications:

02/24/11 10:44 PM	DISPUB	PUBLIC NOTIFIED THROUGH PERMANENT SIGNS TO AVOID DIRECT CONTACT WITH DISCHARGED CONTENT
02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST						
Activity Code / Description DISREV: RAIN EVENT DISCHARGE	WO # 1215305	Initiated 02/28/11 08:27 AM	Initiated By GRIFFITH	Assigned To GRIFFITH	Disch Status DOCUMENTED	Event Date 11/29/01	Problem LACK OF SYSTEM CAPACITY	Result UNAUTHORIZED DISCHARGE - WATERS	Completed 03/01/11 10:07 AM	Condition

Spot Inspections:

Discharge Amount:	31,027 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	CLEAN UP NOT POSSIBLE DUE TO MAGNITUDE OF STORM
Control Zone:	NONE NEEDED MSD PROPERTY
Impact:	NONE OBSERVED-PIPE SUBMERGED
Repair:	SITE IS INCLUDED IN ISSDP

Notifications:

02/28/11 12:52 PM	DISPUB	PUBLIC NOTIFIED THROUGH PERMANENT SIGNS TO AVOID DISCHARGE
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	104231	4119 LEE AVE		CAMP TAYLOR DITCH	GROUND

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1212240	02/24/11 08:45 PM	MITCHELL	GRIFFITH	DOCUMENTED	10/23/07	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/02/11 05:33 PM	

Spot Inspections:

Discharge Amount:	11,950 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214078
Control Zone:	CAUTION TAPE AND TEMP SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	LOCATION INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 09:46 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN				Receiving Stream of Treatment Center OHIO RIVER			Region WEST	
<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1214681	02/28/11 07:20 AM	MITCHELL	GRIFFITH	DOCUMENTED	10/23/07	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/02/11 05:35 PM	

Spot Inspections:

Discharge Amount:	10,900 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1216239
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/28/11 09:58 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMP SIGNS TO AVOID CONTACT WITH DISCHARGE
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type SMN Sewer Main	Facility ID 104818	Facility Address 4600 CHAMPIONS TRACE LN	If Pump Station, Name of Pump Station:	Receiving Stream BUECHEL BRANCH	Discharge to STREAM
---------------------------------	-----------------------	---	--	------------------------------------	------------------------

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1213942	02/25/11 03:18 PM	DAVIS	BUECHEL	REPAIRED - ISSUE RESOLVED	02/25/11	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 05:00 PM	MAIN

Spot Inspections:

Discharge Amount:	1,500 GAL
Cause:	SUSPECTED SEWER MAIN BREAK
Clean Up:	NO DEBRIS, CONTRACTOR CLEANED AND SANITIZED
Control Zone:	SIGNS, BARRICADES, FLAGS, AND FENCING
Impact:	DISCOLORATION IN STREAM
Repair:	SET UP PUMPS TO FORCE SEWAGE INTO AJACENT MH. CONTRACTOR REPAIRED CRACK IN LINE IMMEDIATELY ONCE DETECTED USING A PATCH.

Notifications:

02/25/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 12:00 AM	DISPUB	Permanent signs posted along stream to notify the public.

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	13943	4119 LEE AVE		SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1212249	02/24/11 10:20 PM	MITCHELL	GRIFFITH	DOCUMENTED	03/19/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/02/11 05:32 PM	

Spot Inspections:

Discharge Amount:	6,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214072
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	LOCATION INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 08:48 PM	DISPUB	PUBLIC NOTIFIED THOROUGH DOOR HANGERS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	16649	1726 FRASER DR		SOUTH FORK BEARGRASS CREEK	DITCH

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1196691	02/01/11 07:45 PM	MITCHELL	GRIFFITH	DOCUMENTED	01/24/02	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/01/11 08:45 PM	

Spot Inspections:

Discharge Amount:	320 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1196704
Control Zone:	DOOR HANGERS AND CAUTION TAPE PLACED AROUND DISCHARGE
Impact:	LIGHT SOLIDS OBSERVED AROUND DISCHARGE LOCATION
Repair:	THIS LOCATION IS INCLUDED IN THE SANITARY SEWER DISCHARGE PLAN SUBMITTED ON DECEMBER 31, 2008

Notifications:

02/02/11 01:13 PM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND PERMANENT SIGNS TO AVOID DIRECT CONTACT WITH DISCHARGED CONTENT
02/02/11 02:57 PM	DISNOT	Manual email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES #
KY0022411 (Cont'd)Facility ID
MSD0278Water Quality Treatment Center
MORRIS FORMANReceiving Stream of Treatment Center
OHIO RIVERRegion
WEST

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1212220	02/24/11 09:40 PM	MITCHELL	GRIFFITH	DOCUMENTED	01/24/02	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/26/11 01:00 PM	

Spot Inspections:

Discharge Amount:	1,429,320 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1215330
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 09:34 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMP SIGN TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST						
Activity Code / Description DISREV: RAIN EVENT DISCHARGE	WO # 1215314	Initiated 02/28/11 07:44 AM	Initiated By GRIFFITH	Assigned To GRIFFITH	Disch Status DOCUMENTED	Event Date 01/24/02	Problem LACK OF SYSTEM CAPACITY	Result UNAUTHORIZED DISCHARGE - WATERS	Completed 02/28/11 05:05 PM	Condition

Spot Inspections:

Discharge Amount:	120,120 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1216200
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP

Notifications:

02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:10 PM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGER AND TEMPORARY SIGNS TO AVOID DISCHARGE
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	18298	2201 GERALD CT		SOUTH FORK BEARGRASS CREEK	STREAM

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1212155	02/24/11 11:55 PM	JOHNSON JR	GRIFFITH	DOCUMENTED	05/28/04	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 11:45 AM	

Spot Inspections:

Discharge Amount:	21,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213812
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMP SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 08:20 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID DIRECT CONTACT WITH DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	18299	2201 GERALD CT		SOUTH FORK BEARGRASS CREEK	STREAM

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1215327	02/28/11 12:30 PM	GITTINGS	GITTINGS	DOCUMENTED	02/28/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/28/11 04:15 PM	

Spot Inspections:

Discharge Amount:	25 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA
Control Zone:	PLACED TEMPORARY SIGNS AROUND AREA
Impact:	WATER COMING FROM MANHOLE GOING INTO THE CREEK
Repair:	MSD PERSONNAL HAVE BEEN NOTIFIED

Notifications:

02/28/11 12:30 PM	DISPUB	ADVISED MSD PERSONNEL
02/28/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	18471	3107 DELL BROOKE AVE		SOUTH FORK BEARGRASS CREEK	CATCH BASIN

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1211569	02/24/11 11:00 PM	BRIGHT	BRIGHT	DOCUMENTED	02/17/00	PUMPED OVERFLOW	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 02:55 PM	

Spot Inspections:

Discharge Amount:	1,552,900 GAL
Cause:	SET PUMPS TO ALLEVIATE PROPERTY DAMAGE AND FLOODING DURING A SIGNIFICANT RAIN EVENT
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE OVERFLOW SITE ONCE THE RAIN SUBSIDED
Control Zone:	MSD PERSONNEL SET OUT BARRICADES AND TEMPORARY SIGNS ON THE PUMP
Impact:	THE MAJORITY OF THIS OVERFLOW CONSISTED PRIMARILY OF STORMWATER WITH SOME SEWAGE.
Repair:	THIS LOCATION IS IN THE INTERIM SANITARY SEWER DISCHARGE PLAN

Notifications:

02/24/11 11:00 PM	DISPUB	MSD PERSONNEL PLACED SIGNS
02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES #
KY0022411 (Cont'd)Facility ID
MSD0278Water Quality Treatment Center
MORRIS FORMANReceiving Stream of Treatment Center
OHIO RIVERRegion
WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1214419	02/28/11 07:40 AM	BRIGHT	BRIGHT	DOCUMENTED	02/17/00	PUMPED OVERFLOW	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 04:03 AM	

Spot Inspections:

Discharge Amount:	1,908,000 GAL
Cause:	SET PUMPS TO ALLEVIATE PROPERTY DAMAGE AND FLOODING DURING A SIGNIFICANT RAIN EVENT
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE OVERFLOW SITE ONCE THE RAIN SUBSIDED
Control Zone:	MSD PERSONNEL SET OUT BARRICADES AND TEMPORARY SIGNS ON THE PUMP
Impact:	THE MAJORITY OF THIS OVERFLOW CONSISTED PRIMARILY OF STORMWATER WITH SOME SEWAGE.
Repair:	THIS LOCATION IS IN THE INTERIM SANITARY SEWER DISCHARGE PLAN

Notifications:

02/28/11 07:40 AM	DISPUB	MSD PERSONNEL PLACED SIGNS
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN		Receiving Stream of Treatment Center OHIO RIVER		Region WEST				
Facility Type	Facility ID	Facility Address		If Pump Station, Name of Pump Station:		Receiving Stream	Discharge to			
SMH Sewer Manhole	18483	3015 BOAIRES LN				SOUTH FORK BEARGRASS CREEK	CATCH BASIN			
<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211571	02/24/11 11:05 PM	BRIGHT	BRIGHT	DOCUMENTED	02/17/00	PUMPED OVERFLOW	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 12:45 PM	

Spot Inspections:

Discharge Amount:	1,071,100 GAL
Cause:	SET PUMPS TO ALLEVIATE PROPERTY DAMAGE AND FLOODING DURING A SIGNIFICANT RAIN EVENT.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE OVERFLOW SITE ONCE THE RAIN SUBSIDED
Control Zone:	MSD SET BARRICADES AND TEMPORARY SIGNS ON THE PUMPS
Impact:	THE MAJORITY OF THIS OVERFLOW CONSISTED PRIMARILY OF STORMWATER WITH SOME SEWAGE.
Repair:	THIS LOCATION IS IN THE INTERIM SANITARY SEWER DISCHARGE PLAN

Notifications:

02/25/11 11:05 PM	DISPUB	MSD PERSONNEL PLACED SIGNS
02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES #
KY0022411 (Cont'd)Facility ID
MSD0278Water Quality Treatment Center
MORRIS FORMANReceiving Stream of Treatment Center
OHIO RIVERRegion
WEST

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1214425	02/28/11 07:57 AM	BRIGHT	BRIGHT	DOCUMENTED	02/17/00	PUMPED OVERFLOW	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 02:30 AM	

Spot Inspections:

Discharge Amount:	1,732,200 GAL
Cause:	SET PUMPS TO ALLEVIATE PROPERTY DAMAGE AND FLOODING DURING A SIGNIFICANT RAIN EVENT.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE OVERFLOW SITE ONCE THE RAIN SUBSIDED
Control Zone:	MSD SET BARRICADES AND TEMPORARY SIGNS ON THE PUMPS
Impact:	THE MAJORITY OF THIS OVERFLOW CONSISTED PRIMARILY OF STORMWATER WITH SOME SEWAGE.
Repair:	THIS LOCATION IS IN THE INTERIM SANITARY SEWER DISCHARGE PLAN

Notifications:

02/28/11 07:57 AM	DISPUB	MSD PERSONNEL PLACED SIGNS
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	18505	3540 RAMONA AVE		SOUTH FORK BEARGRASS CREEK	CATCH BASIN

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1211575	02/24/11 11:15 PM	BRIGHT	BRIGHT	DOCUMENTED	02/17/00	PUMPED OVERFLOW	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 04:55 AM	

Spot Inspections:

Discharge Amount:	323,000 GAL
Cause:	SET PUMPS TO ALLEVIATE PROPERTY DAMAGE AND FLOODING DURING A SIGNIFICANT RAIN EVENT.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE OVERFLOW SITE ONCE THE RAIN SUBSIDED
Control Zone:	MSD SET BARRICADES AND TEMPORARY SIGNS ON THE PUMPS
Impact:	THE MAJORITY OF THIS OVERFLOW CONSISTED PRIMARILY OF STORMWATER WITH SOME SEWAGE.
Repair:	THIS LOCATION IS IN THE INTERIM SANITARY SEWER DISCHARGE PLAN

Notifications:

02/24/11 11:15 PM	DISPUB	MSD PERSONNEL PLACED SIGNS
02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1214736	02/28/11 10:25 AM	BRIGHT	BRIGHT	DOCUMENTED	02/17/00	PUMPED OVERFLOW	UNAUTHORIZED DISCHARGE - WATERS	02/28/11 06:13 PM	

Spot Inspections:

Discharge Amount:	444,600 GAL
Cause:	SET PUMPS TO ALLEVIATE PROPERTY DAMAGE AND FLOODING DURING A SIGNIFICANT RAIN EVENT.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE OVERFLOW SITE ONCE THE RAIN SUBSIDED
Control Zone:	MSD SET BARRICADES AND TEMPORARY SIGNS ON THE PUMPS
Impact:	THE MAJORITY OF THIS OVERFLOW CONSISTED PRIMARILY OF STORMWATER WITH SOME SEWAGE.
Repair:	THIS LOCATION IS IN THE INTERIM SANITARY SEWER DISCHARGE PLAN

Notifications:

02/28/11 10:37 AM	DISPUB	MSD PERSONNEL PLACED SIGNS
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	18595	3101 WEDGEWOOD WAY		WEDGEWOOD DITCH	DITCH

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1215321	02/28/11 12:38 PM	BRIGHT	BRIGHT	DOCUMENTED	02/17/00	PUMPED OVERFLOW	UNAUTHORIZED DISCHARGE - WATERS	02/28/11 06:00 PM	

Spot Inspections:

Discharge Amount:	305,900 GAL
Cause:	SET PUMPS TO ALLEVIATE PROPERTY DAMAGE AND FLOODING DURING A SIGNIFICANT RAIN EVENT.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE OVERFLOW SITE ONCE THE RAIN SUBSIDED
Control Zone:	MSD SET BARRICADES AND TEMPORARY SIGNS ON THE PUMPS
Impact:	THE MAJORITY OF THIS OVERFLOW CONSISTED PRIMARILY OF STORMWATER WITH SOME SEWAGE.
Repair:	THIS LOCATION IS IN THE INTERIM SANITARY SEWER DISCHARGE PLAN

Notifications:

02/28/11 12:38 PM	DISPUB	MSD PERSONNEL PLACED SIGNS
02/28/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	21628-W	7404 ARROWWOOD RD		GOOSE CREEK	DITCH

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211580	02/25/11 12:01 AM	ELDER	MILLS	DOCUMENTED	12/16/00	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 11:00 AM	

Spot Inspections:

Discharge Amount:	16,475 GAL
Cause:	LACK OF CAPACITY DUE TO RAIN EVENT IN THE AREA
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED AROUND THE AREA
Impact:	NO IMPACT OBSERVED
Repair:	THIS SITE WAS FOUND DURING RAIN EVENT RECON- WILL BE MONITORED & EVALUATED FOR REPAIR

Notifications:

02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 12:01 AM	DISPUB	TEMPORARY SIGNS POSTED AROUND THE AREA
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES #
KY0022411 (Cont'd)Facility ID
MSD0278Water Quality Treatment Center
MORRIS FORMANReceiving Stream of Treatment Center
OHIO RIVERRegion
WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1215338	02/28/11 01:15 PM	ELDER	MILLS	DOCUMENTED	12/16/00	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/28/11 03:30 PM	

Spot Inspections:

Discharge Amount:	1,750 GAL
Cause:	LACK OF CAPACITY DUE TO RAIN EVENT IN AREA
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS PLACED AROUND THE AREA
Impact:	SEWAGE OBSERVED
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL BE MONITORED & EVALUATED FOR REPAIR

Notifications:

02/28/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:15 PM	DISPUB	TEMPORARY SIGNS PLACED AROUND THE AREA



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	23211	3302 TROUT CREEK DR		SOUTH FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1212271	02/24/11 10:10 PM	MITCHELL	GRIFFITH	DOCUMENTED	02/22/00	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 10:25 AM	

Spot Inspections:

Discharge Amount:	36,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214062
Control Zone:	BARRICADE AND CAUTION TAPE PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	LOCATION INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 08:31 PM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	25876	3703 ALCONA LN		SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1212194	02/24/11 11:30 PM	JOHNSON JR	GRIFFITH	DOCUMENTED	02/18/00	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 10:00 AM	

Spot Inspections:

Discharge Amount:	19,300 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213768
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMP SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 09:11 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN			Receiving Stream of Treatment Center OHIO RIVER			Region WEST		
Facility Type SMH Sewer Manhole	Facility ID 27005	Facility Address 1012 ALTA CIR		If Pump Station, Name of Pump Station: MIDDLE FORK BEARGRASS CREEK			Discharge to GROUND			
<u>Activity Code / Description</u> DISREV: RAIN EVENT DISCHARGE	<u>WO #</u> 1211570	<u>Initiated</u> 02/24/11 11:48 PM	<u>Initiated By</u> FIELDS	<u>Assigned To</u> GRIFFITH	<u>Disch Status</u> DOCUMENTED	<u>Event Date</u> 09/02/03	<u>Problem</u> LACK OF SYSTEM CAPACITY	<u>Result</u> UNAUTHORIZED DISCHARGE - WATERS	<u>Completed</u> 03/01/11 02:30 PM	<u>Condition</u>

Spot Inspections:

Discharge Amount:	37,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214039
Control Zone:	BARRICADES, CAUTION TAPE, AND TEMP SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	LOCATION IS INCLUDED IN THE SANITARY SEWER DISCHARGE PLAN SUBMITTED ON DECEMBER 31, 2008

Notifications:

02/24/11 11:58 PM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS, PERMANENT SIGNS, AND TEMP SIGNS TO AVOID DISCHARGE
02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1214763	02/28/11 08:31 AM	FIELDS	GRIFFITH	DOCUMENTED	09/02/03	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 02:30 PM	

Spot Inspections:

Discharge Amount:	96,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1216150
Control Zone:	BARRICADES AND CAUTION TAPE PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	LOCATION INCLUDED IN THE SANITARY SEWER DISCHARGE PLAN SUBMITTED ON DEC 31, 2008

Notifications:

02/28/11 10:50 AM	DISPUB	PUBLIC NOTIFIED THROUGH PERMANENT SIGNS TO AVOID CONTACT WITH DISCHARGE
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	30681	3401 FOUNTAIN DR		SOUTH FORK BEARGRASS CREEK	GROUND

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211669	02/24/11 11:40 PM	JOHNSON JR	GRIFFITH	DOCUMENTED	10/18/04	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 07:20 AM	

Spot Inspections:

Discharge Amount:	17,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213832
Control Zone:	BARRICADES AND CAUTION TAPE PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	LOCATION INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 07:59 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
Facility Type SMH Sewer Manhole	Facility ID 40871	Facility Address 2120 INDIAN HILLS TRL	If Pump Station, Name of Pump Station:	Receiving Stream MUDDY FORK BEARGRASS CREEK
Discharge to DITCH				
Activity Code / Description DISREV: RAIN EVENT DISCHARGE	WO # 1211588	Initiated 02/25/11 12:40 AM	Initiated By ELDER	Assigned To MILLS
Disch Status DOCUMENTED	Event Date 03/04/08	Problem LACK OF SYSTEM CAPACITY	Result UNAUTHORIZED DISCHARGE - WATERS	Completed 02/26/11 12:40 AM
Condition				

Spot Inspections:

Discharge Amount:	36,000 GAL
Cause:	LACK OF CAPACITY DUE TO RAIN EVENT IN AREA
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS AROUND AFFECTED AREA
Impact:	PERSONAL HYGIENE PRODUCTS AND SEWAGE OBSERVED ON THE GROUND
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR

Notifications:

02/25/11 01:17 AM	DISPUB	Temporary signs posted around affected area
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1215626	02/28/11 09:00 PM	ELDER	THOMPSON	DOCUMENTED	03/04/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 02:50 AM	

Spot Inspections:

Discharge Amount:	8,750 GAL
Cause:	LACK OF CAPACITY DUE TO RAIN EVENT IN AREA
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	CONES PLACED AROUND THE AREA
Impact:	DEBRIS & PERSONAL HYGIENE PRODUCTS OBSERVED
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL BE MONITORED & EVALUATED FOR REPAIR

Notifications:

02/28/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 09:00 PM	DISPUB	cones placed around the area



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN		Receiving Stream of Treatment Center OHIO RIVER		Region WEST				
Facility Type SMH Sewer Manhole	Facility ID 40872	Facility Address 2105 INDIAN HILLS TRL		If Pump Station, Name of Pump Station:		Receiving Stream MUDDY FORK BEARGRASS CREEK	Discharge to GROUND			
<u>Activity Code / Description</u> DISREV: RAIN EVENT DISCHARGE	<u>WO #</u> 1211586	<u>Initiated</u> 02/25/11 12:40 AM	<u>Initiated By</u> ELDER	<u>Assigned To</u> MILLS	<u>Disch Status</u> DOCUMENTED	<u>Event Date</u> 12/15/07	<u>Problem</u> LACK OF SYSTEM CAPACITY	<u>Result</u> UNAUTHORIZED DISCHARGE - WATERS	<u>Completed</u> 02/26/11 12:40 AM	<u>Condition</u>

Spot Inspections:

Discharge Amount:	216,090 GAL
Cause:	LACK OF CAPACITY DUE TO RAIN EVENT IN AREA
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	BARRICADES & TEMPORARY SIGNS WERE POSTED.
Impact:	PERSONAL HYGIENE PRODUCTS & SEWAGE OBSERVED ON THE GROUND
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR

Notifications:

02/25/11 01:12 AM	DISPUB	BARRICADES & TEMPORARY SIGNS WERE POSTED
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1215617	02/28/11 09:00 PM	ELDER	THOMPSON	DOCUMENTED	12/15/07	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 02:50 AM	

Spot Inspections:

Discharge Amount:	10,500 GAL
Cause:	LACK OF CAPACITY DUE TO RAIN EVENT IN AREA
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	BARRACADES PLACED IN STREET
Impact:	DEBRIS & PERSONAL HYGIENE PRODUCTS OBSERVED.
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL BE MONITORED & EVALUATED FOR REPAIR

Notifications:

02/28/11 11:16 PM	DISPUB	Barricades in the street
02/28/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
--------------------------------------	-------------------------------	--	---	-----------------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	41374	300 MOCKINGBIRD VALLEY RD		MUDDY FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1211631	02/25/11 01:35 AM	FIELDS	GRIFFITH	DOCUMENTED	03/27/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/26/11 12:15 PM	

Spot Inspections:

Discharge Amount:	157,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214653
Control Zone:	CAUTION TAPE AND PERMANENT SIGNS
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	LOCATION INCLUDED IN THE ISSDP SUBMITTED ON DECEMBER 31, 2008

Notifications:

02/25/11 07:05 AM	DISPUB	PUBLIC NOTIFIED THROUGH PERMANENT SIGNS TO AVOID CONTACT WITH DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES #
KY0022411 (Cont'd)Facility ID
MSD0278Water Quality Treatment Center
MORRIS FORMANReceiving Stream of Treatment Center
OHIO RIVERRegion
WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1215308	02/28/11 11:03 AM	GRIFFITH	GRIFFITH	DOCUMENTED	03/27/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/28/11 12:09 PM	

Spot Inspections:

Discharge Amount:	7,950 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1216128
Control Zone:	CAUTION TAPE AND STAKES PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP

Notifications:

02/28/11 12:56 PM	DISPUB	PUBLIC NOTIFIED THROUGH PERMANENT SIGNS TO AVOID DISCHARGE
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	41416	3343 BROWNSBORO RD		MUDDY FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1211633	02/25/11 01:43 AM	FIELDS	GRIFFITH	FORCE MAJEURE	08/04/09	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/26/11 12:20 PM	

Spot Inspections:

Discharge Amount:	75,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214662
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT DEBRIS OBSERVED AROUND DISCHARGE
Repair:	LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 07:08 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	43472	8409 SABERDEE DR		GOOSE CREEK	DITCH

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211578	02/24/11 11:55 PM	ELDER	MILLS	DOCUMENTED	03/04/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 10:32 AM	

Spot Inspections:

Discharge Amount:	15,925 GAL
Cause:	LACK OF CAPACITY DUE TO RAIN EVENT IN AREA
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED AROUND THE AREA
Impact:	PERSONAL HYGIENE PRODUCTS & SEWAGE OBSERVED ON THE GROUND
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR AND EVALUATE FOR REPAIR

Notifications:

02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/24/11 11:55 PM	DISPUB	TEMPORARY SIGNS POSTED AROUND THE AREA
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN		Receiving Stream of Treatment Center OHIO RIVER		Region WEST				
Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:		Receiving Stream	Discharge to				
SMH Sewer Manhole	45835	1132 ROSTREVOR CIR			MIDDLE FORK BEARGRASS CREEK	GROUND				
<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211568	02/24/11 11:21 PM	FIELDS	GRIFFITH	DOCUMENTED	09/02/03	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 02:05 AM	

Spot Inspections:

Discharge Amount:	42,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214040
Control Zone:	CAUTION TAPE AND TEMP SIGNS PLACED AROUND AREA
Impact:	LIGHT IMPACT OBSERVED
Repair:	LOCATION INCLUDED IN THE SANITARY SEWER DISCHARGE PLAN SUBMITTED ON DECEMBER 31, 2008

Notifications:

02/24/11 11:54 PM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMPORARY SIGNS TO AVOID DISCHARGE
02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1214746	02/28/11 08:20 AM	FIELDS	GRIFFITH	DOCUMENTED	09/02/03	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/28/11 12:03 PM	

Spot Inspections:

Discharge Amount:	100,350 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1216164
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	THIS LOCATION IS INCLUDED IN THE SANITARY SEWER DISCHARGE PLAN SUBMITTED ON DECEMBER 31, 2008

Notifications:

02/28/11 10:41 AM	DISPUB	PUBLIC NOTIFIED THROUGH PERMANENT SIGNS TO AVOID CONTACT WITH DISCHARGE
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47593	8021 CHRISTIAN CT		MIDDLE FORK BEARGRASS CREEK	GROUND

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211629	02/25/11 01:08 AM	CLARK	GRIFFITH	DOCUMENTED	03/19/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 09:25 AM	

Spot Inspections:

Discharge Amount:	14,750 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214057
Control Zone:	BARRICADES AND TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 07:00 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMPORARY SIGNS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	48885	2201 GERALD CT		SOUTH FORK BEARGRASS CREEK	STREAM

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211682	02/24/11 11:58 PM	JOHNSON JR	GRIFFITH	DOCUMENTED	02/24/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 12:00 PM	

Spot Inspections:

Discharge Amount:	19,250 GAL
Cause:	LACK OF CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213825
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMPORARY SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	LOCATION INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 08:11 AM	DISPUB	PUBLIIC NOTIFIED THROUGH DOOR HANGERS AND TEMP SIGNS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	49647	4315 PRUITT CT		SOUTH FORK BEARGRASS CREEK	GROUND

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1215574	02/28/11 01:33 PM	JOHNSON JR	GRIFFITH	DOCUMENTED	02/28/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 01:00 PM	

Spot Inspections:

Discharge Amount:	13,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1215785
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMP SIGN PLACED AROUND DISCHARGE
Impact:	VERY LIGHT DEBRIS OBSERVED
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/28/11 07:22 PM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE
02/28/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	49672	3603 BARDSTOWN RD		SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1212158	02/24/11 11:51 PM	JOHNSON JR	GRIFFITH	DOCUMENTED	12/15/07	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 11:00 AM	

Spot Inspections:

Discharge Amount:	32,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1213800
Control Zone:	BARRICADE, CAUTION TAPE, AND TEMPORARY SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 08:24 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES #
KY0022411 (Cont'd)Facility ID
MSD0278Water Quality Treatment Center
MORRIS FORMANReceiving Stream of Treatment Center
OHIO RIVERRegion
WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1215318	02/28/11 12:30 PM	GITTINGS	GITTINGS	DOCUMENTED	12/15/07	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/28/11 04:12 PM	

Spot Inspections:

Discharge Amount:	10 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA
Control Zone:	PLACED TEMPORARY DISCHARGE SIGNS AROUND THE IMPACTED AREA
Impact:	WATER COMING OUT OF MANHOLE GOING INTO THE CATCH BASIN
Repair:	NEED TO WAIT FOR RAIN TO STOP

Notifications:

02/28/11 12:30 PM	DISPUB	ADVISED MSD PERSONNEL ABOUT ISSUE
02/28/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN			Receiving Stream of Treatment Center OHIO RIVER			Region WEST		
Facility Type	Facility ID	Facility Address		If Pump Station, Name of Pump Station:			Receiving Stream	Discharge to		
SMH Sewer Manhole	51160	3305 INDIAN CREEK CT					SOUTH FORK BEARGRASS CREEK	GROUND		
<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1212258	02/24/11 10:20 PM	MITCHELL	GRIFFITH	DOCUMENTED	04/04/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 10:11 AM	

Spot Inspections:

Discharge Amount:	44,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214068
Control Zone:	CAUTION TAPE AND TEMP SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 10:09 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	51594	1418 TREVILIAN WAY		SOUTH FORK BEARGRASS CREEK	DITCH

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1212227	02/24/11 10:31 PM	MITCHELL	GRIFFITH	DOCUMENTED	09/12/06	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 09:30 AM	

Spot Inspections:

Discharge Amount:	12,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214083
Control Zone:	CAUTION TAPE AND TEMP SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	THIS LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 09:40 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST						
Activity Code / Description DISREV: RAIN EVENT DISCHARGE	WO # 1214714	Initiated 02/28/11 07:38 AM	Initiated By MITCHELL	Assigned To GRIFFITH	Disch Status DOCUMENTED	Event Date 09/12/06	Problem LACK OF SYSTEM CAPACITY	Result UNAUTHORIZED DISCHARGE - WATERS	Completed 03/01/11 11:00 AM	Condition

Spot Inspections:

Discharge Amount:	19,300 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1216263
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	LOCATION IS INCLUDED IN THE ISSDP SUBMITTED ON 2-31-08

Notifications:

02/28/11 10:17 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65633	4640 BARBOUR LN		LITTLE GOOSE CREEK	STREAM

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211604	02/25/11 01:40 AM	ELDER	MILLS	DOCUMENTED	04/04/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 05:18 AM	

Spot Inspections:

Discharge Amount:	54,500 GAL
Cause:	RAIN EVENT IN AREA, LACK OF CAPACITY
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED AROUND THE AREA
Impact:	SEWAGE OBSERVED ON THE GROUND
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL BE MONITORED & EVALUATED FOR REPAIR

Notifications:

02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:40 AM	DISPUB	TEMPORARY SIGNS POSTED
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)		Facility ID MSD0278		Water Quality Treatment Center MORRIS FORMAN		Receiving Stream of Treatment Center OHIO RIVER		Region WEST			
Facility Type SMH Sewer Manhole		Facility ID 72571-X		Facility Address 4600 CHAMPIONS TRACE LN		If Pump Station, Name of Pump Station: SOUTH FORK BEARGRASS CREEK		Discharge to STREAM			
Activity Code / Description DISREV: RAIN EVENT DISCHARGE		WO # 1211546	Initiated 02/24/11 09:52 PM	Initiated By GRIFFITH	Assigned To GRIFFITH	Disch Status DOCUMENTED	Event Date 11/29/01	Problem LACK OF SYSTEM CAPACITY	Result UNAUTHORIZED DISCHARGE - WATERS	Completed 02/25/11 11:43 PM	Condition

Spot Inspections:

Discharge Amount:	1,509,071 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	CLEAN UP NOT POSSIBLE DUE TO MAGNITUDE OF STORM
Control Zone:	MSD PROPERTY, PIPE SUBMERGED
Impact:	NO IMPACT OBSERVED-PIPE SUBMERGED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE ISSDP

Notifications:

02/24/11 10:17 PM	DISPUB	PUBLIC NOTIFIED TO AVOID DISCHARGE THROUGH PERMANENT SIGNS
02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1215299	02/28/11 08:20 AM	GRIFFITH	GRIFFITH	DOCUMENTED	11/29/01	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 06:31 AM	

Spot Inspections:

Discharge Amount:	1,427,596 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	NONE NEEDED PIPE SUBMERGED
Control Zone:	NONE NEEDED MSD REMOTE LOCATION
Impact:	NONE OBSERVED-PIPE SUBMERGED
Repair:	SITE LOCATED IN ISSDP

Notifications:

02/28/11 12:47 PM	DISPUB	PUBLIC NOTIFIED THROUGH PERMANENT SIGNS TO AVOID DISCHARGE
02/28/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/28/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type SMH Sewer Manhole	Facility ID 90700	Facility Address 8021 CHRISTIAN CT	If Pump Station, Name of Pump Station:	Receiving Stream MIDDLE FORK BEARGRASS CREEK	Discharge to CATCH BASIN
------------------------------------	----------------------	---------------------------------------	--	--	-----------------------------

Activity Code / Description	WO #	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV: RAIN EVENT DISCHARGE	1211627	02/25/11 01:04 AM	CLARK	GRIFFITH	DOCUMENTED	03/19/08	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/25/11 10:25 AM	

Spot Inspections:

Discharge Amount:	7,950 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214056
Control Zone:	BARRICADES, CAUTION TAPE, AND TEMPORARY SIGNS PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	LOCATION INCLUDED IN ISSDP SUBMITTED ON 12-31-08

Notifications:

02/25/11 06:41 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMPORARY SIGNS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN		Receiving Stream of Treatment Center OHIO RIVER			Region WEST			
Facility Type	Facility ID	Facility Address		If Pump Station, Name of Pump Station:			Receiving Stream	Discharge to		
SSL Sewer Service Line	BU05074039	3305 BENT CREEK CT					SOUTH FORK BEARGRASS CREEK	GROUND		
<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1212215	02/24/11 10:05 PM	MITCHELL	GRIFFITH	DOCUMENTED	02/24/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 11:00 AM	

Spot Inspections:

Discharge Amount:	36,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214088
Control Zone:	CAUTION TAPE AND TEMPORARY SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED
Repair:	THIS IS AN SSL CLEANOUT IN A MH. WE ARE WORKING ON A SOLUTION

Notifications:

02/25/11 09:31 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN			Receiving Stream of Treatment Center OHIO RIVER			Region WEST		
Facility Type	Facility ID	Facility Address		If Pump Station, Name of Pump Station:			Receiving Stream	Discharge to		
SSL Sewer Service Line	BU05091039	3303 TROUT CREEK DR					SOUTH FORK BEARGRASS CREEK	GROUND		
<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1212206	02/24/11 10:00 PM	MITCHELL	GRIFFITH	DOCUMENTED	02/24/11	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/01/11 12:03 PM	

Spot Inspections:

Discharge Amount:	72,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 1214093
Control Zone:	CAUTION TAPE AND TEMPORARY SIGN PLACED AROUND DISCHARGE
Impact:	LIGHT IMPACT OBSERVED AROUND DISCHARGE
Repair:	THIS LOCATION IS AN SSL AND WE ARE WORKING ON A SOLUTION

Notifications:

02/25/11 09:25 AM	DISPUB	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID DISCHARGE
02/25/11 01:00 AM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/25/11 01:00 AM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV .

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	CSO020	147 BUCHANAN ST		OHIO RIVER	STREAM

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1200491	02/05/11 01:54 PM	ELDER	FLYNN	REPAIRED - ISSUE RESOLVED	02/05/11	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE - WATERS	02/05/11 03:00 PM	

Spot Inspections:

Discharge Amount:	2,345,000 GAL
Cause:	FAILURE OF INLINE AIR FILLED PIPE PLUG
Clean Up:	DISCHARGES DIRECTLY TO OHIO RIVER NO CLEANUP POSSIBLE
Control Zone:	DISCHARGES DIRECTLY TO OHIO RIVER NO CONTROL ZONE POSSIBLE
Impact:	DISCHARGES DIRECTLY TO OHIO RIVER NO VISION POSSIBLE
Repair:	CREW IS WORKING TO STOP THE OVERFLOW BY ATTEMPTING TO INSTALL A NEW PLUG

Notifications:

	DISPUB	notification by project WIN website. Supervisor informed crews on site
02/05/11 01:03 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/05/11 01:03 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES # KY0022411 (Cont'd)	Facility ID MSD0278	Water Quality Treatment Center MORRIS FORMAN	Receiving Stream of Treatment Center OHIO RIVER	Region WEST
-------------------------------	------------------------	---	--	----------------

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD0012-PS	3246 RADIANCE RD	HIGHGATE SPRINGS	SOUTH FORK BEARGRASS CREEK	STREAM

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1211567	02/24/11 10:08 PM	ELDER	WRIGHT	DOCUMENTED	12/16/00	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	02/26/11 08:35 PM	

Spot Inspections:

Discharge Amount:	718,650 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT IN AREA
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEANUP
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED.
Repair:	THIS LOCATION IS IN THE INTERIM SANITARY SEWER DISCHARGE PLAN.

Notifications:

02/24/11 11:57 PM	DISPUB	Permenant signs posted
02/24/11 01:00 PM	DISNOT	Email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov
02/24/11 01:00 PM	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov



IMSAST0004

Overflow Report

Initiated Feb 01, 2011 12:00 AM thru Feb 28, 2011 11:59 PM

Report Selections: Treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI, CSO, Result: WUS, Act Code: DISDW, DISREV

KPDES #
KY0022411 (Cont'd)Facility ID
MSD0278Water Quality Treatment Center
MORRIS FORMANReceiving Stream of Treatment Center
OHIO RIVERRegion
WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISREV: RAIN EVENT DISCHARGE	1217466	02/28/11 06:26 AM	SINGLETON	WRIGHT	DOCUMENTED	12/16/00	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	03/02/11 12:19 AM	

Spot Inspections:

Discharge Amount:	753,350 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED
Repair:	THIS LOCATION IS IN TEH INTERIM SANITARY SEWER DISCHARGE PLAN

Notifications:

02/28/11 06:26 AM	DISPUB	PERMANENT SIGNS POSTED
03/04/11 03:47 PM	DISNOT	Manual email notification of unauthorized discharge sent to ireland.sean@epa.gov, eppc.ert@ky.gov and LisaA.Jeffries@ky.gov

Total Facilities Printed: 40

Total Work Orders Printed: 59