



700 West Liberty Street  
Louisville Kentucky 40203-1911  
502-540-6000  
[www.msdlouky.org](http://www.msdlouky.org)

August 21, 2015

Cheryl Edwards  
Permit Support Section  
Surface Water Permits Branch  
Division of Water  
200 Fair Oaks Lane 4<sup>th</sup> Floor  
Frankfort, KY 40601

**Re: Morris Forman Water Quality Treatment Center  
KPDES Permit No. KY0022411**

Dear Ms. Edwards:

In accordance with the provisions of the KPDES Permit referenced above, the monthly Discharge Monitoring Report (DMR) and monthly Discharge (overflow) Reports for the reporting period July 1<sup>st</sup> to July 31<sup>st</sup> are provided through NetDMR.

There was one violation in the month of July, 2015 for a seven (7) day fecal coliform parameter. MFWQTC met all other permit requirements for the month.

Should you have any questions, please contact me at (502) 540-6793.

Sincerely,

A handwritten signature in cursive script that reads "Alex E. Novak".

Alex E. Novak, P.E.  
Treatment Facilities Director

vgt



*Beneficial Use of Louisville's Biosolids*  
[www.louisvillegreen.com](http://www.louisvillegreen.com)

DMR Copy of Record

<b>Permit</b>					
Permit #:	KY0022411	Permittee:	MORRIS FORMAN WQTC MSD	Facility:	MORRIS FORMAN WQTC MSD
Major:	Yes	Permittee Address:	4522 ALGONQUIN PKWY LOUISVILLE, KY 40211	Facility Location:	4522 ALGONQUIN PKWY LOUISVILLE, KY 40211
Permitted Feature:	001 External Outfall	Discharge:	001-1 MUNICIPAL DISCHARGE		

<b>Report Dates &amp; Status</b>					
Monitoring Period:	From 07/01/15 to 07/31/15	DMR Due Date:	08/28/15	Status:	NetDMR Validated

**Considerations for Form Completion**  
 G - INFLUENTE - SECONDARY EFFLUENT1 - FINAL EFFLUENT - Parameter 74055 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

<b>Principal Executive Officer</b>					
First Name:	Greg	Title:	Executive Director	Telephone:	502-540-6000
Last Name:	Heitzman				

**No Data Indicator (NODI)**  
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	3.4					19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.					>=	2 INST MIN					19 - mg/L		01/01 - Daily	GR - GRAB	
					Value NODI															
00310	BOD, 5-day, 20 deg. C	E - Secondary/Biological Process Complete	0	--	Sample	=	13196	=	12221	26 - lb/d		=	17	=	17	19 - mg/L	0	01/01 - Daily	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d		<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L		01/01 - Daily	CP - COMPOS	
					Value NODI															
00310	BOD, 5-day, 20 deg. C	G - Raw Sewage Influent	0	--	Sample	=	252624	=	304376	26 - lb/d		=	276	=	467	19 - mg/L	0	01/01 - Daily	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d			Req Mon MO AVG	Req Mon MX WK AV	19 - mg/L	01/01 - Daily		CP - COMPOS		
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.4				12 - SU	0	01/01 - Daily	GR - GRAB		
					Permit Req.					>=	6 MINIMUM			<=	9 MAXIMUM		12 - SU	01/01 - Daily	GR - GRAB	
					Value NODI															
00530	Solids, total suspended	E - Secondary/Biological Process Complete	0	--	Sample	=	14340	=	16140	26 - lb/d		=	19	=	25	19 - mg/L	0	01/01 - Daily	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d		<=	30 MO AVG	<=	45 MX WK AV	19 - mg/L		01/01 - Daily	CP - COMPOS	
					Value NODI															
00530	Solids, total suspended	G - Raw Sewage Influent	0	--	Sample	=	326309	=	346816	26 - lb/d		=	348	=	526	19 - mg/L	0	01/01 - Daily	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d			Req Mon MO AVG	Req Mon MX WK AV	19 - mg/L	01/01 - Daily		CP - COMPOS		
					Value NODI															
00610	Nitrogen, ammonia total [as N]	E - Secondary/Biological Process Complete	0	--	Sample	=	6108	=	7180	26 - lb/d		=	7.7	=	10.8	19 - mg/L	0	01/01 - Daily	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d		<=	20 MO AVG	<=	30 MX WK AV	19 - mg/L		01/01 - Daily	CP - COMPOS	
					Value NODI															
00610	Nitrogen, ammonia total [as N]	G - Raw Sewage Influent	0	--	Sample	=	6333	=	7120	26 - lb/d		=	7	=	11	19 - mg/L	0	01/01 - Daily	CP - COMPOS	
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	26 - lb/d			Req Mon MO AVG	Req Mon MX WK AV	19 - mg/L	01/01 - Daily		CP - COMPOS		
					Value NODI															
50050	Flow, in conduit or thru treatment plant	E - Secondary/Biological Process Complete	0	--	Sample	=	107.18	=	136.56	03 - MGD							0	99/99 - Continuous	CN - CONTIN	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD								99/99 - Continuous	CN - CONTIN	
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample									<	0.015	19 - mg/L	0	01/01 - Daily	GR - GRAB	
					Permit Req.										<=	.019 DAILY MX		19 - mg/L	01/01 - Daily	GR - GRAB
					Value NODI															
X 74055	Coliform, fecal general	1 - Effluent Gross	1	--	Sample							=	190	=	1307	13 - #/100mL	1	01/01 - Daily	GR - GRAB	
					Permit Req.							<=	200 30DA GEO	<=	400 7 DA GEO	13 - #/100mL		01/01 - Daily	GR - GRAB	
					Value NODI															
81010	BOD, 5-day, percent removal	K - Percent Removal	0	--	Sample					=	94				23 - %	0	01/30 - Monthly	CA - CALCTD		
					Permit Req.					>=	85 MO MIN				23 - %		01/30 - Monthly	CA - CALCTD		
					Value NODI															
81011	Solids, suspended percent removal	K - Percent Removal	0	--	Sample					=	96				23 - %	0	01/30 - Monthly	CA - CALCTD		
					Permit Req.					>=	85 MO MIN				23 - %		01/30 - Monthly	CA - CALCTD		
					Value NODI															

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

<b>Edit Check Errors</b>						
Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge

74055 Coliform, fecal general 1 - Effluent Gross Quality or Concentration Sample Value 3 Soft The provided sample value is outside the permit limit. (Error Code: 1) Yes

**Comments**

**Attachments**

Name	Type	Size
2015_7_MFWQTC_OverflowReport.pdf	pdf	311694
MFWTC072015DMR.XLS	xls	202240
MFWQTCoverletter.pdf	pdf	39930

**Report Last Saved By**

**MORRIS FORMAN WQTC MSD**

User: robin.burch@louisvillemsd.org Date/Time: 2015-08-20 06:11 (Time Zone: -04:00)  
Name: Robin Burch  
E-Mail: robin.burch@louisvillemsd.org

**DMR Copy of Record**

<b>Permit</b>			
Permit #:	KY0022411	Permittee:	MORRIS FORMAN WQTC MSD
Major:	Yes	Permittee Address:	4522 ALGONQUIN PKWY LOUISVILLE, KY 40211
Permitted Feature:	001 External Outfall	Discharge:	001-B SECONDARY BYPASS
Facility:		Facility:	MORRIS FORMAN WQTC MSD
		Facility Location:	4522 ALGONQUIN PKWY LOUISVILLE, KY 40211

<b>Report Dates &amp; Status</b>			
Monitoring Period:	From 07/01/15 to 07/31/15	DMR Due Date:	08/28/15
Status:	NetDMR Validated		

**Considerations for Form Completion**  
 MONITORING DURING PERIODS OF SECONDARY BYPASS IN ADDITION TO REGULAR MONITORING.1 - FINAL EFFLUENTF - SECONDARY BYPASS AFTER PRIMARYTREATMENT.

<b>Principal Executive Officer</b>			
First Name:	Greg	Title:	Executive Director
Last Name:	Heitzman	Telephone:	502-540-6000

**No Data Indicator (NODI)**  
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00310	BOD, 5-day, 20 deg. C	1 - Effluent Gross	0	--	Sample						=	26		=	33	19 - mg/L	20/30 - Twenty Per Month WH/DS - When Discharging	CP - COMPOS CP - COMPOS	
					Permit Req.											Req Mon MO AVG			Req Mon MX WK AV
					Value NODI														
00310	BOD, 5-day, 20 deg. C	F - Primary/Preliminary Process Complete	0	--	Sample						=	124		=	276	19 - mg/L	20/30 - Twenty Per Month WH/DS - When Discharging	CP - COMPOS CP - COMPOS	
					Permit Req.											Req Mon MO AVG			Req Mon MX WK AV
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample						=	30		=	54	19 - mg/L	20/30 - Twenty Per Month WH/DS - When Discharging	CP - COMPOS CP - COMPOS	
					Permit Req.											Req Mon MO AVG			Req Mon MX WK AV
					Value NODI														
00530	Solids, total suspended	F - Primary/Preliminary Process Complete	0	--	Sample						=	119		=	404	19 - mg/L	20/30 - Twenty Per Month WH/DS - When Discharging	CP - COMPOS CP - COMPOS	
					Permit Req.											Req Mon MO AVG			Req Mon MX WK AV
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample						=	6.4		=	13	19 - mg/L	20/30 - Twenty Per Month WH/DS - When Discharging	CP - COMPOS CP - COMPOS	
					Permit Req.											Req Mon MO AVG			Req Mon MX WK AV
					Value NODI														
00610	Nitrogen, ammonia total [as N]	F - Primary/Preliminary Process Complete	0	--	Sample						=	8		=	18.9	19 - mg/L	20/30 - Twenty Per Month WH/DS - When Discharging	CP - COMPOS CP - COMPOS	
					Permit Req.											Req Mon MO AVG			Req Mon MX WK AV
					Value NODI														
50050	Flow, in conduit or thru treatment plant	F - Primary/Preliminary Process Complete	0	--	Sample	=	37.72	=	51.45	03 - MGD						20/30 - Twenty Per Month WH/DS - When Discharging	CN - CONTIN CN - CONTIN		
					Permit Req.		Req Mon MO AVG		Req Mon MX WK AV	03 - MGD									
					Value NODI														

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
 No errors.

**Comments**

**Attachments**  
 No attachments.

**Report Last Saved By**  
**MORRIS FORMAN WQTC MSD**

User:	robin.burch@louisvillemsd.org	Date/Time:	2015-08-20 06:08 (Time Zone: -04:00)
Name:	Robin Burch		
E-Mail:	robin.burch@louisvillemsd.org		

Press (Ctrl r) to recalculate spreadsheet.

MORRIS FORMAN WATER QUALITY TREATMENT CENTER JEFFERSON COUNTY, KENTUCKY MONTH OF July 2015  
 KPDE8 PERMIT NO. KY0022411 PLANT CAPACITY - 120 MGD RECEIVING STREAM- OHIO RIVER

DATE	WASTEWATER FLOWS (Million Gallons)			TEMP (DEGF)		pH		SETS (ML)		TSS (mg/L)		D.O. (mg/L)	5-DAY BOD (mg/L)			RETURN SLUDGE			AERATION BASIN				ACTIVE		CHLORINATION			FINAL EFFLUENT			
	Final	Sec.	Bypass	raw	final	raw	final	raw	final	raw	final	final	raw	prim.	final	final	FLOW	TSS	TVSS	D.O.	MLSS	MLVSS	SET	SVI	Sludge Wasted	Primary Sludge	Chlorine Dosage	Resid	Fecal Coliform	NH3-N	Pump.
	Effluent	Effluent																													
7/1	99.40	91.36	8.04	7.7	7.7	7.1	6.7	10.0	0.1	292	11	7.2	306	153	12	22.9	7.8	6.2	16.6	2.0	1.6	146	74	0.60	0.40	2.01	0.015	115	10	24.0	
7/2	208.12	131.53	76.59	7.8	7.8	7.0	6.7	6.8	0.5	212	40	5.6	158	106	31	23.1	11.4	8.8	14.7	2.3	1.8	140	65	0.64	0.45	4.49	0.015	920	8	24.0	
7/3	195.96	129.81	66.15	7.5	7.5	7.2	6.6	4.2	0.4	160	33	6.8	113	60	19	23.4	10.6	8.2	14.5	1.8	1.5	141	81	0.73	0.33	4.38	0.015	1850	6	24.0	
7/4	138.47	124.29	14.18	7.7	7.7	7.2	6.9	6.2	0.1	166	10	9.5	106	61	7	22.1	11.2	8.1	15.2	1.9	1.5	110	56	0.74	0.24	4.16	0.015	1400	6	24.0	
7/5	96.72	96.72	0.00	7.7	7.7	7.4	6.9	7.0	0.1	188	10	8.6	146	57	7	20.2	8.4	6.6	15.3	2.2	1.8	112	67	0.72	0.25	2.39	0.015	660	6	24.0	
7/6	96.22	96.22	0.00	7.4	7.4	7.2	6.9	11.0	0.1	284	10	9.9	219	87	9	15.9	7.3	5.4	17.5	1.8	1.4	107	57	0.79	0.31	2.03	0.015	39	11	24.0	
7/7	160.48	109.79	50.69	7.5	7.5	7.2	6.7	8.0	0.1	228	22	8.0	175	90	20	12.7	8.3	6.2	25.8	1.8	1.3	113	64	0.81	0.37	4.60	0.015	40	10	24.0	
7/8	156.28	127.50	28.78	7.7	7.7	7.3	6.7	8.0	0.1	232	21	7.8	173	84	18	12.6	7.8	6.1	17.2	1.4	1.0	96	69	0.59	0.37	4.20	0.015	350	6	16.4	
7/9	168.54	126.38	42.16	7.7	7.7	7.2	6.7	10.0	0.1	236	22	8.1	186	94	18	13.0	9.6	7.2	15.2	1.5	1.2	101	64	0.51	0.28	3.92	0.015	48400	6	13.7	
7/10	177.50	123.07	54.43	7.7	7.7	7.2	6.7	8.0	0.2	252	31	7.7	213	140	34	13.5	11.3	8.5	14.7	2.5	1.8	118	50	0.51	0.23	4.53	0.015	208	7	24.0	
7/11	151.77	125.03	26.74	7.8	7.8	7.4	6.8	8.0	0.1	280	11	6.3	198	105	14	13.4	11.7	8.8	15.9	1.9	1.3	109	61	0.63	0.32	4.93	0.015	400	6	24.0	
7/12	177.17	128.88	48.29	7.6	7.6	7.0	7.0	6.0	0.1	216	22	6.7	111	70	18	13.7	10.1	7.7	16.4	2.0	1.5	115	57	0.77	0.33	5.23	0.015	255	5	24.0	
7/13	204.37	133.88	70.71	7.6	7.6	7.2	6.8	7.0	0.3	248	28	8.7	126	62	27	17.8	11.5	8.9	17.4	2.0	1.5	129	65	0.63	0.33	4.76	0.015	1020	4	24.0	
7/14	220.86	131.84	89.02	7.7	7.7	7.2	6.7	5.5	0.2	176	30	8.0	110	66	27	24.0	10.6	7.8	16.8	1.5	1.2	99	64	0.65	0.26	5.40	0.015	17800	3	24.0	
7/15	182.42	135.04	47.38	7.7	7.7	7.3	6.8	7.5	0.1	280	18	6.5	205	106	34	26.5	8.1	6.0	15.1	2.0	1.5	125	64	0.69	0.40	5.76	0.015	870	4	24.0	
7/16	140.90	134.62	6.28	7.6	7.6	7.2	6.7	11.0	0.1	276	14	7.4	260	135	16	25.9	11.5	8.7	14.4	2.3	1.8	148	66	0.75	0.30	4.75	0.015	229	4	24.0	
7/17	122.38	122.32	0.04	7.6	7.6	7.1	6.6	15.0	0.1	368	12	7.6	311	154	10	25.5	11.0	8.7	13.0	2.0	1.7	131	65	0.88	0.20	3.77	0.015	102	4	24.0	
7/18	224.50	136.56	87.94	7.8	7.8	7.1	6.4	7.5	0.4	156	30	6.1	88	94	25	25.4	10.4	8.5	14.8	3.0	2.5	139	54	0.92	0.20	6.36	0.015	225	3	24.0	
7/19	158.56	134.39	24.17	7.7	7.7	7.2	6.6	7.5	0.2	188	16	6.6	138	100	17	25.3	10.6	8.2	14.8	2.3	1.8	150	65	0.90	0.19	3.83	0.015	83	3	24.0	
7/20	121.58	121.58	0.00	7.6	7.6	7.1	6.7	13.0	0.1	372	7	8.3	357	141	7	24.9	12.5	9.7	14.7	2.1	1.7	147	70	0.94	0.24	2.75	0.015	58	6	24.0	
7/21	112.59	108.65	3.94	7.8	7.8	7.1	6.5	13.0	0.1	392	14	6.6	318	175	18	24.7	12.0	9.4	15.2	2.8	2.2	178	64	0.91	0.35	2.15	0.015	55	7	24.0	
7/22	89.29	89.29	0.00	7.7	7.7	7.1	6.6	13.5	0.1	464	9	6.7	477	209	9	24.8	12.6	10.1	14.3	3.0	2.4	173	58	0.89	0.31	1.92	0.015	15	8	14.0	
7/23	82.75	82.75	0.00	7.8	7.8	7.2	6.6	26.0	0.1	516	10	5.8	488	326	16	25.2	13.1	10.6	12.6	2.7	2.3	178	67	0.91	0.35	1.92	0.015	32	8	4.2	
7/24	78.32	78.32	0.00	8.1	8.1	7.3	6.6	12.5	0.1	424	11	5.4	384	240	10	25.4	11.3	9.2	13.0	3.9	3.1	261	68	0.97	0.29	2.83	0.015	15	10	0.0	
7/25	72.03	72.03	0.00	7.9	7.9	7.0	6.8	17.0	0.1	536	12	5.5	613	312	16	25.5	12.9	10.7	13.0	3.9	3.2	244	63	1.00	0.13	2.34	0.015	2	10	0.0	
7/26	70.29	70.29	0.00	8.1	8.1	7.0	6.5	16.0	0.1	485	14	4.9	406	291	12	26.0	15.1	12.3	12.4	3.9	3.2	233	61	1.07	0.09	1.75	0.015	20	10	0.0	
7/27	79.66	78.75	0.91	8.0	8.0	7.1	6.6	22.0	0.4	592	54	4.8	418	276	33	26.6	17.0	13.6	12.2	4.5	3.5	294	66	1.19	0.29	2.02	0.015	46	13	0.0	
7/28	74.92	74.92	0.00	8.1	8.1	6.9	6.6	22.0	0.4	665	48	4.1	486	220	23	26.5	17.9	14.0	12.3	5.1	4.1	323	61	1.25	0.33	1.99	0.015	124	14	0.0	
7/29	85.57	77.74	7.83	8.1	8.1	7.0	6.4	21.2	3.5	660	158	5.4	453	339	113	26.4	19.9	15.8	12.3	3.5	2.8	272	58	1.24	0.39	3.40	0.015	16	15	0.0	
7/30	65.74	65.74	0.00	8.0	8.0	6.8	6.5	15.0	0.3	500	66	9.1	363	221	84	22.7	19.9	15.8	11.7	3.5	2.8	207	58	0.39	0.19	1.76	0.015	2700	15	0.0	
7/31	63.43	63.43	0.00	8.0	8.0	7.0	6.6	32.0	0.1	735	107	3.4	451	303	139	21.5	17.9	14.1	5.1	4.7	3.8	356	76	1.20	0.28	4.71	0.015	280	18	0.0	
Total	4078.8	3322.5	754.3													877.0															504.1
Average	131.5	107.2	24.3	77.6	77.6	7.1	6.7	12.2	0.3	348	29	6.9	276	157	27	21.8	12.0	9.4	14.6	2.6	2.1	168	64	0.82	0.29	3.58	0.015	190	8		

SEWER CONNECTIONS 146598 TIMES 4 = 586392 SEWER POPULATION

IND. WASTER POPULATION EQ  
 CUSTOMERS 357  
 FLOW 866072  
 BOD 1194267  
 TSS 1229617

Authorized Agent



Certification No. 5691

MORRIS FORMAN WASTEWATER TREATMENT PLANT

JEFFERSON COUNTY, KY

Month of Jul-15

Average Flow

SETTLING TANKS	Primary	Secondary		
		Battery A	Battery B	Battery C
Average Flow (MGD)	4076.77	33.21	31.59	15.02
Tanks in Service	4.00	7.0	5.7	4.0
Surface Area (Ft.2)	77000.00	60391.25	49264.64	34230.12
Volume (MG)	8.33	6.19	5.05	3.51
Weir Length (Ft.)	2860.00	2502.92	2041.78	1418.67
Avg. Weir Overflow (GPD/Ft)	1425444.06	13267.93	15472.54	10587.70
Avg. Settling Rate (GPD/FT2)	52945.06	717.71	792.65	568.97
Avg. Detention Time	0.05	4.47	3.83	5.60

AERATION TANKS

	Battery A	Battery B	Battery C
Volume (Gallons)	4200000	4200000	2100000
Avg. Flow (MGD)	43.34	39.05	19.48
Avg. Detention Time (Hours)	3.04	3.19	3.36

CHLORINE CONTACT CHAMBERS

Contact Chambers in Use	2.0
Volume (Gallons)	2340000
Avg. Detention Time (Hours)	0.85

Remarks: BY-PASS REPORTS (See Attached)



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	00746	804 N ARBOR DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387533		07/12/2015	MARKS JR	OPS CSHIFT	DOCUMENTED	12/16/2000	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 02:00 AM	

**Discharge Reporting:**

Discharge Amount:	11,550 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	SEE WO#2389001
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AT THIS LOCATION

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2389001		7/14/2015 8:56:00AM	OPS BSHIFT CENTRAL	SINGLETON	DOCUMENTED	12/16/2000	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/15/15 03:45 AM	

**Discharge Reporting:**

Discharge Amount:	89,175 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION CA BE FOUND IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	00817	806 PINE WAY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2388619		07/13/2015	MARKS JR	OPS CSHIFT	DOCUMENTED	12/05/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 06:20 PM	

**Discharge Reporting:**

Discharge Amount:	525 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	SEE WO#2388993
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

**Notifications:**

7/13/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/13/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	01793	9 MUIRFIELD PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387527		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/03/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 08:21 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388642
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	02933	7900 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387502		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:13 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388634
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	02935	7900 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387499		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:09 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388633
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08426	4315 PRUITT CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387549		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/25/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 12:48 PM	

**Discharge Reporting:**

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387631
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08427	4313 PRUITT CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387546		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/25/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 12:47 PM	

**Discharge Reporting:**

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387607
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08431	4339 PRUITT CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387550		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/25/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 12:54 PM	

**Discharge Reporting:**

Discharge Amount:	300 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387634
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08717	3726 FINCASTLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387050		07/10/2015	MITCHELL	GRIFFITH	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/10/15 01:55 PM	

**Discharge Reporting:**

Discharge Amount:	1,200 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387117
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/10/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2387556		7/12/2015 7:24:00AM	GRIFFITH	MITCHELL	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/12/15 11:27 AM	

**Discharge Reporting:**

Discharge Amount:	12,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387637
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2389029		7/14/2015 5:51:00AM	GRIFFITH	MITCHELL	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 04:59 PM	

**Discharge Reporting:**

Discharge Amount:	300 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389801
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRain EVENT DISCHARGE	2391502		7/18/2015 1:36:00AM	GRIFFITH	MITCHELL	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/18/15 08:31 AM	

**Discharge Reporting:**

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391503
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08935-SM	1001 BRECKENRIDGE LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387441		07/12/2015	GRIFFITH	GRIFFITH	DOCUMENTED	11/29/2001	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/12/15 05:42 PM	

**Discharge Reporting:**

Discharge Amount:	2,379,438 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	104223	4103 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387571		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	05/20/2005	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 11:11 AM	

**Discharge Reporting:**

Discharge Amount:	1,100 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	WO# 2387691
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2389035		7/14/2015 5:37:00AM	GRIFFITH	MITCHELL	DOCUMENTED	05/20/2005	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 04:49 PM	

**Discharge Reporting:**

Discharge Amount:	300 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389803
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	104224	4103 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2389100		07/14/2015	LOGAN JR	GRIFFITH	DOCUMENTED	07/14/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 04:48 PM	

**Discharge Reporting:**

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389799
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	105936	7713 WESTPORT RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387578		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 05:02 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388664
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	115183	208 BRUNSWICK RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387538		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:28 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388647
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	115184	208 BRUNSWICK RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387540		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 04:36 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388649
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	115185	207 BRUNSWICK RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387541		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 04:36 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388650
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	13946	1600 BELMAR DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387569		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	10/30/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 11:22 AM	

**Discharge Reporting:**

Discharge Amount:	2,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387802
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRain EVENT DISCHARGE	2389061		7/14/2015 5:42:00AM	GRIFFITH	MITCHELL	DOCUMENTED	10/30/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 08:41 AM	

**Discharge Reporting:**

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389063
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	15195	1700 SULGRAVE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387575		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	07/12/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 07:10 AM	

**Discharge Reporting:**

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388662
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	16455	1913 CHARBDIN PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387589		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/03/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 04:34 PM	

**Discharge Reporting:**

Discharge Amount:	30,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387711
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	16649	1726 FRASER DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387910		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	01/24/2002	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 12:15 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387913
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/13/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
-----------------	--------	---



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	21089A	207 BRUNSWICK RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387539		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/27/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 04:36 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388648
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	21171	4609 BLENHEIM RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387544		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/27/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 04:32 PM	

**Discharge Reporting:**

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388657
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	23211	3302 TROUT CREEK DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387559		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/22/2000	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 09:23 PM	

**Discharge Reporting:**

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388660
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	24448	4002 BROOKFIELD AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387585		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/23/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 05:50 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387707
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	25017	308 STONEHENGE DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387543		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/27/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 04:31 PM	

**Discharge Reporting:**

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388656
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	26752	3317 BROWNSBORO RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387584		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	04/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 11:02 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388669
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27007	1013 ALTA CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387484		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	02/05/2014	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 07:39 AM	

**Discharge Reporting:**

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388175
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	30376	8113 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387534		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	11/29/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 04:20 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388645
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	40471	1552 CHEROKEE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387595		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	07/18/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 07:45 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388672
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2391495		7/18/2015 2:40:00AM	GRIFFITH	FIELDS	DOCUMENTED	07/18/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/19/15 11:18 AM	

**Discharge Reporting:**

Discharge Amount:	21,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391582
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	40870	2120 INDIAN HILLS TRL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387548		07/12/2015	MARKS JR	OPS CSHIFT	DOCUMENTED	09/27/2002	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 12:00 AM	

**Discharge Reporting:**

Discharge Amount:	30,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	NO IMPACT OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	41374	300 MOCKINGBIRD VALLEY RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387582		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/27/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 05:35 PM	

**Discharge Reporting:**

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388666
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	41416	3343 BROWNSBORO RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387583		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	05/03/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 11:09 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388667
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	42680	4640 BARBOUR LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2389120		07/14/2015	SINGLETON	OPS BSHIFT EAST	DOCUMENTED	03/19/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 12:57 AM	

**Discharge Reporting:**

Discharge Amount:	143,500 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGN
Impact:	SEWAGE & DEBRIS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE LOCATION

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	43726	1108 DUPONT CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387586		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/23/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 06:06 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388670
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45796	1011 ALTA CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387488		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	05/10/2014	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 07:39 AM	

**Discharge Reporting:**

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388624
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

<b>KPDES #</b>	<b>Facility ID</b>	<b>Water Quality Treatment Center</b>	<b>Receiving Stream of Treatment Center</b>	<b>Region</b>
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2391490		7/18/2015 2:33:00AM	GRIFFITH	FIELDS	DOCUMENTED	05/10/2014	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/19/15 11:05 AM	

**Discharge Reporting:**

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391578
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45835	1132 ROSTREVOR CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387494		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	09/02/2003	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 07:28 AM	

**Discharge Reporting:**

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388628
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2391491		7/18/2015 2:26:00AM	GRIFFITH	FIELDS	DOCUMENTED	09/02/2003	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/19/15 10:35 AM	

**Discharge Reporting:**

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391579
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45900	1122 ROSTREVOR CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387597		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/27/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 03:14 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388674
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	46623	4801 CASSIA CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387590		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	04/03/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/16/15 09:30 AM	

**Discharge Reporting:**

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2390679
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	46627	1910 CHARBDIN PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387593		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/03/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:00 AM	

**Discharge Reporting:**

Discharge Amount:	4,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391322
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47034	232 STONEHENGE DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387542		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	11/22/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 04:28 PM	

**Discharge Reporting:**

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388650
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47582	201 BULLITT LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387496		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 07:49 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388631
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2391493		7/18/2015 3:23:00AM	GRIFFITH	FIELDS	DOCUMENTED	12/05/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/19/15 11:40 AM	

**Discharge Reporting:**

Discharge Amount:	19,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391581
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47583	202 OXMOOR LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387495		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	02/06/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:03 AM	

**Discharge Reporting:**

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391310
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRain EVENT DISCHARGE	2391492		7/18/2015 3:23:00AM	GRIFFITH	FIELDS	DOCUMENTED	02/06/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/19/15 01:00 PM	

**Discharge Reporting:**

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391580
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47593	8021 CHRISTIAN CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387519		07/13/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:18 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388638
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47603	8016 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387522		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 04:13 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388640
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47604	8016 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387524		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 08:09 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388641
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	49445	2216 FAIRLAND AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387565		07/12/2015	MITCHELL	GRIFFITH	BEYOND APPROVED DESIGN STORM	10/06/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 06:02 PM	

**Discharge Reporting:**

Discharge Amount:	15,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387662
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2389037		7/14/2015 7:07:00AM	GRIFFITH	MITCHELL	BEYOND APPROVED DESIGN STORM	10/06/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 09:12 PM	

**Discharge Reporting:**

Discharge Amount:	400 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389804
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	49446	2219 RICHLAND AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387566		07/12/2015	MITCHELL	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/03/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 06:03 PM	

**Discharge Reporting:**

Discharge Amount:	6,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387667
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2389041		7/14/2015 7:08:00AM	GRIFFITH	MITCHELL	BEYOND APPROVED DESIGN STORM	04/03/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 09:13 PM	

**Discharge Reporting:**

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389805
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	51160	3305 INDIAN CREEK CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387557		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	04/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 01:27 PM	

**Discharge Reporting:**

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387948
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	51594	1418 TREVILIAN WAY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387043		07/10/2015	MITCHELL	GRIFFITH	DOCUMENTED	09/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/10/15 01:40 PM	

**Discharge Reporting:**

Discharge Amount:	1,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387116
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/10/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2387560		7/12/2015 7:30:00AM	GRIFFITH	MITCHELL	DOCUMENTED	09/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/12/15 11:35 AM	

**Discharge Reporting:**

Discharge Amount:	14,400 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387656
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2389101		7/14/2015 5:48:00AM	GRIFFITH	MITCHELL	DOCUMENTED	09/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 09:07 AM	

**Discharge Reporting:**

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389102
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRain EVENT DISCHARGE	2391504		7/18/2015 1:45:00AM	GRIFFITH	MITCHELL	DOCUMENTED	09/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/18/15 08:45 AM	

**Discharge Reporting:**

Discharge Amount:	4,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391505
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	63357	332 STONEHENGE DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387577		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/27/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 04:32 PM	

**Discharge Reporting:**

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388663
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65606	1910 CHARBDIN PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387579		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	10/06/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:03 AM	

**Discharge Reporting:**

Discharge Amount:	5,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391316
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65610	1802 ROUND RIDGE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387594		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/03/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:00 AM	

**Discharge Reporting:**

Discharge Amount:	6,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391329
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65623	1804 ROUND RIDGE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387580		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	06/23/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/16/15 09:30 AM	

**Discharge Reporting:**

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2390677
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65633	4640 BARBOUR LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2389121		07/14/2015	SINGLETON	OPS BSHIFT EAST	DOCUMENTED	04/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 12:57 AM	

**Discharge Reporting:**

Discharge Amount:	95,700 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE & DEBRIS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65635	4640 BARBOUR LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2389119		07/14/2015	SINGLETON	OPS BSHIFT EAST	DOCUMENTED	04/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 12:57 AM	

**Discharge Reporting:**

Discharge Amount:	95,700 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE & DEBRIS OBSERVE
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE LOCATION

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	66349	3726 FINCASTLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387555		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/12/15 11:28 AM	

**Discharge Reporting:**

Discharge Amount:	2,400 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387635
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2389025		7/14/2015 5:50:00AM	GRIFFITH	MITCHELL	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 04:58 PM	

**Discharge Reporting:**

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389800
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRain EVENT DISCHARGE	2391498		7/18/2015 1:35:00AM	GRIFFITH	FIELDS	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/18/15 08:30 AM	

**Discharge Reporting:**

Discharge Amount:	3,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391500
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	67535	9 MUIRFIELD PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387531		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	03/26/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 08:21 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388643
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	72289	1700 SULGRAVE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387477		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	05/29/2012	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 07:10 AM	

**Discharge Reporting:**

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388161
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2391487		7/18/2015 2:40:00AM	GRIFFITH	FIELDS	DOCUMENTED	05/29/2012	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/19/15 11:12 AM	

**Discharge Reporting:**

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391574
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/15/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/15/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	74513	1106 BROADFIELDS DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387588		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/03/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 05:50 PM	

**Discharge Reporting:**

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388671
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	84155	7913 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387537		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/10/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:23 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388646
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	90700	8021 CHRISTIAN CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387504		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 06:15 AM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388636
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	96673	3920 DUTCHMANS LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387599		07/12/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/27/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 06:12 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388675
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	BU05074039	3305 BENT CREEK CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387562		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/24/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 09:25 PM	

**Discharge Reporting:**

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388661
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	BU05091039	3303 TROUT CREEK DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387568		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/24/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/12/15 04:09 PM	

**Discharge Reporting:**

Discharge Amount:	9,900 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387686
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	KK14815019	4108 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387567		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	07/29/2009	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/12/15 11:12 AM	

**Discharge Reporting:**

Discharge Amount:	100 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387673
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRain EVENT DISCHARGE	2389053		7/14/2015 5:41:00AM	GRIFFITH	MITCHELL	DOCUMENTED	07/29/2009	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 08:43 AM	

**Discharge Reporting:**

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389056
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	KK14855239	4107 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387570		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	05/15/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/12/15 11:15 AM	

**Discharge Reporting:**

Discharge Amount:	1,100 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387681
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRain EVENT DISCHARGE	2389065		7/14/2015 5:39:00AM	GRIFFITH	MITCHELL	DOCUMENTED	05/15/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/14/15 08:40 AM	

**Discharge Reporting:**

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389081
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRain EVENT DISCHARGE	2391506		7/18/2015 1:39:00AM	GRIFFITH	MITCHELL	DOCUMENTED	05/15/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	07/18/15 08:35 AM	

**Discharge Reporting:**

Discharge Amount:	1,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391507
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD0040-PS	7404 ARROWWOOD RD	DEVONDALE	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2388693		07/13/2015	SINGLETON	OPS BSHIFT EAST	DOCUMENTED	01/26/2012	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/15/15 08:05 AM	

**Discharge Reporting:**

Discharge Amount:	157,875 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS PLACED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD0057-LS	806 PINE WAY	ANCHOR ESTATES #2	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387530		07/12/2015	MARKS JR	OPS CSHIFT	DOCUMENTED	12/16/2000	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 02:05 AM	

**Discharge Reporting:**

Discharge Amount:	4,850 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	SEE WORK ORDER #2388619
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AT THIS LOCATION

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD0186-PS	2120 INDIAN HILLS TRL	MUDDY FORK	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2387520		07/12/2015	MARKS JR	OPS BSHIFT EAST	DOCUMENTED	01/27/2012	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/13/15 12:00 AM	

**Discharge Reporting:**

Discharge Amount:	300,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	NO IMPACT OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

**Notifications:**

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 07/01/2015 00:00 thru 07/31/2015 23:59, treatment Plant: MSD0278 MORRIS FORMAN, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	Z18284029	3928 DUTCHMANS LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2389125		07/14/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	07/14/15 06:07 PM	

**Discharge Reporting:**

Discharge Amount:	200 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389798
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

**Notifications:**

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 70

Total Work Orders Printed: 92