



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

July 15, 2014

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Berrytown WQTC; KPDES No.: KY0036501
Discharge Monitoring Reports – June 2014**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the Berrytown WQTC, KPDES No.: KY0036501 for the month of June 2014.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMRs, please contact me at (502) 239-7574.

Sincerely,

A handwritten signature in cursive script that reads "Duane V. Wright".

Duane V. Wright
Process Supervisor Central Region

DVW/Berrytown 06.14

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit

Permit #:
Major:

KY0036501
No

Permittee:
Permittee Address:

BERRYTOWN WQTC MSD
1203 HEAFER RD
LOUISVILLE, KY 40222

Facility:
Facility Location:

BERRYTOWN WQTC MSD
1203 HEAFER RD
LOUISVILLE, KY 40222

Permitted Feature:

001
External Outfall

Discharge:

001-1
SANITARY WASTEWATER

Report Dates & Status

Monitoring Period:

From 06/01/14 to 06/30/14

DMR Due Date:

07/28/14

Status:

NetDMR Validated

Considerations for Form Completion

TOTAL NITROGEN IS THE SUMMATION OF THE ANALYTICAL RESULTS FOR TOTAL NITRATES, TOTAL NITRITES, AND TOTAL KJELDAHL NITROGEN

Principal Executive Officer

First Name:
Last Name:

Greg
Heitzman

Title:

Exec. Dir.

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Parameter		Monitoring Location	Season #	Param. NODI		Quantity or Loading					Quality or Concentration							# of Ex.	Frequency of Analysis	Sample Type
Code	Name					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample						=	8					19 - mg/L		01/01 - Daily	GR - GRAB
					Permit Req.						>=	7 INST MIN					19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample						=	6			=	7	12 - SU		01/01 - Daily	GR - GRAB
					Permit Req.						>=	6 MINIMUM			<=	9 MAXIMUM	12 - SU	0	01/07 - Weekly	GR - GRAB
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	2.3	=	4.1	26 - lb/d			=	3	=	4	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	18.8 MO AVG	<=	28.2 WKLY AVG	26 - lb/d			<=	30 MO AVG	<=	45 WKLY AVG	19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI															
00600	Nitrogen, total	1 - Effluent Gross	0	--	Sample								=	18	=	23	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Permit Req.									Req Mon MO AVG		Req Mon WKLY AVG	19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	1	--	Sample	=	0.4	=	0.8	26 - lb/d			=	0.5	=	0.6	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	2.5 MO AVG	<=	3.8 WKLY AVG	26 - lb/d			<=	4 MO AVG	<=	6 WKLY AVG	19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI															
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample								=	2.2	=	3.2	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Permit Req.									Req Mon MO AVG		Req Mon WKLY AVG	19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.084	=	0.11	03 - MGD									99/99 - Continuous	CN - CONTIN
					Permit Req.		Req Mon MO AVG		Req Mon WKLY AVG	03 - MGD								0	99/99 - Continuous	IN - INSTAN
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								<	0.01	<	0.01	19 - mg/L		01/01 - Daily	GR - GRAB
					Permit Req.								<=	.011 MO AVG	<=	.019 WKLY AVG	19 - mg/L	0	01/07 - Weekly	GR - GRAB
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample								=	2	=	6	13 - #/100mL		01/07 - Weekly	GR - GRAB
					Permit Req.								<=	130 30DA GEO	<=	240 7 DA GEO	13 - #/100mL	0	01/07 - Weekly	GR - GRAB
					Value NODI															
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	5.3	=	6.8	26 - lb/d			=	7	=	9	19 - mg/L		01/07 - Weekly	CP - COMPOS
					Permit Req.	<=	15.7 MO AVG	<=	23.5 WKLY AVG	26 - lb/d			<=	25 MO AVG	<=	37.5 WKLY AVG	19 - mg/L	0	01/07 - Weekly	24 - COMP24
					Value NODI															

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
Berrytown062014_COVER.pdf	pdf	17333
Berrytown062014_MOR.pdf	pdf	25166

Report Last Saved By


BERRYTOWN WQTC MSD

User:

kevin.ries@louisvillemsd.org

Date/Time:

2014-07-24 09:56 (Time Zone: -04:00)



Berrytown	Report for	Jun-14				Tot. Exc.=		0						
Tot. Flow=	2.51172	Concentrations						Pounds						
Date	Flow	TSS	BOD	NH3	Ecoli	TSS	BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC	Tot. N	
6/1/14	0.164	3	5	0.56		4.098	6.829	0.765	0.908	8.6	6.7	0.01	10.77	
6/2/14	0.128				1					8.4	6.7	0.01		
6/3/14	0.108									8.8	6.9	0.01		
6/4/14	0.107									9	6.9	0.01		
6/5/14	0.098									8.6	6.7	0.01		
6/6/14	0.086									8.9	6.8	0.01		
6/7/14	0.081									8.7	6.9	0.01		
6/8/14	0.082	2	7	0.34		1.366	4.780	0.232	2.18	8.9	6.8	0.01	18.01	
6/9/14	0.079				1					9.1	6.9	0.01		
6/10/14	0.081									8.9	6.8	0.01		
6/11/14	0.093									8.8	6.7	0.01		
6/12/14	0.094									9.1	6.7	0.01		
6/13/14	0.081									9.4	6.8	0.01		
6/14/14	0.078									9.6	6.6	0.01		
6/15/14	0.076	4	6	0.56		2.536	3.804	0.355	2.37	9.2	6.7	0.01	20.61	
6/16/14	0.071				1					9.5	6.7	0.01		
6/17/14	0.067									9.1	6.6	0.01		
6/18/14	0.068									8.8	6.6	0.01		
6/19/14	0.067									8.3	6.6	0.01		
6/20/14	0.071									8.5	6.3	0.01		
6/21/14	0.076									7.9	7.3	0.01		
6/22/14	0.074	2	9	0.34		1.242	5.590	0.211	3.18	8.2	6.6	0.01	22.81	
6/23/14	0.069				6					8.6	6.7	0.01		
6/24/14	0.075									8.4	6.5	0.01		
6/25/14	0.083									8.8	6.6	0.01		
6/26/14	0.073									8.6	6.7	0.01		
6/27/14	0.073									8.4	6.6	0.01		
6/28/14	0.067									8.4	6.6	0.01		
6/29/14	0.073									8.7	6.7	0.01		
6/30/14	0.069									8.4	6.5	0.01		
7/1/14														
Average	0.084	3	7	0.5	1.57	2	5.251	0.39	2.2	8.75	7	0.01	18.05	
Maximum	0.164	4	9	0.6	6.00	4	6.829	0.8	3.2	9.60	7	0.01	22.81	
Exceed.	18	0	0	0	0	0	0	0						