



*Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org*

April 10, 2013

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Chenoweth Hills WQTC; KPDES No.: KY0029459
Discharge Monitoring Reports – March 2013**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Chenoweth Hills WQTC, KPDES No.: KY0029459 for the month of March 2013.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMRs, please contact me at (502) 239-7574.

Sincerely,

A handwritten signature in cursive script that reads "Duane V. Wright".

Duane V. Wright
Process Supervisor Central Region

DVW/Chenoweth Hills 3.13

Enclosures

cc: R. Shaw
T. Singleton



*Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com*

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CEDAR CREEK WQTC
ADDRESS: 8405 CEDAR CREEK RD
LOUISVILLE, KY 40211
FACILITY: CHENOWETH HILLS WQTC MSD
LOCATION: 4305 ST RENE CT
JEFFERSONTOWN, KY 40299
ATTN: KEVIN RIES

KY0029459	001-1
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 40211
MINOR (SUBR LV) JEFFE
SANITARY WASTEWATER
External Outfall

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
FROM 03/01/2013	TO 03/31/2013

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved (DO) 00300 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	7	*****	*****		0	1/1	GR
	PERMIT REQUIREMENT	*****	*****	*****	7 INST MIN	*****	*****	mg/L		Weekly	GRAB
pH 00400 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	6	*****	8		0	1/1	GR
	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended 00530 1 0 Effluent Gross	SAMPLE MEASUREMENT	10	18		*****	7	13		0	1/1	CP
	PERMIT REQUIREMENT	50 30DA AVG	100 DAILY MX	lb/d	*****	30 30DA AVG	60 DAILY MX	mg/L		Weekly	COMPOS
Nitrogen, ammonia total (as N) 00610 1 2 Effluent Gross	SAMPLE MEASUREMENT	0.5	0.7		*****	0.3	0.5		0	1/1	CP
	PERMIT REQUIREMENT	16.7 30DA AVG	33.4 DAILY MX	lb/d	*****	10 30DA AVG	20 DAILY MX	mg/L		Weekly	COMPOS
Phosphorus, total (as P) 00665 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	2.2	3.1		0	1/1	CP
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	COMPOS
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.186	0.526		*****	*****	*****	*****	0	cn	cn
	PERMIT REQUIREMENT	Req. Mon. 30DA AVG	Req. Mon. INST MAX	MGD	*****	*****	*****	*****		Continuous	CONTIN
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.010	<0.010		0	1/1	GR
	PERMIT REQUIREMENT	*****	*****	*****	*****	.011 30DA AVG	.019 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER <i>GREG HOFFMAN</i> EXEC DIR TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE 502 546 6000	DATE 04/25/2013
			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT <i>Dwayne V. King</i>

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NOD=9 for the Season not needed.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CEDAR CREEK WQTC
ADDRESS: 8405 CEDAR CREEK RD
LOUISVILLE, KY 40211
FACILITY: CHENOWETH HILLS WQTC MSD
LOCATION: 4305 ST RENE CT
JEFFERSONTOWN, KY 40299
ATTN: KEVIN RIES


KY0029459	001-1
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 40211
MINOR
(SUBR LV) JEFFE
SANITARY WASTEWATER
External Outfall

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM 03/01/2013	TO	03/31/2013	

No Discharge

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Coliform, fecal general	SAMPLE MEASUREMENT	*****	*****	*****	*****	8	16		0	1/1	GR
74055 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	200 30DA GEO	400 7 DA GEO	#/100mL		Weekly	GRAB
BOD, carbonaceous, 05 day, 20 C	SAMPLE MEASUREMENT	7	10		*****	5	6		0	1/1	CO
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	50 30DA AVG	100 DAILY MX	lb/d	*****	30 30DA AVG	60 DAILY MX	mg/L		Weekly	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
GREG HOFFMAN EXEC DIR			502 540 6800
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER
			MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

Chenoweth Hills		Report for	Mar-13		Tot. Exc.= 0		Pounds						
Tot. Flow= 5.75147		Concentrations				BOD							
Date	Flow	TSS	BOD	NH3	Fecal	TSS	BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC	
3/1/13	0.151									7.8	7.9	<0.010	
3/2/13	0.167									8.5	7.7	<0.010	
3/3/13	0.169	13	5	0.22		18.31	7.04	0.31	3.14	7	7.7	<0.010	
3/4/13	0.130				4					8.3	7.7	<0.010	
3/5/13	0.175									7.8	7.6	<0.010	
3/6/13	0.184									8.3	7.8	<0.010	
3/7/13	0.163									8	7.5	<0.010	
3/8/13	0.148									7.8	7.6	<0.010	
3/9/13	0.154									8.1	7.5	<0.010	
3/10/13	0.158									7.6	7.5	<0.010	
3/11/13	0.511									8.1	7.7	<0.010	
3/12/13	0.243									7.1	6.8	<0.010	
3/13/13	0.176	6	6	0.45		8.80	8.80	0.66	2.04	7.9	6.4	<0.010	
3/14/13	0.145				9					7.9	6.9	<0.010	
3/15/13	0.133									7.9	7	<0.010	
3/16/13	0.140									7.7	7	<0.010	
3/17/13	0.260									7	7.3	<0.010	
3/18/13	0.526									7	7.6	<0.010	
3/19/13	0.247									7.3	7.6	<0.010	
3/20/13	0.178	3	3	0.17		4.45	4.45	0.25	1.06	7.8	7.5	<0.010	
3/21/13	0.154				8					7.7	7.6	<0.010	
3/22/13	0.123									7.9	7.6	<0.010	
3/23/13	0.135									8.1	7.2	<0.010	
3/24/13	0.193	6	6	0.39		9.64	9.64	0.63	2.75	8.4	7.3	<0.010	
3/25/13	0.181				16					8.2	7.1	<0.010	
3/26/13	0.147									7.8	7.6	<0.010	
3/27/13	0.141									8.3	7.6	<0.010	
3/28/13	0.131									7.7	7.4	<0.010	
3/29/13	0.124									7.3	6.7	<0.010	
3/30/13	0.135									7.4	7	<0.010	
3/31/13	0.133									7.3	6.6	<0.010	
Average	0.186	7	5	0.3	8	10	7.48	0.46	2.2	7.8	7	0.00	
Maximum	0.526	13	6	0.5	16	18	9.64	0.7	3.1	8.5	8	0.00	