



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

July 15, 2013

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Chenoweth Hills WQTC; KPDES No.: KY0029459
Discharge Monitoring Reports – June 2013**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Report (DMR) and the Monthly Operating Report (MOR) for the Chenoweth Hills WQTC, KPDES No.: KY0029459 for the month of June 2013.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMRs, please contact me at (502) 239-7574.

Sincerely,

Duane V. Wright
Process Supervisor Central Region

DVW/Chenoweth Hills 06.13

Enclosures

cc: R. Shaw
T. Singleton



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit			
Permit #:	KY0029459	Permittee:	CHENOWETH HILLS WQTC MSD
Major:	No	Permittee Address:	4305 ST RENE CT JEFFERSONTOWN, KY 40299
Permitted Feature:	001 External Outfall	Discharge:	001-1 SANITARY WASTEWATER
Facility:		Facility Location:	CHENOWETH HILLS WQTC MSD 4305 ST RENE CT JEFFERSONTOWN, KY 40299

Report Dates & Status			
Monitoring Period:	From 06/01/13 to 06/30/13	DMR Due Date:	07/28/13
Status:	NetDMR Validated		

Considerations for Form Completion
Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

Principal Executive Officer			
First Name:	Greg	Title:	Executive Director
Last Name:	Heitzman	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type					
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units			
00300	Oxygen, dissolved (DO)	1 - Effluent Gross	0	--	Sample	=	7				=	7				19 - mg/L	0	27/30 - 27 Per Month 01/07 - Weekly	GR - GRAB GR - GRAB			
					Permit Req.	>=	7	INST MIN						19 - mg/L								
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample	=	6				=	8			12 - SU	0	29/30 - 29 Per Month 01/07 - Weekly	GR - GRAB GR - GRAB				
					Permit Req.	>=	6	MINIMUM			<=	9	MAXIMUM	12 - SU								
					Value NODI																	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	3	=	4	26 - lb/d	=	3	=	4	19 - mg/L	0	01/07 - Weekly 01/07 - Weekly	CP - COMPOS CP - COMPOS				
					Permit Req.	<=	50	30DA AVG	<=	100	DAILY MX	26 - lb/d	<=	30	30DA AVG				<=	60	DAILY MX	19 - mg/L
					Value NODI																	
00610	Nitrogen, ammonia total (as N)	1 - Effluent Gross	1	--	Sample	=	0.43	=	0.5	26 - lb/d	=	0.5	=	0.5	19 - mg/L	0	01/07 - Weekly 01/07 - Weekly	CP - COMPOS CP - COMPOS				
					Permit Req.	<=	6.67	30DA AVG	<=	13.3	DAILY MX	26 - lb/d	<=	4	30DA AVG				<=	8	DAILY MX	19 - mg/L
					Value NODI																	
00665	Phosphorus, total (as P)	1 - Effluent Gross	0	--	Sample						=	4.4	=	4.7	19 - mg/L	0	01/07 - Weekly 01/07 - Weekly	CP - COMPOS CP - COMPOS				
					Permit Req.																	
					Value NODI																	
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.121	=	0.369	03 - MGD						0	99/99 - Continuous 99/99 - Continuous	CN - CONTIN CN - CONTIN				
					Permit Req.																	
					Value NODI																	
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01	<	0.01	19 - mg/L	0	01/01 - Daily 01/07 - Weekly	GR - GRAB GR - GRAB				
					Permit Req.																	
					Value NODI																	
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample						=	51	=	95	13 - #/100mL	0	01/07 - Weekly 01/07 - Weekly	GR - GRAB GR - GRAB				
					Permit Req.																	
					Value NODI																	
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	3	=	4	26 - lb/d	=	4	=	4	19 - mg/L	0	01/07 - Weekly 01/07 - Weekly	CP - COMPOS CP - COMPOS				
					Permit Req.	<=	50	30DA AVG	<=	100	DAILY MX	26 - lb/d	<=	30	30DA AVG				<=	60	DAILY MX	19 - mg/L
					Value NODI																	

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments		
Name	Type	Size
Chenowethhills062013_cover.pdf	pdf	17173
Chenowethhills062013_MOR.pdf	pdf	24073

Report Last Saved By
CHENOWETH HILLS WQTC MSD

User:	wrightd	Date/Time:	2013-07-24 12:52 (Time Zone: -04:00)
Name:	Duane Wright		
E-Mail:	duane.wright@louisvillemsd.org		

Chenoweth Hills		Report for		Jun-13		Tot. Exc.= 0							
Tot. Flow= Date	3.6154 Flow	TSS	Concentrations		Fecal	TSS	Pounds		NH3	Tot. Phos.	D.O.	p.H.	TRC
			BOD	NH3			BOD						
6/1/13	0.123										7.2	7.2	0.01
6/2/13	0.116	3	4	0.5		3	4	0.49	4.52		7.1	7.3	0.01
6/3/13	0.089				70						7.3	6.9	0.01
6/4/13	0.087										7.2	7.3	0.01
6/5/13	0.096										7.2	7.6	0.01
6/6/13	0.096										7.4	6.2	0.01
6/7/13	0.095										7.8	6.8	0.01
6/8/13	0.104										7	6.6	0.01
6/9/13	0.111	3	4	0.45		3	4	0.42	4.49		7.6	6.8	0.01
6/10/13	0.111				95							6.7	0.01
6/11/13	0.097										7.3	6.6	0.01
6/12/13	0.097										7.2	6.2	0.01
6/13/13	0.083										7.6	6.2	0.01
6/14/13	0.074										8.6	7.2	0.01
6/15/13	0.099										7.6	6.2	0.01
6/16/13	0.109	4	4	0.5		4	4	0.45	4.66				0.01
6/17/13	0.165				31						7.4	7.6	0.01
6/18/13	0.179										7.5	7.4	0.01
6/19/13	0.107										7.2	7.6	0.01
6/20/13	0.092										7.3	7.4	0.01
6/21/13	0.095										7.2	7.2	0.01
6/22/13	0.096										7.5	7	0.01
6/23/13	0.107	2	3	0.39		2	3	0.35	3.85		7.6	7.2	0.01
6/24/13	0.093				32						7.3	7	0.01
6/25/13	0.092										7.5	6.3	0.01
6/26/13	0.245										7.4	6.5	0.01
6/27/13	0.369											6.8	0.01
6/28/13	0.148										7.2	6.6	0.01
6/29/13	0.121										7.5	6.8	0.01
6/30/13	0.120										7.4	7	0.01
7/1/13													
Average	0.121	3	4	0.5	50.68	3	3.473	0.43	4.4		7.41	7	0.01
Maximum	0.369	4	4	0.5	95.00	4	3.880	0.5	4.7		8.60	8	0.01
Exceed.	2	0	0	0	0	0	0	0	0				