



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

July 19, 2011

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Chenoweth Run WQTC
KPDES No.: KY0042226
Discharge Monitoring Reports – June 2011**


Dear Ms. Edwards:

Attached is the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the Chenoweth Run WQTC, KPDES No.: KY0042226 for the month of June 2011.

There were no exceedences, bypass or overflow reports.

If you have any questions concerning the attached DMR's, please contact me at (502) 239-7574.

Sincerely,


Duane V. Wright
Process Supervisor Central Region

DVW/ Chen. Run 6.11

Enclosures

cc: C. Roth (DOW Louisville)
T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

NAME CHENOWETH RUN WQTC
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD.
 LOUISVILLE KY 40211
 FACILITY CHENOWETH RUN WQTC
 LOCATION LOUISVILLE KY 40203
 ATTN: DENNIS THOMASSON, SR METRO OPS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

WQTR	0012
PERMIT NUMBER	DISCHARGE NUMBER

MINOR (SUBR LV)
 F - FINAL
 SANITARY WASTEWATER EFFLUENT
 *** NO DISCHARGE [] ***

JEFF

MONITORING PERIOD:						
YEAR	MO.	DAY	TO	YEAR	MO.	DAY

FROM

TO

NOTE: Read Instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
003000 1 0 0 EFFLUENT GROSS VALUE				***	7					0	17/30	GR
	PERMIT REQUIREMENT			****	INST MIN			MG/L				
004000 1 0 0 EFFLUENT GROSS VALUE				***	6.7		7.3			0	17/30	GR
	PERMIT REQUIREMENT			****	MINIMUM		MAXIMUM	5U				
005200 1 0 0 EFFLUENT GROSS VALUE		25	37			8	13			0	0/07	CP
	PERMIT REQUIREMENT	GODA AVG	DAILY MX	LBS/DY		GODA AVG	DAILY MX	MG/L				
005510 1 1 0 EFFLUENT GROSS VALUE		4.21	8.3			1	3			0	0/07	CP
	PERMIT REQUIREMENT	GODA AVG	DAILY MX	LBS/DY		GODA AVG	DAILY MX	MG/L				
006655 1 0 0 EFFLUENT GROSS VALUE				***		4.5	5.5			0	0/07	CP
	PERMIT REQUIREMENT			****		GODA AVG	DAILY MX	MG/L				
009090 1 0 0 EFFLUENT GROSS VALUE		0.417	0.888							0	CN	LN
	PERMIT REQUIREMENT	GODA AVG	INST MAX	MGD								
009090 1 0 0 EFFLUENT GROSS VALUE				***		40.010	40.010			0	17/30	GR
	PERMIT REQUIREMENT			****		GODA AVG	DAILY MX	MG/L				

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 H. J. SCHARDEIN, JR.
 EXEC. DIR.
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
Dennis Thomasson, Sr.

TELEPHONE	DATE
502 540 6000	11 7 19
AREA CODE NUMBER	YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME CHENOWETH RUN WQTC
ADDRESS 070 CEDAR CREEK WQTC
8405 CEDAR CREEK RD
LOUISVILLE KY 40211
FACILITY CHENOWETH RUN WQTC
LOCATION LOUISVILLE KY 40223
ATTN: DENNIS THOMASSON, SR. METRO OPS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
FROM YEAR MO. DAY	TO YEAR MO. DAY

MINOR (SUBR LV)
T - FINAL
SANITARY WASTEWATER EFFLUENT
*** NO DISCHARGE ***

NOTE: Read Instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
GENERAL EFFLUENT GROSS VALUE						12	27		0	0/07	GR
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT			***		300A 000	7 DA 000	100ML			
5 DAY BOD5 GROSS VALUE		11.3	15.6			4	5		0	0/07	LP
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	300A AVG	DAILY MX	LBS/DY		300A AVG	DAILY MX	MG/L			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
D. SCHANDLER, JR.
EXRE. DIR.
TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT
Dennis Thomasson, Sr.

TELEPHONE 502 540 6000
DATE 11 7 19
AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

CHENOWETH RUN		Report for		Jun-01		Tot. Exc.=		0			
Tot. Flow=	12.506			Concentrations				Pounds		Conc.	
Date	Flow	TSS	BOD	NH3	Fecal	TSS	BOD	NH3	T Phos		
6/1/01	0.34	13	5	0.5	27	36.863	14.178	1.418	3.79		
6/2/01	0.336										
6/3/01	0.345										
6/4/01	0.355										
6/5/01	0.356										
6/6/01	0.337										
6/7/01	0.351										
6/8/01	0.331	9	3	3	20	24.845	8.282	8.282	4.65		
6/9/01	0.33										
6/10/01	0.338										
6/11/01	0.372										
6/12/01	0.346										
6/13/01	0.349										
6/14/01	0.336										
6/15/01	0.467	5	4	0.84	9	19.474	15.579	3.272	5.49		
6/16/01	0.367										
6/17/01	0.373										
6/18/01	0.549										
6/19/01	0.548										
6/20/01	0.583										
6/21/01	0.433										
6/22/01	0.42	5	2	1.1		17.514	7.006	3.853	4.18		
6/23/01	0.888										
6/24/01	0.812				5						
6/25/01	0.453										
6/26/01	0.341										
6/27/01	0.376										
6/28/01	0.357										
6/29/01	0.374										
6/30/01	0.343										
Average	0.417	8.00	3.50	1.36	12.49	24.67	11.26	4.21	4.53		
Maximum	0.888	13.00	5.00	3.00	27.00	36.86	15.58	8.28	5.49		