



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

August 13, 2012

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Chenoweth Run WQTC
KPDES No.: KY0042226
Discharge Monitoring Reports – July 2012**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the Chenoweth Run WQTC, KPDES No.: KY0042226 for the month of July 2012.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMR's, please contact me at (502) 239-7574.

Sincerely,

A handwritten signature in cursive script, appearing to read "Duane V. Wright".

Duane V. Wright
Process Supervisor Central Region

DVW/ Chen. Run 7.12

Enclosures

cc: C. Roth (DOW Louisville)
T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CEDAR CREEK WQTC
 ADDRESS: 8405 CEDAR CREEK RD
 LOUISVILLE, KY 40211
 FACILITY: CHENOWETH RUN WQTC
 LOCATION: 14000 BECKLEY TRACE
 LOUISVILLE, KY 40223

KY0042226

PERMIT NUMBER

001-2

DISCHARGE NUMBER

DMR Mailing ZIP CODE: 40211

MINOR

(SUBR LV) JEFFE

SANITARY WASTEWATER

External Outfall

ATTN: DENNIS THOMASSON, SR METRO OPS

FROM

MM/DD/YYYY

07/01/2012

TO

MM/DD/YYYY

07/31/2012

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved (DO)	SAMPLE MEASUREMENT	*****	*****	*****	8	*****	*****		0	1 1/1	GR
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	7 INST MIN	*****	*****	mg/L		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	6.1	*****	7.0		0	1/1	GR
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	13	25		*****	10	18		0	1/1	CP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	118 30DA AVG	236 DAILY MX	lb/d	*****	30 30DA AVG	60 DAILY MX	mg/L		Weekly	COMPOS
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	0.75	1.0		*****	0.6	0.7		0	1/1	CP
00610 1 1 Effluent Gross	PERMIT REQUIREMENT	7.84 30DA AVG	15.7 DAILY MX	lb/d	*****	2 30DA AVG	4 DAILY MX	mg/L		Weekly	COMPOS
Phosphorus, total (as P)	SAMPLE MEASUREMENT	*****	*****	*****	*****	4.0	4.8		0	1/1	CP
00665 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. 30DA AVG	Req. Mon. DAILY MX	mg/L		Weekly	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.167	0.212		*****	*****	*****	*****	0	1/1	1/1
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. 30DA AVG	Req. Mon. INST MAX	MGD	*****	*****	*****	*****		Continuous	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	20.010	20.010		0	1/1	GR
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	.011 30DA AVG	.019 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER GREG HEITZMAN INTERIM EXEC DIR. TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		502 5406000 08/17/2012
		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CEDAR CREEK WQTC
ADDRESS: 8405 CEDAR CREEK RD
LOUISVILLE, KY 40211
FACILITY: CHENOWETH RUN WQTC
LOCATION: 14000 BECKLEY TRACE
LOUISVILLE, KY 40223

ATTN: DENNIS THOMASSON, SR METRO OPS


KY0042226	001-2
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 40211
MINOR
(SUBR LV) JEFFE
SANITARY WASTEWATER
External Outfall

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	07/01/2012	TO	07/31/2012

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Coliform, fecal general	SAMPLE MEASUREMENT	*****	*****	*****	*****	5	12		0	1/1	GR
74055 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	200 30DA GEO	400 7 DA GEO	#/100mL		Weekly	GRAB
BOD, carbonaceous, 05 day, 20 C	SAMPLE MEASUREMENT	6.8	8.3		*****	5	6		0	1/1	CP
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	39.2 30DA AVG	78.4 DAILY MX	lb/d	*****	10 30DA AVG	20 DAILY MX	mg/L		Weekly	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
GREG HEITZMAN INTERIM EXEC DIR TYPED OR PRINTED			502 5406000	08/17/2012
			AREA Code	NUMBER
			MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

