



**MSD**

*Louisville and Jefferson County Metropolitan Sewer District  
700 West Liberty Street  
Louisville Kentucky 40203-1911  
502-540-6000  
www.msdlouky.org*

May 22, 2007

Ms. Kathy Thurman  
Kentucky Division of Water  
14 Reilly Road  
Frankfort, Kentucky 40601

**Re: MSD Metro Operations  
Glenview Acres WTP; KPDES No.: KY0022462  
Discharge Monitoring Reports – April 2007**

Dear Ms. Thurman:

Attached is the Discharge Monitoring Reports (DMRs) for the Glenview Acres WTP; KPDES No.: KY0022462 for the month of April 2007.

If you have any questions concerning the attached DMRs, please contact me at (502)241-9093

Sincerely,

John Kessel  
Process Supervisor, East Region

JMK/Glenview Acres 0407

Enclosures

cc: M. Mudd (DOW Louisville)  
E. Brady  
T. Singleton  
P. Burgin  
R. Shaw



*Beneficial Use of Louisville's Biosolids  
www.louisvillegreen.com*

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) DISCHARGE MONITORING REPORT (DMR)

Form Approved OMB No. 2040-0004

NAME CLERMONT ACRES STP MSD  
 ADDRESS 170 LOUISVILLE/JEFF CO MSD  
 432 ALDINGHAM PARK  
 LOUISVILLE KY 40211-2477  
 FACILITY CLERMONT ACRES STP MSD  
 LOCATION LOUISVILLE KY  
 WITH ALEX EMOVAK OPER MGR

KY0022462  
 PERMIT NUMBER

001 2  
 DISCHARGE NUMBER

MINOR  
 (SUFR LV)  
 F - FINAL  
 SANITARY WASTEWATER  
 EFFLUENT  
 \*\*\* NO DISCHARGE \*\*\*

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	04	01		07	04	30

NOTE: Read Instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)		*****	*****		7.6	*****	*****	( 17)	0	1/30	Grab
EFFLUENT GROSS VALUE		*****	*****	*****	INST MIN	*****	*****	MG/L		MONTH	
PH		*****	*****		6.9	*****	6.9	( 12)	0	1/30	Grab
EFFLUENT GROSS VALUE		*****	*****	*****	MINIMUM	*****	MAXIMUM	SU		MONTH	
SOLIDS, TOTAL SUSPENDED		1.33	1.33	( 25)	*****	20.0	20.0	( 17)	0	1/30	Comp
EFFLUENT GROSS VALUE		3.00	8.00	LBS/DY	*****	30	80	MG/L		MONTH	
NITROGEN, AMMONIA TOTAL (AS N)		0.02	0.02	( 25)	*****	0.28	0.28	( 17)	0	1/30	Comp
EFFLUENT GROSS VALUE		1.00	2.00	LBS/DY	*****	10	20	MG/L		MONTH	
FLOW IN CONDUIT OR TREATMENT PLANT		0.006	0.008	( 33)	*****	*****	*****	*****	0	5/7	Ind.
EFFLUENT GROSS VALUE		REPORT	REPORT	MGD	*****	*****	*****	*****		DAYS	
COLIFORM, FECAL GENERAL		*****	*****		*****	1.0	1.0	( 13)	0	1/30	Grab
EFFLUENT GROSS VALUE		*****	*****	*****	*****	300	400	/		MONTH	
BOD, CARBONACEOUS 5 DAY, 20C		0.27	0.27	( 25)	*****	4.0	4.0	( 17)	0	1/30	Comp
EFFLUENT GROSS VALUE		3.00	8.00	LBS/DY	*****	30	80	MG/L		MONTH	

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER  
 H J Swanson  
 Exec Director  
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT  
 TELEPHONE 609 241 9093  
 DATE 07 05 22  
 AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)