



MSD

*Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org*

February 23, 2007

Ms. Kathy Thurman
Kentucky Division of Water
14 Reilly Road
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Glenview Acres WTP; KPDES No.: KY0022462
Discharge Monitoring Reports – January 2007**

Dear Ms. Thurman:

Attached is the Discharge Monitoring Reports (DMRs) for the Glenview Acres WTP; KPDES No.: KY0022462 for the month of December 2006.

If you have any questions concerning the attached DMRs, please contact me at (502)241-9093

Sincerely,

John Kessel
Process Supervisor, East Region

JMK/Glenview Acres 0107

Enclosures

cc: M. Mudd (DOW Louisville)
E. Brady
T. Singleton
P. Burgin
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

MINOR

(SUBR LV)

F - FINAL

SANITARY WASTEWATER

EFFLUENT

*** NO DISCHARGE 1 1 ***

NOTE: Read instructions before completing this form.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME GLENVIEW ACRES STP MSD

ADDRESS C/O LOUISVILLE/JEFF CO MSD

1522 ALCONQUIN PKWY

LOUISVILLE

KY 40211-2477

FACILITY GLENVIEW ACRES STP MSD

LOCATION LOUISVILLE

KY

ATTN: ALEX E NOVAK, OPER MGR

KY0022462

PERMIT NUMBER

001 2

DISCHARGE NUMBER

MONITORING PERIOD

YEAR	MO	DAY	TO	YEAR	MO	DAY
07	01	01		07	01	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****		8.6	*****	*****	(19)	0	1/31	Grab
00300 1 0 0	PERMIT REQUIREMENT	*****	*****	***	INST MIN	*****	*****	MG/L		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE											
PH	SAMPLE MEASUREMENT	*****	*****		6.8	*****	6.9	(12)	0	1/31	Grab
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	***	MINIMUM	*****	9.0	SU		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE											
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	1.20	1.20	(20)	*****	9.0	9.0	(19)	0	1/31	Comp
00500 1 0 0	PERMIT REQUIREMENT	3.00	8.00	***	*****	30	80	MG/L		ONCE/ MONTH	COMPOS
EFFLUENT GROSS VALUE		30DA AVG	DAILY MX	LBS/DY		30DA AVG	DAILY MX				
NITROGEN, AMMONIA TOTAL (AS N)	SAMPLE MEASUREMENT	.01	.01	(20)	*****	.05	.05	(19)	0	1/31	Comp
00610 1 2 0	PERMIT REQUIREMENT	1.00	2.00	***	*****	10	20	MG/L		ONCE/ MONTH	COMPOS
EFFLUENT GROSS VALUE		30DA AVG	DAILY MX	LBS/DY		30DA AVG	DAILY MX				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	.008	.016	(03)	*****	*****	*****		0	24/31	Inst.
00050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT		*****	*****	*****	***		WEEK- DAYS	INSTAN
EFFLUENT GROSS VALUE		30DA AVG	INST MAX	MGD							
COLIFORM, FECAL GENERAL	SAMPLE MEASUREMENT	*****	*****		*****	1.0	1.0	(13)	0	1/31	Grab
74055 1 0 0	PERMIT REQUIREMENT	*****	*****	***	*****	200	400 #/	100ML		ONCE/ MONTH	GRAB
EFFLUENT GROSS VALUE						30DA SED	7 DA SED				
BOD, CARBONACEOUS 5 DAY, 20C	SAMPLE MEASUREMENT	1.07	1.07	(20)	*****	8.0	8.0	(19)	0	1/31	Comp
00082 1 0 0	PERMIT REQUIREMENT	3.00	8.00	***	*****	30	60	MG/L		ONCE/ MONTH	COMPOS
EFFLUENT GROSS VALUE		30DA AVG	DAILY MX	LBS/DY		30DA AVG	DAILY MX				

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

H.J. Schardein Jr

Exec Director

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE

508
AREA CODE540-6600
NUMBER07
YEAR02
MO20
DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)