



**MSD**

*Louisville and Jefferson County Metropolitan Sewer District  
700 West Liberty Street  
Louisville Kentucky 40203-1911  
502-540-6000  
www.msdlouky.org*

March 20, 2007

Ms. Kathy Thurman  
Kentucky Division of Water  
14 Reilly Road  
Frankfort, Kentucky 40601

**Re: MSD Metro Operations  
Glenview Acres WTP; KPDES No.: KY0022462  
Discharge Monitoring Reports – February 2007**

Dear Ms. Thurman:

Attached is the Discharge Monitoring Reports (DMRs) for the Glenview Acres WTP; KPDES No.: KY0022462 for the month of February 2007.

If you have any questions concerning the attached DMRs, please contact me at (502)241-9093

Sincerely,

John Kessel  
Process Supervisor, East Region

JMK/Glenview Acres 0207

Enclosures

cc: M. Mudd (DOW Louisville)  
E. Brady  
T. Singleton  
P. Burgin  
R. Shaw



*Beneficial Use of Louisville's Biosolids  
www.louisvillegreen.com*

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)  
DISCHARGE MONITORING REPORT (DMR)

MINOR  
(SUBR LV)  
F - FINAL  
SANITARY WASTEWATER  
EFFLUENT

\*\*\* NO DISCHARGE ( ) \*\*\*

NOTE: Read Instructions before completing this form.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME OLENVIEW ACRES STP MSD  
ADDRESS C/O LOUISVILLE/JEFF CO MBD  
4542 ALDONQUIN PKWY  
LOUISVILLE KY 40211-2497  
FACILITY OLENVIEW ACRES STP MSD  
LOCATION LOUISVILLE KY  
ATTN: ALEX E NOVAK OPER MGR

KY0022462		001 2				
PERMIT NUMBER		DISCHARGE NUMBER				
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	02	01		07	02	28

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
DO (mg/L) DISSOLVED O <sub>2</sub>	*****	*****	*****	*****	8.1	*****	*****	( 17 )	0	1/28	Grab
DO (mg/L) EFFLUENT GROSS VALUE	*****	*****	*****	*****	INST MIN	*****	*****	MG/L		1/28	Grab
PH	*****	*****	*****	*****	6.9	*****	( 9 )	( 12 )	0	1/28	Grab
PH EFFLUENT GROSS VALUE	*****	*****	*****	*****	MINIMUM	*****	MAXIMUM	BU		1/28	Grab
SOLIDS, TOTAL SUSPENDED	*****	*****	*****	*****	6.0	*****	6.0	( 17 )	0	1/28	Comp
SOLIDS, TOTAL SUSPENDED EFFLUENT GROSS VALUE	*****	*****	*****	*****	30DA AVG	*****	30	60		1/28	Composite
NITROGEN, AMMONIA TOTAL (AS N)	*****	*****	*****	*****	0.02	*****	0.28	( 17 )	0	1/28	Comp
NITROGEN, AMMONIA TOTAL (AS N) EFFLUENT GROSS VALUE	*****	*****	*****	*****	30DA AVG	*****	10	20		1/28	Composite
FLOW IN CONDUIT OF WASTEWATER TREATMENT PLANT	*****	*****	*****	*****	0.007	*****	*****	*****	0	1/28	Inst
FLOW IN CONDUIT OF WASTEWATER TREATMENT PLANT EFFLUENT GROSS VALUE	*****	*****	*****	*****	REPORT	*****	*****	*****		1/28	Inst
COLIFORM, FECAL GENERAL	*****	*****	*****	*****	1	*****	1	( 13 )	0	1/28	Grab
COLIFORM, FECAL GENERAL EFFLUENT GROSS VALUE	*****	*****	*****	*****	30DA GEO	*****	400	7 DA GEO		1/28	Grab
BOD, CARBONACEOUS 5 DAY, 20C	*****	*****	*****	*****	0.13	*****	2.0	( 17 )	0	1/28	Comp
BOD, CARBONACEOUS 5 DAY, 20C EFFLUENT GROSS VALUE	*****	*****	*****	*****	30DA AVG	*****	30	60		1/28	Composite

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER A.S. Schroeder Jr Exec. Director TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 	TELEPHONE		DATE		
			AREA CODE	NUMBER	YEAR	MO	DAY
			504	241-4093	07	03	20

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)