



MSD

*Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org*

August 23, 2007

Ms. Kathy Thurman
Kentucky Division of water
14 Reilly Road
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Glenview Bluff WTP
KPDES No.: KY0044261
Discharge Monitoring Reports – July 2007**

Dear Ms. Thurman:

Attached is the Discharge Monitoring Reports (DMRs) for the Glenview Bluff WTP, KPDES No.: KY0044261 for the Third quarter of 2007.

If you have any questions concerning the attached DMRs, please contact me at (502)540-6035.

Sincerely,

John Kessel
Process Supervisor, East Region

JMK/Glenview Bluff 0707

Enclosures

cc: M. Mudd (DOW Louisville)
E. Brady
T. Singleton
P. Burgin
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME GLENVIEW BLUFF STP MSD
 ADDRESS C/O CEDAR CREEK STP
 B405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY GLENVIEW BLUFF STP MSD
 LOCATION LOUISVILLE KY 40222
 ATTN: DENNIS THOMASSON

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0044261	001
PERMIT NUMBER	DISCHARGE NUMBER

MINOR
 (SUBR LV)
 F - FINAL
 SANITARY WASTEWATER
 EFFLUENT
 *** NO DISCHARGE 1 1 ***

JEFFE

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
07	07	01		07	07	01

FROM

TO

NOTE: Read Instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****		7.4	*****	*****	(17)	0	1/92	Grab
00300 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	INST MIN	*****	*****	MG/L		WEEKLY	GRAB
EFFLUENT GROSS VALUE											
PH	SAMPLE MEASUREMENT	*****	*****		6.8	*****	6.8	(12)	0	1/92	Grab
00400 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	MINIMUM	*****	MAXIMUM	SV		WEEKLY	GRAB
EFFLUENT GROSS VALUE											
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	0.18	0.18	(26)	*****	7.0	7.0	(17)	0	1/92	Comp
00530 1 0 0	PERMIT REQUIREMENT	2.50	5.00		*****	30	60	MG/L		WEEKLY	COMPOS
EFFLUENT GROSS VALUE		30DA AVG	DAILY MX	LBS/DY		30DA AVG	DAILY MX				
NITROGEN, AMMONIA TOTAL (AS N)	SAMPLE MEASUREMENT	0.003	0.003	(26)	*****	0.10	0.10	(17)	0	1/92	Comp
00610 1 1 0	PERMIT REQUIREMENT	0.33	0.60		*****	4	8	MG/L		WEEKLY	COMPOS
EFFLUENT GROSS VALUE		30DA AVG	DAILY MX	LBS/DY		30DA AVG	DAILY MX				
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.004	0.006	(03)	*****	*****	*****	*****	0	5/17	Inst
00050 1 0 0	PERMIT REQUIREMENT	REPORT	REPORT		*****	*****	*****	*****		WEEKLY	INSTAN
EFFLUENT GROSS VALUE		30DA AVG	INST MAX	MGD							
COLIFORM, FECAL GENERAL	SAMPLE MEASUREMENT	*****	*****		*****	1.0	1.0	(12)	0	1/92	Grab
74055 1 0 0	PERMIT REQUIREMENT	*****	*****	*****	*****	200	400 #/	100ML		WEEKLY	GRAB
EFFLUENT GROSS VALUE						30DA GED	7 DA GED				
BOD, CARBONACEOUS 5 DAY, 20C	SAMPLE MEASUREMENT	0.03	0.03	(26)	*****	1.0	1.0	(17)	0	1/92	Comp
00082 1 0 0	PERMIT REQUIREMENT	2.50	5.00		*****	30	60	MG/L		WEEKLY	COMPOS
EFFLUENT GROSS VALUE		30DA AVG	DAILY MX	LBS/DY		30DA AVG	DAILY MX				
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.				TELEPHONE		DATE			
H.J. Schardin Jr. Exec Director						503 241-4093		07 08 21			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE	NUMBER	YEAR	MO	DAY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)