



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

May 15, 2012

Cheryl Edwards
DMR Coordinator
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Glenview Bluff WTP
KPDES No.: KY0044261
Discharge Monitoring Reports for the- Second Quarter of 2012.**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports and the Monthly Operator Report (DMRs) for the Glenview Bluff WTP, KPDES No.: KY0044261 for the Second quarter 2012.

There are no exceedences, bypasses or overflow report forms for this quarter.

If you have any questions concerning the attached DMRs, please contact me at (502)587-5856.

Sincerely,

Kevin Thompson,
Process Supervisor, East Region

KT/ Glenview Bluff 04/12.

Enclosures

cc: C. Roth (DOW Louisville)
T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME GLENVIEW BLUFF WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY GLENVIEW BLUFF WQTC MSD
 LOCATION LOUISVILLE KY 40222
 ATTN: DENNIS THOMASSEN, SR METRO OPS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0044261
 PERMIT NUMBER
 0011
 DISCHARGE NUMBER

MINOR
 (SUBR LV)
 7 - FINAL
 SANITARY WASTEWATER
 EFFLUENT

Form Approved
 OMB No. 2040-0004

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
1990	05	15		1990	05	15

*** NO DISCHARGE ***

NOTE: Read Instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PHOSPHORUS, TOTAL (AS P) 00665 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	*****	*****	*****	*****	3.18	3.18	MG/L	B	1/90	CP
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 60050 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	0.001	0.001	(G3)	*****	*****	*****	*****	B	CN	CN
CHLORINE, TOTAL RESIDUAL 60060 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.010	<0.010	MG/L	B	2/90	GR
E. COLI 61040 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	*****	*****	*****	*****	6	6	100ML	B	1/90	GR
BOD, CARBONACEOUS 5 DAY, 20C 60082 1 0 0 EFFLUENT GROSS VALU	PERMIT REQUIREMENT	0.01	0.01	(MS)	*****	2	2	MG/L	B	1/90	CP

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 Greg C. Hatzman
 Interim Executive Director
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Ken Brown
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE 502 540-6000
 DATE 12 05 15
 AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 TOTAL NITROGEN=TKM (AS N) AND NITRATE/NITRITE (AS N).

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME GLENVIEW BLUFF WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY GLENVIEW BLUFF WQTC MSD
 LOCATION LOUISVILLE KY 40222
 ATTN: DENNIS THOMASSON, SR METRO OPS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

XY0044261 PERMIT NUMBER
 001 1 DISCHARGE NUMBER

MINOR (SUBR LV)
 F - FINAL
 SANITARY WASTEWATER EFFLUENT
 *** NO DISCHARGE 1-1-90 ***

JEFF

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
12	04	02		12	06	30

NOTE: Read Instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO) 00300 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT	*****	*****		7.0	*****	*****	(19)		29/90	GR
	PERMIT REQUIREMENT	*****	*****	****	7.0 INST. MIN	*****	*****	MG/L		DIRLY	GRAB
PH 00400 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT	*****	*****		6.0	*****	8.0	(12)		29/90	GR
	PERMIT REQUIREMENT	*****	*****	****	6.0 MINIMUM	*****	8.0 MAXIMUM	SU		DIRLY	GRAB
SOLIDS, TOTAL SUSPENDED 00530 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT	0.09	0.09	(25)	*****	13	13	(19)		1/90	CP
	PERMIT REQUIREMENT	2.50 MD AVG	3.75 DAILY MX	LBS/D	*****	30 MD AVG	45 DAILY MX	MG/L		DIRLY	COMPS
NITROGEN, TOTAL (AS N) 00600 1 0 0 EFFLUENT GROSS VALU	SAMPLE MEASUREMENT	*****	*****		*****	29	29	(19)		1/90	CP
	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MD AVG	REPORT DAILY MX	MG/L		DIRLY	COMPS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 Greg C. Heitzman
 Interim Executive Director
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Kevin Thomas

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE 502 540-6000
 DATE 12 05 15
 AREA CODE NUMBER YEAR MO DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments herè)
 TOTAL NITROGEN=TKN (AS N) AND NITRATIE/NITRITE (AS N).

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME GLENVIEW BLUFF WQTC MSD
 ADDRESS C/O CEDAR CREEK WQTC
 8405 CEDAR CREEK RD
 LOUISVILLE KY 40211
 FACILITY GLENVIEW BLUFF WQTC MSD
 LOCATION LOUISVILLE KY 40222
 ATTN: DENNIS THOMASSEN, SR METRO OPS

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

KY0044251
 PERMIT NUMBER
 001 1
 DISCHARGE NUMBER

MINOR
 (SUBR LV)
 F - FINAL
 SANITARY WASTEWATER
 EFFLUENT
 *** NO DISCHARGE ***

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY

FROM

TO

NOTE: Read Instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
NITROGEN AMMONIA TOTAL (AS N) 30610 1 2 0 EFFLUENT GROSS VALU		0.006	0.006	(25)	*****	0.8	0.8			1/90	CP
	PERMIT REQUIREMENT	30DA AVG	DAILY MX	LBS/D	*****	30DA AVG	DAILY MX	MG/L			
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER
 Greg C. Heitzman
 Interim Executive Director
 TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Signature of Greg C. Heitzman
 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE
 502 540-6000
 DATE
 12 05 15

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 TOTAL NITROGEN=TKN (AS N) AND NITRATIC/NITRITE (AS N)

