



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

April 13, 2014

Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Glenview Bluff WTP
KPDES No.: KY0044261
Discharge Monitoring Reports for the— First Quarter of 2014.**

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports and the Monthly Operator Report (DMRs) for the Glenview Bluff WTP, KPDES No.: KY0044261 for the First quarter 2014.

There are no exceedences, overflows or bypass report forms for this quarter.

If you have any questions concerning the attached DMRs, please contact me at (502)587-5856.

Sincerely,

A handwritten signature in black ink, appearing to read "Kevin Thompson", written over a horizontal line.

Kevin Thompson,
Process Supervisor, East Region

KT/ Glenview Bluff 03/14.

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit

Permit #:

KY0044261

Major:

No

Permittee:

GLENVIEW BLUFF WQTC MSD

Permittee Address:

3711 GLEN BLUFF RD
LOUISVILLE, KY 40222

Facility:

GLENVIEW BLUFF WQTC MSD

Facility Location:

3711 GLEN BLUFF RD
LOUISVILLE, KY 40222

Permitted Feature:

001
External Outfall

Discharge:

001-1
SANITARY WASTEWATER

Report Dates & Status

Monitoring Period:

From 01/01/14 to 03/31/14

DMR Due Date:

04/28/14

Status:

NetDMR Validated

Considerations for Form Completion

TOTAL NITROGEN=TKN (AS N) AND NITRATIE/NITRITE (AS N). Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

Principal Executive Officer

First Name:

Greg

Last Name:

Heitzman

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI: --

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

Parameter		Monitoring Location	Field	Type	Description	Acknowledge
Code	Name					
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	All	Soft	All permit limit values for the Parameter are missing sample values or NODI selection. (Error Code: -1)	Yes

Comments

Attachments

Name		Type	Size
201403_GlenviewBluff_COVERLETTER.pdf		pdf	16858
201403_GlenviewBluff_MOR.pdf		pdf	8371
<i>Report Last Saved By</i>			
<i>GLENVIEW BLUFF WQTC MSD</i>			
User:	kevin.thompson@louisvillemsd.org	Date/Time:	2014-04-24 08:55 (Time Zone: -04:00)
Name:	Kevin Thompson		
E-Mail:	kevin.thompson@louisvillemsd.org		

Glenview Bluff		Report for		Jan-14		Tot. Exc.=		0		Pounds							
Tot. Flow=		0.057		Concentrations													
Date	Flow	TSS	BOD	NH3	Ecoli	TSS	BOD	NH3	Tot. Phos.	Tot. N	D.O.	p.H.	TRC				
1/1/14	0.002																
1/2/14	0.002																
1/3/14	0.002										7.5	7.3	0.01				
1/4/14	0.002										7.5	7.3	0.01				
1/5/14	0.002																
1/6/14	0.001																
1/7/14	0.002																
1/8/14	0.003										8	7.1	0.01				
1/9/14	0.003	7	6	0.39		0.159	0.136	0.009	2.21	33.91	8.9	6.5	0.01				
1/10/14	0.001				87						8	6	0.01				
1/11/14	0.002										8	7.1					
1/12/14	0.002										7.8	6					
1/13/14	0.002										7.9	6.3	0.01				
1/14/14	0.002										8	6.2	0.01				
1/15/14	0.002										7.8	6.3	0.01				
1/16/14	0.002										8	6.3	0.01				
1/17/14	0.001										7.7	6.2	0.01				
1/18/14	0.002										7.5	6.1	0.01				
1/19/14	0.002										7.4	6.2	0.01				
1/20/14	0.002										7.3	6.3	0.01				
1/21/14	0.002										7.3	6.3	0.01				
1/22/14	0.002										7.3	6.3	0.01				
1/23/14	0.002										7.5	6.3	0.01				
1/24/14	0.002										9.5	6.6	0.01				
1/25/14	0.003										10	6.6	0.01				
1/26/14	0.002										7.8	6.5	0.01				
1/27/14	0.001										8	6.4	0.01				
1/28/14	0.002										7.6	6.3	0.01				
1/29/14	0.002										7.5	6.4	0.01				
1/30/14	0.002										7.4	6.3	0.01				
1/31/14	0.001										7.6	6.4	0.01				
Average	0.002	7	6	0.4	87.00	0.16	0.136	0.01	2.2	33.91	7.88	6	0.01				
Maximum	0.003	7	6	0.4	87.00	0.16	0.136	0.01	2.2	33.91	10.00	7	0.01				
	0	0	0	0	0	0	0	0									