

Appendix A-1 - Discharge Work Orders - Dry Weather CSOs







KPDES # Facility ID Water Quality Treatement Center Receiving Stream of Treatment Center Region

Facility Type Facility ID Facility Address If Pump Station, Name of Pump Station: Receiving Stream Discharge to

Activity Code / Description WO # Ref No Initiated Initiated By Assigned To Disch Status Event Date Problem Result Completed Condition

THERE WERE NO DRY WEATHER CSOS FOR THE PERIOD

Total Facilities Printed: 1

Total Work Orders Printed:

JULY 1, 2014 - SEPTEMBER 30, 2014

10/7/2014 Page 1 of 1 8:31:27 AM



Appendix A-2 - Discharge Work Orders - Bypass







KPDES # Facility ID Water Quality Treatement Center Receiving Stream of Treatment Center Region

Facility Type Facility ID Facility Address If Pump Station, Name of Pump Station: Receiving Stream Discharge to

Activity Code / Description WO # Ref No Initiated By Assigned To Disch Status Event Date Problem Result Completed Condition

THERE WERE NO BYPASS EVENTS FOR THE PERIOD JULY 1, 2014 - SEPTEMBER 30, 2014

Total Facilities Printed: 1

Total Work Orders Printed:



Appendix A-3 - Discharge Work Orders - Blending







KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0255	10725 OLD TAYLORSVILLE RD		CHENOWETH RUN	STREAM

Activity Code / Description	WO # Ref		Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2219250	8/22/14	GREEN	OPS CSHIFT	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	08/23/14 01:52	
DISCHARGE		8:44 pm					JTOWN WQTC	DISCHAGE - WATERS	PM	

Discharge Reporting:

Discharge Amount:	117,106 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT IN THE AREA
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	NEGOTIATIONS ARE UNDERWAY TO ALLOW TEMPORARY BLENDING AT THIS LOCATION
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

Plant Details:

DAILY TOTAL PLANT FLOW	8,811,000 GAL	
PEAK PLANT FLOW WHEN BLENDING	13,467,000 GPD	

8/23/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
8/9/14 1:00 am	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0025194 (Cont'd)MSD0255JEFFERSONTOWNCHENOWETH RUNCENT

WO# **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2231197 **OPS ASHIFT GREEN** DOCUMENTED DISREV:RAIN EVENT 9/11/2014 01/14/2007 **BLENDING AT** UNAUTHORIZED 09/11/14 01:01 2:58:00AM JTOWN WQTC DISCHARGE **DISCHAGE - WATERS** PM

Discharge Reporting:

zicona. go i toporanig.	
Discharge Amount:	1,006,453 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO A RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEANUP
Control Zone:	PERMANENT SIGNS ARE POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	NEGOTIATIONS ARE UNDERWAY TO ALLOW TEMPORARY BLENDING AT THIS LOCATION.
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	16,505,000 GPD
DAILY TOTAL PLANT FLOW	8,757,000 GAL

Notifications:

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'

Total Facilities Printed: 1

Total Work Orders Printed: 2



Appendix A-4 - Discharge Work Orders – Waters of the United States







KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08717	3726 FINCASTLE RD		SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2222160	8/27/14	MITCHELL	GRIFFITH	DOCUMENTED	12/15/2007	LACK OF	UNAUTHORIZED	08/27/14 07:50	
DISCHARGE		6:30 pm					SYSTEM	DISCHAGE - WATERS	PM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	2,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 2222176
Control Zone:	CAUTION TAPE AND TEMP SIGNS PLACED
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN THE IOAP
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE

8/28/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
-----------------	--------	---



CAPACITY



Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2231224 **GRIFFITH** MITCHELL DOCUMENTED LACK OF DISREV:RAIN EVENT 9/11/2014 12/15/2007 UNAUTHORIZED 09/11/14 06:17 SYSTEM 2:10:00AM DISCHARGE **DISCHAGE - WATERS** AM

Discharge Reporting:

Biodiange reporting.	
Discharge Amount:	7,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	DISCLN WO# 2232077
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08935-SM	1001 BRECKENRIDGE LN		MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2219455	8/22/14	GRIFFITH	GRIFFITH	DOCUMENTED	11/29/2001	LACK OF	UNAUTHORIZED	08/22/14 11:42	
DISCHARGE		9:09 pm					SYSTEM	DISCHAGE - WATERS	PM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	118,282 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM
Control Zone:	CAUTION TAPE AND TEMPORARY
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE

8/25/14 1:0	00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org'	
-------------	-------	--------	---	--





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2231200		9/11/2014	GRIFFITH	GRIFFITH	DOCUMENTED	11/29/2001	LACK OF	UNAUTHORIZED	09/11/14 11:13	
DISCHARGE			3:45:00AM					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	633,437 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	104231	4119 LEE AVE		CAMP TAYLOR DITCH	GROUND

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2231225	9/11/14	MITCHELL	GRIFFITH	DOCUMENTED	10/23/2007	LACK OF	UNAUTHORIZED	09/11/14 06:29	
DISCHARGE		2:23 am					SYSTEM	DISCHAGE - WATERS	AM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	7,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	DISCLN WO# 2232083
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	108956	7302 FLOYDSBURG RD		FLOYDS FORK	STREAM

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2231205	9/11/14	SINGLETON	OPS ASHIFT	ELIMINATED	12/17/2010	LACK OF	UNAUTHORIZED	09/11/14 09:15	
DISCHARGE		3:00 am					SYSTEM	DISCHAGE - WATERS	AM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	11,250 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS PLACED
Impact:	SEWAGE OBSERVED
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR. MSD HAULED STATION #2231342
Public Notification:	TEMPORARY SIGNS PLACED AROUND AFFECTED AREA

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	13943	4119 LEE AVE		SOUTH FORK	GROUND
				BEARGRASS CREEK	

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2231229	9/11/14	MITCHELL	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF	UNAUTHORIZED	09/10/14 06:30	
DISCHARGE		2:24 am					SYSTEM	DISCHAGE - WATERS	AM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	DISLCN WO# 2232085
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	13946	1600 BELMAR DR		CAMP TAYLOR DITCH	GROUND

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2222140	8/27/14	MITCHELL	GRIFFITH	DOCUMENTED	10/30/2013	LACK OF	UNAUTHORIZED	08/27/14 07:40	
DISCHARGE		6:12 pm					SYSTEM	DISCHAGE - WATERS	PM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	4,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	DISLCN WO# 4349866
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE

8/28/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	
-----------------	--------	---	--





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2231238		9/11/2014	GRIFFITH	MITCHELL	DOCUMENTED	10/30/2013	LACK OF	UNAUTHORIZED	09/11/14 06:23	
DISCHARGE			2:18:00AM					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	DISCLN WO# 2232092
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to

SMH Sewer Manhole 15518 334 MOCKINGBIRD VALLEY RD

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2223558	8/30/14	SINGLETON	OPS BSHIFT	REPAIRED -	08/30/2014	POWER OUTAGE	UNAUTHORIZED	08/30/14 07:20	
DISCHARGE		6:50 pm		EAST	ISSUE		(LG&E)	DISCHAGE - WATERS	PM	
					RESOLVED					

Discharge Reporting:

Discharge Amount:	1,500 GAL
Cause:	TREE FELL ON POWER LINES KNOCKING POWER OUT TO THE STATION
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	GENERATOR INSTALLED UNTIL POWER RESTORED WO#2223559
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

9/2/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org'	
8/28/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	16649	1726 FRASER DR		SOUTH FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2219579	8/22/14	GRIFFITH	GRIFFITH	DOCUMENTED	01/24/2002	LACK OF	UNAUTHORIZED	08/23/14 09:30	
DISCHARGE		8:30 am					SYSTEM	DISCHAGE - WATERS	PM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	4,591 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 2219975
Control Zone:	TEMPORARY SIGNS AND CAUTION TAPE PLACED
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN THE IOAP
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE

8/25/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org'	
8/23/14 1:00 am	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	



CAPACITY

Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2220873 **GRIFFITH FISHER** DOCUMENTED LACK OF DISREV:RAIN EVENT 8/27/2014 01/24/2002 UNAUTHORIZED 08/27/14 07:30 SYSTEM 6:34:00PM DISCHARGE **DISCHAGE - WATERS** PM

Discharge Reporting:

Bioonarge reporting.	
Discharge Amount:	2,221 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 2220873
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE

8/28/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
8/25/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2231206		9/11/2014	GRIFFITH	GRIFFITH	DOCUMENTED	01/24/2002	LACK OF	UNAUTHORIZED	09/11/14 11:15	
DISCHARGE			2:33:00AM					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	9,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	DISCLN WO# 2232033
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	26752	3317 BROWNSBORO RD		MUDDY FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2219251	8/22/14	FISHER	GRIFFITH	DOCUMENTED	04/04/2008	LACK OF	UNAUTHORIZED	08/22/14 11:30	
DISCHARGE		8:03 pm					SYSTEM	DISCHAGE - WATERS	PM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 2219379
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE

8/23/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
8/9/14 1:00 am	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27007	1013 ALTA CIR		MIDDLE FORK	STREAM
				BEARGRASS CREEK	

Activity Code / Description	WO # Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2231216	9/11/14	FIELDS	GRIFFITH	DOCUMENTED	02/05/2014	LACK OF	UNAUTHORIZED	09/12/14 03:40	
DISCHARGE		4:31 am					SYSTEM	DISCHAGE - WATERS	PM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	600 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2231959
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27116	10304 CAVEN AVE		MUD CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2201272		7/27/14	RHODES	HENDERSON	DOCUMENTED	11/15/2011	LACK OF	UNAUTHORIZED	07/27/14 02:30	
DISCHARGE			10:20 am					SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	12,500 GAL
Cause:	RAIN EVENT LACK OF SYSTEM CAPACITY
Clean Up:	MSD PERSONNEL WILL CLEAN AREA UNDER WORK ORDER#2204779
Control Zone:	MSD PERSONNEL PLACED CAUTION TAPE AND SIGNS
Impact:	MSD PERSONNEL OBSERVED SEWAGE
Repair:	LOCATION PART OF MSD IOAP
Public Notification:	MSD PERSONNEL ADVISED BY WAY OF DOOR CARD

7/27/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
7/14/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0078956 (Cont'd)MSD0277DEREK R. GUTHRIEOHIO RIVERWEST

WO# **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2220870 WITTEN DOCUMENTED LACK OF DISREV:RAIN EVENT 8/27/2014 TELLMAN 11/15/2011 UNAUTHORIZED 08/27/14 11:30 SYSTEM 9:56:00PM DISCHARGE **DISCHAGE - WATERS** PM

CAPACITY

Discharge Reporting:

Discharge Reporting.	
Discharge Amount:	15,000 GAL
Cause:	HEAVY RAIN EXCEEDED CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	TAPE & TEMP SIGNS
Impact:	SEWAGE
Repair:	A SOLUTION FOR THIS IS INCLUDED IN THE IOAP
Public Notification:	MSD ADVISED CUSTOMER BY DOOR CARD

8/28/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
-----------------	--------	---



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	28009	9800 HOFELICH LN		CEDAR CREEK	GROUND

Activity Code / Description	WO # Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISDW:DRY WEATHER	2193027	7/12/14	JOHNSON	JOHNSON	REPAIRED -	07/12/2014	GREASE	UNAUTHORIZED	07/12/14 07:12	MAIN
DISCHARGE		6:48 pm			ISSUE		BLOCKAGE	DISCHAGE - WATERS	PM	
					RESOLVED					

Discharge Reporting:

Discharge Amount:	200 GAL
Cause:	GREASE AND ROOTS OBSTRUCTION IN MAIN SEWER
Clean Up:	MSD PERSONNEL CLEANED THE IMPACTED AREA
Control Zone:	MSD PERSONNEL PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA
Impact:	SEWAGE/WATER DISCHARGED FROM MAIN SEWER TO DRAINAGE DITCH
Repair:	WORK ORDER 2193450; ROOT CUT TO REMOVE GREASE AND ROOT OBSTRUCTION
Public Notification:	ADVISED CUSTOMER ON SITE

7/13/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
6/22/14 1:01 am	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28173	3258 RUCKRIEGEL PKY		CHENOWETH RUN	GROUND

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2231210	9/11/14	FISHER	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	09/12/14 10:50	
DISCHARGE		3:48 am					SYSTEM	DISCHAGE - WATERS	AM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	1,400 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2231965
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28551	11401 GRAND AVE		CHENOWETH RUN	STREAM

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2219252	8/22/14	FISHER	GRIFFITH	DOCUMENTED	11/22/2011	LACK OF	UNAUTHORIZED	08/22/14 11:45	
DISCHARGE		8:48 pm					SYSTEM	DISCHAGE - WATERS	PM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 2219380
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

8/23/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
8/9/14 1:00 am	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0025194 (Cont'd)MSD0255JEFFERSONTOWNCHENOWETH RUNCENT

WO# **Disch Status Activity Code / Description** Ref No Initiated Initiated By **Assigned To Event Date Problem** Result Completed Condition 2231214 **GRIFFITH FISHER** DOCUMENTED LACK OF DISREV:RAIN EVENT 9/11/2014 11/22/2011 UNAUTHORIZED 09/12/14 11:03 SYSTEM 3:03:00AM DISCHARGE DISCHAGE - WATERS AM

CAPACITY

Discharge Reporting:

Discharge reporting.	
Discharge Amount:	1,600 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	WO# 2231967
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OT TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45796	1011 ALTA CIR		MIDDLE FORK	DITCH
				BEARGRASS CREEK	

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2231217		9/11/14	FIELDS	GRIFFITH	DOCUMENTED	05/10/2014	LACK OF	UNAUTHORIZED	09/12/14 03:40	
DISCHARGE			4:30 am					SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	600 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2231969
Control Zone:	CAUTION TAPE AND TEMMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45835	1132 ROSTREVOR CIR		MIDDLE FORK	GROUND
				BEARGRASS CREEK	

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2231215		9/11/14	FIELDS	GRIFFITH	DOCUMENTED	09/02/2003	LACK OF	UNAUTHORIZED	09/11/14 03:31	
DISCHARGE			4:20 am					SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	48,500 GAL
Cause:	LACK OF SYSTEM CAPACTIY-HEAVY RAIN.
Clean Up:	WO# 2231958
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47582	201 BULLITT LN		MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO # Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2231424	9/11/14	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF	UNAUTHORIZED	09/11/14 11:06	
DISCHARGE		4:50 am					SYSTEM	DISCHAGE - WATERS	AM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	6,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	DISCLN WO# 2232032
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47583	202 OXMOOR LN		MIDDLE FORK	STREAM
				BEARGRASS CREEK	

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2231418		9/11/14	FIELDS	GRIFFITH	DOCUMENTED	02/06/2008	LACK OF	UNAUTHORIZED	09/11/14 11:06	
DISCHARGE			4:50 am					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	6,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 2232030
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	51594	1418 TREVILIAN WAY		SOUTH FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2193300	7/13/14	MITCHELL	GRIFFITH	DOCUMENTED	09/12/2006	LACK OF	UNAUTHORIZED	07/14/14 01:15	
DISCHARGE		10:50 pm					SYSTEM	DISCHAGE - WATERS	AM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	1,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 2193665
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE

7/14/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
7/13/14 1:00 am	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# **Disch Status Activity Code / Description** Ref No Initiated Initiated By **Assigned To Event Date Problem** Result Completed Condition **GRIFFITH** MITCHELL DOCUMENTED LACK OF DISREV:RAIN EVENT 2211880 8/8/2014 09/12/2006 UNAUTHORIZED 08/09/14 12:00

DISCHARGE 8:35:00AM SYSTEM DISCHAGE - WATERS PM CAPACITY

Discharge Reporting:

Discharge Amount:	22,500 GAL			
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN			
Clean Up:	DISCLN # 2212180			
Control Zone:	CAUTION TAPE AND TEMP SIGNS PLACED			
Impact:	LIGHT DEBRIS OBSERVED			
Repair:	LOCATION INCLUDED IN THE IOAP			
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE			

8/9/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
7/30/14 1:00 am	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2222148 **GRIFFITH** MITCHELL DOCUMENTED LACK OF DISREV:RAIN EVENT 8/27/2014 09/12/2006 UNAUTHORIZED 08/27/14 07:10

DISCHARGE 6:00:00PM SYSTEM DISCHAGE - WATERS PM CAPACITY

Discharge Reporting:

2.com.igg.				
Discharge Amount:	3,000 GAL			
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN			
Clean Up:	DISCLN WO# 2222152			
Control Zone:	CAUTION TAPE AND TEMP SIGNS PLACED			
Impact:	LIGHT DEBRIS OBSERVED			
Repair:	LOCATION INCLUDED IN THE IOAP			
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE			

8	3/28/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	
---	-----------------	--------	---	--





KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# **Disch Status Activity Code / Description** Ref No Initiated Initiated By **Assigned To Event Date Problem** Result Completed Condition 2231428 **GRIFFITH** MITCHELL DOCUMENTED LACK OF DISREV:RAIN EVENT 9/11/2014 09/12/2006 UNAUTHORIZED 09/11/14 05:29 SYSTEM 2:02:00AM DISCHARGE DISCHAGE - WATERS AM

CAPACITY

Discharge Reporting:

Discharge Amount:	2,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	DISCLN WO# 2232095
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	62412E-AG	4640 BARBOUR LN		LITTLE GOOSE CREEK	GROUND

Activity Code / Description	WO # Ref I	<u>lo</u> <u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
DISDW:DRY WEATHER	2234689	9/22/14	MARKS JR	OPS BSHIFT	REPAIRED -	09/22/2014	STRUCTURAL	UNAUTHORIZED	09/22/14 05:20	
DISCHARGE		9:25 am		EAST	ISSUE		FAILURE	DISCHAGE - WATERS	PM	
					RESOLVED					

Discharge Reporting:

Discharge Amount:	240,600 GAL
Cause:	FORCE MAIN BREAK
Clean Up:	CONTRACTOR CLEANED & SANITIZED THE AREA
Control Zone:	TAPE & TEMPORARY SIGNS PLACED AROUND AFFECTED AREA
Impact:	SEWAGE, PERSONAL HYGIENE PRODUCTS & DISCOLORATION IN STREAM OBSERVED
Repair:	CONTRACTOR REPAIRED FORCE MAIN
Public Notification:	ADVISED PROPERTY OWNER TO AVOID CONTACT WITH SEWAGE

9/22/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/18/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65633	4640 BARBOUR LN		LITTLE GOOSE CREEK	STREAM

Activity Code / Description	WO# Re	f No Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISDW:DRY WEATHER	2234908	9/22/14	MARKS JR	OPS BSHIFT	DOCUMENTED	04/04/2008	STRUCTURAL	UNAUTHORIZED	09/22/14 10:40	
DISCHARGE		6:40 pm		EAST			FAILURE	DISCHAGE - WATERS	PM	

Discharge Reporting:

Discharge Amount:	33,200 GAL
Cause:	BROKEN FORCE MAIN
Clean Up:	CONTRACTOR CLEANED & SANITIZED THE AREA
Control Zone:	TAPE & TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA
Impact:	SEWAGE & DISCOLORATION IN STREAM OBSERVED
Repair:	CONTRACTOR REPAIRED FORCE MAIN
Public Notification:	ADVISED PROPERTY OWNER TO AVAOID CONTACT WITH SEWAGE

9/23/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	
9/22/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	66349	3726 FINCASTLE RD		CAMP TAYLOR DITCH	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2231220		9/11/14 2:11	MITCHELL	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	09/11/14 06:18	
DISCHARGE			am					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	DISCLN WO# 2232075
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOFITIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	69070B-AG	7001 U S HIGHWAY 42		LITTLE GOOSE CREEK	GROUND

Activity Code / Description	WO# Ref N	o Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISDW:DRY WEATHER	2233800	9/18/14	MARKS JR	COOPER II	REPAIRED -	09/18/2014	STRUCTURAL	UNAUTHORIZED	09/18/14 04:30	
DISCHARGE		8:30 am			ISSUE		FAILURE	DISCHAGE - WATERS	PM	
					RESOLVED					

Discharge Reporting:

Discharge Amount:	200 GAL
Cause:	suspected failure of forcemain
Clean Up:	contractor to clean affected area
Control Zone:	temp signs posted
Impact:	sewage
Repair:	contractor fixing pipe
Public Notification:	MSD USED SIGNS TO WARN PUBLIC





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	e	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sew	er Service Line	70388	4805 MID DR		PONDER CREEK	GROUND

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISDW:DRY WEATHER	2233827		9/18/14	MARINO	MARINO	REPAIRED -	01/31/2005	OBSTRUCTION-N	UNAUTHORIZED	09/18/14 11:50	MAIN
DISCHARGE			11:15 am			ISSUE		OT GREASE /	DISCHAGE - WATERS	AM	
						RESOLVED		ROOTS			

Discharge Reporting:

Discharge Amount:	100 GAL
Cause:	OBSTRUCTION IN MAIN SEWER
Clean Up:	MSD PERSONNEL CLEANED THE IMPACTED AREA
Control Zone:	ADVISED CUSTOMER TO AVOID CONTACT WITH IMPACTED AREA
Impact:	SEWAGE AROUND CLEANOUT DISCHARGE IN DITCH LINE
Repair:	WORK ORDER 2233817; FLUSHED MAIN SEWER
Public Notification:	ADVISED CUSTOMER ON SITE

9/18/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	
-----------------	--------	---	--





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SND Sewer Node	72620-ST	201 W RIVER RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISDW:DRY WEATHER	2233517		9/17/14	SINGLETON	OPS BSHIFT	REPAIRED -	09/17/2014	MECHANICAL	UNAUTHORIZED	09/17/14 11:54	
DISCHARGE			11:52 am		CENTRAL	ISSUE		FAILURE	DISCHAGE - WATERS	AM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	100 GAL
Cause:	CLEAN OUT CAP FAILED. RIVER WATER PUMPED
Clean Up:	NO DEBRIS
Control Zone:	NO CONTROL ZONE
Impact:	NO IMPACT OBSERVED
Repair:	REPLACED CLEAN OUT PLUG
Public Notification:	NO PUBLIC NOTIFICATION

9/17/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/11/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	CSO020	147 BUCHANAN ST		OHIO RIVER	STREAM

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2207547	7/26/14	FRENCH	THOMPSON	REPAIRED -	07/29/2014	ELECTRICAL	UNAUTHORIZED	07/29/14 10:00	
DISCHARGE		10:30 pm			ISSUE		PROBLEMS AT	DISCHAGE - WATERS	AM	
					RESOLVED		MSD			

Discharge Reporting:

Discharge Amount:	110,000,000 GAL
Cause:	SCADA MALFUNCTION. POWER RELATED PROBLEM AT STARKEY PS NOT REPORTED THROUGH SCADA SYSTEM DUE TO MALFUNCTION.
Clean Up:	PIPE DISCHARGE SUBMERGED
Control Zone:	PERMANENT SIGNS POSTED ALONG THE OHIO RIVER
Impact:	PIPE DISCHARGE SUBMERGED
Repair:	STATION RESTORED, RESET VFD, REBOOT PC FOR SCADA SYSTEM
Public Notification:	PERMANENT SIGNS POSTED ALONG THE OHIO RIVER

7/30/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org'	
-----------------	--------	---	--





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	CSO082	1339 LEXINGTON RD		SOUTH FORK	
				BEARGRASS CREEK	

Activity Code / Description	WO # Re	ef No Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2207550	7/26/14	FRENCH	THOMPSON	REPAIRED -	07/29/2014	ELECTRICAL	UNAUTHORIZED	07/29/14 10:00	
DISCHARGE		10:30 pm			ISSUE		PROBLEMS AT	DISCHAGE - WATERS	AM	
					RESOLVED		MSD			

Discharge Reporting:

Discharge Amount:	10,000,000 GAL
Cause:	SCADA MALFUNCTION. POWER RELATED PROBLEM AT STARKEY PS NOT REPORTED THROUGH SCADA SYSTEM DUE TO
	MALFUNCTION.
Clean Up:	PIPE DISCHARGE SUBMERGED
Control Zone:	PERMANENT SIGNS POSTED ALONG THE OHIO RIVER
Impact:	PIPE DISCHARGE SUBMERGED
Repair:	STATION RESTORED, RESET VFD, REBOOT PC FOR SCADA SYSTEM
Public Notification:	PERMANENT SIGNS POSTED ALONG THE OHIO RIVER

7/30/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org'
-----------------	--------	---





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	KK14815019	4108 LEE AVE		CAMP TAYLOR DITCH	GROUND

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
DISREV:RAIN EVENT	2222138	8/27/14	MITCHELL	GRIFFITH	DOCUMENTED	07/29/2009	LACK OF	UNAUTHORIZED	08/27/14 07:45	
DISCHARGE		7:20 pm					SYSTEM	DISCHAGE - WATERS	PM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	200 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN
Clean Up:	DISCLN WO# 2222143
Control Zone:	CAUTION TAPE AND TEMP SIGNS PLACED
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN THE IOAP
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR HANGERS TO AVOID CONTACT WITH DISCHARGE

	8/28/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'	
--	-----------------	--------	---	--



Initiated Jul 01, 2014 12:00 AM thru Sep 30, 2014 11:59 PM

CAPACITY

Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2231237 **GRIFFITH** MITCHELL DOCUMENTED LACK OF DISREV:RAIN EVENT 9/11/2014 07/29/2009 UNAUTHORIZED 09/11/14 06:32 SYSTEM 2:27:00AM DISCHARGE DISCHAGE - WATERS AM

Discharge Reporting:

Diomary Reporting.					
Discharge Amount:	200 GAL				
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.				
Clean Up:	DISCLN WO# 2232089				
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.				
Impact:	LIGHT DEBRIS OBSERVED.				
Repair:	LOCATION INCLUDED IN IOAP				
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.				

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



Initiated Jul 01, 2014 12:00 AM thru Sep 30, 2014 11:59 PM

CAPACITY

Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD0057-LS	806 PINE WAY	ANCHOR ESTATES #2	MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO # Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2231234	9/11/14	SINGLETON	OPS BSHIFT	DOCUMENTED	12/16/2000	LACK OF	UNAUTHORIZED	09/11/14 08:45	
DISCHARGE		7:40 am		CENTRAL			SYSTEM	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	1,625 GAL
Cause:	LACK OF CAPACITY DUE TO RAIN EVENT
Clean Up:	NO DEBRIS
Control Zone:	TEMPORARY SIGNS PLACED
Impact:	SEWAGE OBSERVED
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONIITOR AND EVALUATE FOR REPAIR
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0255	10725 OLD TAYLORSVILLE RD		CHENOWETH RUN	STREAM

Activity Code / Description	WO # Ref	f No <u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
DISREV:RAIN EVENT	2219250	8/22/14	GREEN	OPS CSHIFT	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	08/23/14 01:52	
DISCHARGE		8:44 pm					JTOWN WQTC	DISCHAGE - WATERS	PM	

Discharge Reporting:

Discharge Amount:	117,106 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT IN THE AREA
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	NEGOTIATIONS ARE UNDERWAY TO ALLOW TEMPORARY BLENDING AT THIS LOCATION
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

Plant Details:

DAILY TOTAL PLANT FLOW	8,811,000 GAL	
PEAK PLANT FLOW WHEN BLENDING	13,467,000 GPD	

8/23/14 1:00 am	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
8/9/14 1:00 am	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'



DISCHAGE - WATERS

PM

JTOWN WQTC



Report Selections: Period: 07/01/2014 00:00 thru 09/30/2014 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0025194 (Cont'd)MSD0255JEFFERSONTOWNCHENOWETH RUNCENT

WO# **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2231197 **OPS ASHIFT GREEN** DOCUMENTED DISREV:RAIN EVENT 9/11/2014 01/14/2007 **BLENDING AT** UNAUTHORIZED 09/11/14 01:01

DISCHARGE 2:58:00AM

Discharge Reporting:

z.coa. goopo.tg.	
Discharge Amount:	1,006,453 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO A RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEANUP
Control Zone:	PERMANENT SIGNS ARE POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	NEGOTIATIONS ARE UNDERWAY TO ALLOW TEMPORARY BLENDING AT THIS LOCATION.
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	16,505,000 GPD
DAILY TOTAL PLANT FLOW	8,757,000 GAL

Notifications:

9/11/14 1:00 pm	DISNOT	Email notification of unauthorized discharge sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'
9/2/14 1:00 pm	DISSNO	Supplemental Email notification of unauthorized discharge has been sent to 'DischargeNotices@louisvillemsd.org, Sayre.Dennis@epamail.epa.gov'

Total Facilities Printed: 30

Total Work Orders Printed: 42

10/6/2014 Page 42 of 42 3:50:05 PM