

COMMONWEALTH OF KENTUCKY

NATURAL RESOURCES AND ENVIRONMENTAL PROTECTION CABINET DEPARTMENT FOR ENVIRONMENTAL PROTECTION

FRANKFORT OFFICE PARK 14 REILLY RD FRANKFORT KY 40601

MAY 2 4 2002

Eric G. Brady, Project Coordinator Louisville and Jefferson County MSD 700 West Liberty Street Louisville, Kentucky 40203-1911

e: Ken Carla WWTP

KPDES No.: KY0022497 Jefferson County, Kentucky

Dear Mr. Brady:

Enclosed is the Kentucky Pollutant Discharge Elimination System (KPDES) permit for the above-referenced facility. This action constitutes a final permit issuance under 401 KAR 5:075, pursuant to KRS 224.16-050.

This permit will become effective on the date indicated in the attached permit provided that no request for adjudication is granted. All provisions of the permit will be effective and enforceable in accordance with 401 KAR 5:075, unless stayed by the Hearing Officer under Sections 11 and 13.

Any demand for a hearing on the permit shall be filed in accordance with the procedures specified in KRS 224.10-420, 224.10-440, 224.10-470 and any regulations promulgated thereto. Any person aggrieved by the issuance of a permit final decision may demand a hearing, pursuant to KRS 224.10-420(2), within thirty (30) days from the date of the issuance of this letter. Two (2) copies of request for hearing should be submitted in writing to the Natural Resources and Environmental Protection Cabinet, Office of Administrative Hearings, 35-36 Fountain Place, Frankfort, Kentucky 40601 and the Commonwealth of Kentucky, Natural Resources and Environmental Protection Cabinet, Division of Water, 14 Reilly Road, Frankfort, Kentucky 40601. For your record keeping purposes, it is recommended that these requests be sent by certified mail. The written request must conform to the appropriate statutes referenced above.

If you have any questions regarding the KPDES decision, please contact Courtney Seitz, Inventory and Data Management Section, KPDES Branch, at (502) 564-2225, extension 465.

Further information on procedures and legal matters pertaining to the hearing request may be obtained by contacting the Office of Administrative Hearings at (502) 564-7312.


Sincerely,


Jeffrey W. Pratt, Director Division of Water

JWP:NG:ng Enclosure

c: Louisville Regional Office Division of Water Files







KENTUCKY POLLUTANT
DISCHARGE ELIMINATION
SYSTEM

PERMIT

PERMIT NO.: KY0022497

AUTHORIZATION TO DISCHARGE UNDER THE KENTUCKY POLLUTANT DISCHARGE ELIMINATION SYSTEM

Pursuant to Authority in KRS 224,

Louisville & Jefferson County MSD 700 West Liberty Street Louisville, Kentucky 40203-1911

is authorized to discharge from a facility located at

Ken Carla Wastewater Treatment Plant Lynhall Road Prospect, Jefferson County, Kentucky

to receiving waters named

Harrods Creek / Mile point 1.43

in accordance with effluent limitations, monitoring requirements, and other conditions set forth in PARTS I, II, and III hereof. The permit consists of this cover sheet and PART I $\underline{2}$ pages, PART II $\underline{1}$ page, and PART III $\underline{1}$ page.

This permit shall become effective on October 1, 2002.

This permit and the authorization to discharge shall expire at midnight, September 30, 2007.

WAY 2 4 2002

Date Signed

Jeffrey W. Pratt, Director Division of Water

Robert W. Logan Commissioner

DEPARTMENT FOR ENVIRONMENTAL PROTECTION
Division of Water, Frankfort Office Park, 14 Reilly Road, Frankfort, Kentucky 40601

PART I Page I-1

Permit No.: KY0022497

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning on the effective date of this permit and lasting through the term of this permit, the permittee is authorized to discharge from outfall(s) serial number(s): 001, Sanitary Wastewater.

Such discharges shall be limited and monitored by the permittee as specified below:

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS lbs/day Other Units(Specify			Engai ful	MONITORING REQUIREMENTS		
	Monthly Avg.	Daily Max.	Monthly Avg.	Daily Max.	Measurement Frequency	Sample Type	Sampling Location
Flow, Design (0.010 mgd)	N/A	N/A	Report	Report	5/week	Instantaneous	Influent or Effluent
Biochemical Oxygen Demand							ETTTUENC
(5-day)	2.50	5.00	30 mg/l	60 mg/l	1/month	Composite	Effluent
Total Suspended Solids	2.50	5.00	30 mg/l	60 mg/l	1/month	Composite	Effluent
Fecal Coliform Bacteria, N/100	N/A	N/A	200	400	1/month	Grab	Effluent
Ammonia (as N)	1.67	3.34	20 mg/l	40 mg/l	1/month	Composite	Effluent
Phosphorus, Total (as P)	N/A	N/A	Report	Report	1/month	Composite	Effluent
Dissolved Oxygen shall not be less than 2 mg/l					1/month	Grab	Effluent

The pH of the effluent shall not be less than 6.0 standard units nor greater than 9.0 standard units and shall be monitored once per month by grab sample.

There shall be no discharge of floating solids or visible foam in other than trace amounts.

The effluent shall not cause a visible sheen on the receiving water.

PART I
Page I-2
Permit No.: KY0022497

B. Schedule of Compliance

- 1. The permittee shall achieve compliance with all requirements on the effective date of this permit.
- 2. This treatment unit is temporary and in no way supersedes the need of a regional sewer system. The permittee will eliminate the discharge and treatment unit by connection to a regional sewer system when it becomes available as defined in 401 KAR 5:002.

PART II
Page II-1
Permit No.: KY0022497

STANDARD CONDITIONS FOR KPDES PERMIT

The permittee is also advised that all KPDES permit conditions in KPDES Regulation 401 KAR 5:065, Section 1, will apply to all discharges authorized by this permit.

This permit has been issued under the provisions of KRS Chapter 224 and regulations promulgated pursuant thereto. Issuance of this permit does not relieve the permittee from the responsibility of obtaining any other permits or licenses required by this Cabinet and other state, federal, and local agencies.

It is the responsibility of the permittee to demonstrate compliance with permit parameter limitations by utilization of sufficiently sensitive analytical methods.

PART III
Page III-1

Permit No.: KY0022497

PART III

OTHER REQUIREMENTS

A. Reporting of Monitoring Results

Monitoring results obtained during each quarter must be summarized and reported on a preprinted Discharge Monitoring Report (DMR) form, which will be mailed to you. Each quarter's completed DMR must be mailed to the Division of Water at the address listed below (with a copy to the appropriate Regional Office) postmarked no later than the 28th day of the month following the completed quarter.

Division of Water Louisville Regional Office 9116 Leesgate Road Louisville, Kentucky 40222-5084 Attn: Supervisor

Kentucky Natural Resources and Environmental Protection Cabinet Dept. for Environmental Protection Division of Water/KPDES Branch 14 Reilly Road, Frankfort Office Park Frankfort, Kentucky 40601

B. Reopener Clause

This permit shall be modified, or alternatively revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under 401 KAR 5:050 through 5:080 and KRS 224 if the effluent standard or limitation so issued or approved:

- 1. Contains different conditions or is otherwise more stringent than any effluent limitation in the permit; or
- Controls any pollutant not limited in the permit.

The permit as modified or reissued under this paragraph shall also contain any other requirements of KRS Chapter 224 when applicable.



COMMONWEALTH OF KENTUCKY

NATURAL RESOURCES AND ENVIRONMENTAL PROTECTION CABINET DEPARTMENT FOR ENVIRONMENTAL PROTECTION

FRANKFORT OFFICE PARK 14 REILLY RD FRANKFORT KY 40601

STATEMENT OF BASIS

KPDES No.: KY0022497 Permit Writer: Herb Ray

Date: April 10, 2002

Facility Name:

Ken Carla Wastewater Treatment Plant

Facility Location:

Lynhall Road

Prospect, Jefferson County, Kentucky

Permitting Action:

This is a reissuance of a permit for a

subdivision.

Permit Duration:

Expires September 30, 2007. This expiration date will place the facility in the correct 5-year cycle as per the Kentucky Watershed Management Framework. In this instance, the permit is scheduled for reissuance in October 2007 for the Salt/Licking Basin Management Unit. Facility should be eliminated before this date.

Receiving Stream:

Harrods Creek /Mile point 1.43

Stream Segment Use Classification:

Warmwater Aquatic Habitat and Primary/Secondary Contact Recreation. Receiving stream has been listed as impaired for organic enrichment/low DO. An approved TMDL is in place and efforts to remove package plants such as this one are underway. This plant is scheduled for

elimination in 2005.

Stream Low Flow Condition:

NA - Ohio River Backwater

Justification of Permit Conditions:

The following regulations are pursuant to KRS 224.70-100 and KRS 224.70-110.

Biochemical Oxygen Demand (5-day), Total Suspended Solids, Fecal Coliform, and pH The effluent limitations for the above permit parameters are consistent with 401 KAR 5:045.

Ammonia Nitrogen, Phosphorus, and Dissolved Oxygen
The effluent limitations for the above permit parameters are consistent with 401 KAR
5:031. Phosphorus is "monitor and report only".

Antidegradation:

The conditions of 401 KAR 5:029, Section 1(1) have been satisfied by this permit action. A review under Section 1(2), (3), and (4) is not applicable.

ţm

