

Appendix A-1 - Discharge Work Orders - Dry Weather CSOs







KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411MSD0278MORRIS FORMANOHIO RIVERWEST

Facility Type Facility ID Facility Address If Pump Station, Name of Pump Station: Receiving Stream Discharge to
SMH Sewer Manhole CSO113 1215 ELLISON AVE OHIO RIVER STREAM

Activity Code / Description WO # Ref No Initiated Initiated By Assigned To **Disch Status Event Date Problem** Result Completed Condition UNAUTHORIZED : DISDW: DRY WEATHER 2429237 09/14/2015 **MARDIS BRIGHT** REPAIRED -09/14/2015 **OBSTRUCTION-N** 09/14/15 08:30 DISCHARGE ISSUE OT GREASE / DISCHAGE - WATERS AM **RESOLVED** ROOTS

Discharge Reporting:

Discharge Amount:	450 GAL
Cause:	OBSTRUCTION IN MAIN SEWR
Clean Up:	FLUSHED THE LINE
Control Zone:	N/A
Impact:	NONE
Repair:	OPENED BY FLUSHING THE LINE
Public Notification:	N/A

Notifications:

9/3/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/3/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 1

Total Work Orders Printed:



Appendix A-2 - Discharge Work Orders - Bypass







KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0202	5500 HITT RD		HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387485		07/12/2015	MARKS JR	OPS BSHIFT	REPAIRED -	09/27/2015	BYPASS AT	UNAUTHORIZED	07/12/15 01:15	
DISCHARGE					EAST	ISSUE		WQTC	DISCHAGE - WATERS	PM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	157,500 GAL
Cause:	RAIN EVENT CAUSED CREEK TO FLOOD WET WELL
Clean Up:	MSD CLEANED & SANITIZED
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO VISUAL IMPACT
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420 (Cont'd)	MSD0202	HITE CREEK	HITE CREEK	EAST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2388696		7/14/2015	OPS BSHIFT	SINGLETON	REPAIRED -	09/27/2015	BYPASS AT	UNAUTHORIZED	07/14/15 07:20	
DISCHARGE			5:42:00AM	EAST		ISSUE		WQTC	DISCHAGE - WATERS	AM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	49,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED AREA
Control Zone:	TEMPORARY SIGNS PLACED
Impact:	NO VISUAL IMPACT
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420 (Cont'd)	MSD0202	HITE CREEK	HITE CREEK	EAST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISDWDRY WEATHER	2434538		9/26/2015	OPS BSHIFT	MARKS JR	REPAIRED -	09/27/2015	BYPASS AT	UNAUTHORIZED	09/27/15 12:45	
DISCHARGE			10:59:00PM	EAST		ISSUE		WQTC	DISCHAGE - WATERS	AM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	49,074 GAL
Cause:	COMMUNICATION FAILURE OF UV SYSTEM
Clean Up:	NO CLEAN UP REQUIRED MOSTLY TREATED FLOW DISCHARGED AT PLANT EFFLUENT
Control Zone:	PERMANENT SIGNS POSTED ALONG IMPACTED STREAM
Impact:	MOSTLY TREATED FLOW DISCHARGED AT PLANT EFFLUENT - NO UV DISINFECTION OCCURRED
Repair:	OPERATOR INSTALLED SLIDE GATE UNTIL ELETRICAL REPAIRS WERE COMPLETED
Public Notification:	PUBLIC NOTIFIED WITH PERMANENT SIGNS POSTED AT TREATMENT PLANT OUTFALL

9/19/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO
		DISCHARGENOTICE@LOUISVILLEMSD.ORG,SAYRE.DENNIS@EPAMAIL.EPA.GOV,EPPC.ERT@KY.GOV,CHARLIE.ROTH@KY.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0036501	MSD0209	BERRYTOWN	FLOYDS FORK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0209	1203 HEAFER RD		FLOYDS FORK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387497		07/12/2015	MARKS JR	OPS BSHIFT	DOCUMENTED	02/02/2011	BYPASS AT	UNAUTHORIZED	07/13/15 01:40	
DISCHARGE					CENTRAL			WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	38,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SOLIDS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AT THIS LOCATION

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Initiated Jul 01, 2015 12:00 AM thru Sep 30, 2015 11:59 PM

Report Selections: Period: 07/01/2015 00:00 thru 09/30/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Prob Code: BYPAS, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0036501 (Cont'd)	MSD0209	BERRYTOWN	FLOYDS FORK	CENT

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2389577		7/14/2015	OPS BSHIFT	SINGLETON	DOCUMENTED	02/02/2011	BYPASS AT	UNAUTHORIZED	07/14/15 05:45	
DISCHARGE			1:30:00PM	CENTRAL				WQTC	DISCHAGE - WATERS	PM	

Discharge Reporting:

Discharge Amount:	1,425 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS LOCATED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0029416	MSD0228	MCNEELY LAKE	PENNSYLVANIA RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0228	10300 ROD N REEL RD		PENNSYLVANIA RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER	2391494		07/18/2015	MARKS JR	OPS BSHIFT	REPAIRED -	07/18/2015	BYPASS AT	UNAUTHORIZED	07/18/15 01:30	
DISCHARGE					CENTRAL	ISSUE		WQTC	DISCHAGE - WATERS	PM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	8,000 GAL
Cause:	LOST POWER DUE TO POWER LINES BEING ON FIRE.
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE AND SOLIDS OBSERVED
Repair:	INSTALLED GENERATOR TO STOP BYPASS
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0289	8605 CEDAR CREEK RD		CEDAR CREEK	GROUND

Activity Code / Description	<u>WO #</u>	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387653		07/12/2015	SINGLETON	OPS BSHIFT	REPAIRED -	07/12/2015	BYPASS AT	UNAUTHORIZED	07/12/15 09:00	
DISCHARGE					CENTRAL	ISSUE		WQTC	DISCHAGE - WATERS	PM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	FILTER BYPASS GATE FAILED TO OPEN IN AUTO
Clean Up:	NO DEBRIS
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED
Repair:	OPERATOR OPENED BYPASS GATE MANUALLY
Public Notification:	PERMANENT SIGNS POSTED AT THIS LOCATION

7/13/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022420MSD0202HITE CREEKHITE CREEKEAST

Facility Type Facility ID Facility Address If Pump Station, Name of Pump Station: Receiving Stream Discharge to

SPL Sewer Treatment Plant MSD0291 9810 U S HIGHWAY 42 HITE CREEK STREAM

WO # **Activity Code / Description** Ref No Initiated **Initiated By Assigned To Disch Status Event Date Problem** Result Completed Condition : DISREV: RAIN EVENT 2387500 07/12/2015 MARKS JR **OPS BSHIFT** REPAIRED -12/24/2013 BYPASS AT UNAUTHORIZED 07/13/15 12:15 DISCHARGE **EAST** ISSUE WQTC DISCHAGE - WATERS AM **RESOLVED**

Discharge Reporting:

Discharge Amount:	1,325,490 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SOLIDS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

Notifications:

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 5

Total Work Orders Printed: 8



Appendix A-3 - Discharge Work Orders - Blending







KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0255	10725 OLD TAYLORSVILLE RD		CHENOWETH RUN	STREAM

Activity Code / Description	WO # Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2382474	07/03/2015	GREEN	OPS BSHIFT	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	07/04/15 01:28	
DISCHARGE				CENTRAL			JTOWN WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	359,280 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED
	DURING WET WEATHER.
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

Plant Details:

DAILY TOTAL PLANT FLOW	13,665,000 GAL
PEAK PLANT FLOW WHEN BLENDING	12,070,000 GPD

Notifications:

6/30/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
6/30/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

10/6/2015 Page 1 of 6 5:03:41 PM





KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0025194 (Cont'd)MSD0255JEFFERSONTOWNCHENOWETH RUNCENT

WO # **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2387007 **SINGLETON** DOCUMENTED : DISREVRAIN EVENT 7/10/2015 **OPS BSHIFT** 01/14/2007 **BLENDING AT** UNAUTHORIZED 07/11/15 12:50 12:03:00PM CENTRAL JTOWN WQTC DISCHARGE **DISCHAGE - WATERS** AM

Discharge Reporting:

Discharge Amount:	564,375 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED AT THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER.
Public Notification:	PERMANENT SIGNS HAVE BEEN POSTED AT THIS LOCATION

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	12,917,000 GPD
DAILY TOTAL PLANT FLOW	13,595,000 GAL

7/8/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/8/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2387491		7/12/2015	OPS BSHIFT	MARKS JR	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	07/13/15 03:06	
DISCHARGE			7:39:00AM	CENTRAL				JTOWN WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	3,425,126 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	NO CLEANUP- PIPE DISCHARGE SUBMERGED
Control Zone:	PERMANENT SIGN POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED AT THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER.
Public Notification:	PERMANENT SIGNS HAVE BEEN POSTED AT THIS LOCATION.

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	16,306,000 GPD
DAILY TOTAL PLANT FLOW	19,257,000 GAL

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0025194 (Cont'd)MSD0255JEFFERSONTOWNCHENOWETH RUNCENT

WO# **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2388137 **OPS CSHIFT** MARKS JR DOCUMENTED : DISREVRAIN EVENT 7/13/2015 01/14/2007 **BLENDING AT** UNAUTHORIZED 07/15/15 07:53 3:44:00PM JTOWN WQTC DISCHARGE DISCHAGE - WATERS AM

Discharge Reporting:

Discharge Amount:	3,870,550 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED AT THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER
Public Notification:	PERMANENT SIGNS POSTED AT THIS LOCATION

Plant Details:

DAILY TOTAL PLANT FLOW	28,262,000 GAL
PEAK PLANT FLOW WHEN BLENDING	14,537,000 GPD

7/13/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/13/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2391429		7/18/2015	OPS ASHIFT	MARKS JR	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	07/18/15 05:23	
DISCHARGE			2:21:00AM					JTOWN WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	107,109 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	13,621,000 GPD
DAILY TOTAL PLANT FLOW	7,511,000 GAL

7/15/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/15/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0025194 (Cont'd)MSD0255JEFFERSONTOWNCHENOWETH RUNCENT

WO# **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2436657 **SINGLETON** DOCUMENTED : DISREVRAIN EVENT 9/29/2015 **OPS BSHIFT** 01/14/2007 **BLENDING AT** UNAUTHORIZED 09/29/15 04:40 CENTRAL 11:03:00AM JTOWN WQTC DISCHARGE **DISCHAGE - WATERS** PM

Discharge Reporting:

Discharge Amount:	382,797 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED AT THIS PLANT
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER
Public Notification:	PERMANENT SIGNS ARE POSTED AROUND THE AFFECTED AREA

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	15,507,000 GPD
DAILY TOTAL PLANT FLOW	5,956,000 GAL

Notifications:

9/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 1

Total Work Orders Printed: 6



Appendix A-4 - Discharge Work Orders - Waters of the United States







KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	00746	804 N ARBOR DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387533		07/12/2015	MARKS JR	OPS CSHIFT	DOCUMENTED	12/16/2000	LACK OF	UNAUTHORIZED	07/13/15 02:00	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	11,550 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	SEE WO#2389001
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AT THIS LOCATION

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2389001		7/14/2015	OPS BSHIFT	SINGLETON	DOCUMENTED	12/16/2000	LACK OF	UNAUTHORIZED	07/15/15 03:45	
DISCHARGE			8:56:00AM	CENTRAL				SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	89,175 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION CA BE FOUND IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	00817	806 PINE WAY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2388619		07/13/2015	MARKS JR	OPS CSHIFT	DOCUMENTED	12/05/2011	LACK OF	UNAUTHORIZED	07/13/15 06:20	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	525 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	SEE WO#2388993
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/13/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/13/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	01793	9 MUIRFIELD PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387527		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/13/15 08:21	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388642
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	02933	7900 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387502		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	07/15/15 06:13	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388634
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	02935	7900 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387499		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF	UNAUTHORIZED	07/15/15 06:09	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388633
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08426	4315 PRUITT CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387549		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/25/2011	LACK OF	UNAUTHORIZED	07/12/15 12:48	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387631
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facilit	у Туре	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMF	H Sewer Manhole	08427	4313 PRUITT CT		OHIO RIVER	STREAM

Activity Code / Description	<u>WO #</u>	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387546		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/25/2011	LACK OF	UNAUTHORIZED	07/12/15 12:47	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387607
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08431	4339 PRUITT CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387550		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/25/2011	LACK OF	UNAUTHORIZED	07/12/15 12:54	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	300 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387634
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08717	3726 FINCASTLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387050		07/10/2015	MITCHELL	GRIFFITH	DOCUMENTED	12/15/2007	LACK OF	UNAUTHORIZED	07/10/15 01:55	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,200 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387117
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/10/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2387556		7/12/2015	GRIFFITH	MITCHELL	DOCUMENTED	12/15/2007	LACK OF	UNAUTHORIZED	07/12/15 11:27	
DISCHARGE			7:24:00AM					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	12,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387637
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2389029		7/14/2015	GRIFFITH	MITCHELL	DOCUMENTED	12/15/2007	LACK OF	UNAUTHORIZED	07/14/15 04:59	
DISCHARGE			5:51:00AM					SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	300 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389801
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2391502		7/18/2015	GRIFFITH	MITCHELL	DOCUMENTED	12/15/2007	LACK OF	UNAUTHORIZED	07/18/15 08:31	
DISCHARGE			1:36:00AM					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391503
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08935-SM	1001 BRECKENRIDGE LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387441		07/12/2015	GRIFFITH	GRIFFITH	DOCUMENTED	11/29/2001	LACK OF	UNAUTHORIZED	07/12/15 05:42	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,379,438 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	102339	9114 CINDERELLA LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2389038		07/14/2015	SINGLETON	OPS BSHIFT	DOCUMENTED	07/14/2015	LACK OF	UNAUTHORIZED	07/14/15 01:20	
DISCHARGE					WEST			SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	8,425 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE, SOLIDS, DEBRIS & PERSONAL HYGIENE PRODUCTS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS LOCATED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	102447A	5500 HITT RD		HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387508		07/12/2015	MARKS JR	OPS BSHIFT	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/13/15 01:00	
DISCHARGE					EAST	APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	9,999 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	REFERENCE #2388159
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE, SOLIDS & DEBRIS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	104223	4103 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387571		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	05/20/2005	LACK OF	UNAUTHORIZED	07/12/15 11:11	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,100 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	WO# 2387691
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2389035		7/14/2015	GRIFFITH	MITCHELL	DOCUMENTED	05/20/2005	LACK OF	UNAUTHORIZED	07/14/15 04:49	
DISCHARGE			5:37:00AM					SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	300 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389803
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	104224	4103 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2389100		07/14/2015	LOGAN JR	GRIFFITH	DOCUMENTED	07/14/2015	LACK OF	UNAUTHORIZED	07/14/15 04:48	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389799
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	104289	3620 CHARLANE PKY		CHENOWETH RUN	STRFAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387472		07/12/2015	FISHER	GRIFFITH	BEYOND	03/10/2015	LACK OF	UNAUTHORIZED	07/14/15 06:30	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387785
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	105936	7713 WESTPORT RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387578		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	07/14/15 05:02	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388664
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

10/6/2015 Page 21 of 152 5:02:47 PM





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	108674	10723 COPPER RIDGE DR		HITE CREEK	STREAM

Activity Code / Description	<u>WO #</u>	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2389570		07/14/2015	SINGLETON	OPS BSHIFT	BEYOND	04/07/2015	LACK OF	UNAUTHORIZED	07/14/15 02:00	
DISCHARGE					EAST	APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE, DEBRIS & PERSONAL HYGIENE PRODUCTS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION CAN BE LOCATED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	115183	208 BRUNSWICK RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387538		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF	UNAUTHORIZED	07/15/15 06:28	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388647
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	115184	208 BRUNSWICK RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387540		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF	UNAUTHORIZED	07/14/15 04:36	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388649
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	115185	207 BRUNSWICK RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387541		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF	UNAUTHORIZED	07/14/15 04:36	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388650
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	11877	5500 HITT RD		HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2388790		07/14/2015	SINGLETON	OPS BSHIFT	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/14/15 05:00	
DISCHARGE					EAST	APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	9,999 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	NO IMPACT OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	13946	1600 BELMAR DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387569		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	10/30/2013	LACK OF	UNAUTHORIZED	07/12/15 11:22	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387802
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO # **Disch Status Event Date** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Problem** Result Completed 2389061 **GRIFFITH** MITCHELL DOCUMENTED LACK OF : DISREVRAIN EVENT 7/14/2015 10/30/2013 UNAUTHORIZED 07/14/15 08:41 SYSTEM 5:42:00AM DISCHARGE DISCHAGE - WATERS AM

Discharge Reporting:

Discharge Amount:	500 GAL	
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.	
Clean Up:	WO# 2389063	
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.	
Impact:	LIGHT DEBRIS OBSERVED.	
Repair:	LOCATION INCLUDED IN IOAP	
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.	

CAPACITY

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	15195	1700 SULGRAVE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387575		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	07/12/2015	LACK OF	UNAUTHORIZED	07/13/15 07:10	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388662
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	16455	1913 CHARBDIN PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387589		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/12/15 04:34	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	30,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387711
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	16649	1726 FRASER DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387910		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	01/24/2002	LACK OF	UNAUTHORIZED	07/12/15 12:15	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387913
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/1	3/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
-----	--------------	--------	---





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	21089A	207 BRUNSWICK RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387539		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/27/2011	LACK OF	UNAUTHORIZED	07/14/15 04:36	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388648
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	21171	4609 BLENHEIM RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387544		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/27/2011	LACK OF	UNAUTHORIZED	07/14/15 04:32	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388657
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	23211	3302 TROUT CREEK DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387559		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/22/2000	LACK OF	UNAUTHORIZED	07/14/15 09:23	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388660
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0036501	MSD0209	BERRYTOWN	FLOYDS FORK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	24012	1203 HEAFER RD		FLOYDS FORK	STREAM

Activity Code / Description	<u>WO #</u>	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2388697		07/14/2015	SINGLETON	OPS BSHIFT	BEYOND	04/12/2011	LACK OF	UNAUTHORIZED	07/15/15 08:00	
DISCHARGE					CENTRAL	APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	39,250 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	24448	4002 BROOKFIELD AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387585		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/23/2011	LACK OF	UNAUTHORIZED	07/14/15 05:50	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387707
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	25017	308 STONEHENGE DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387543		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/27/2011	LACK OF	UNAUTHORIZED	07/14/15 04:31	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388656
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	25484	9317 LANTANA DR		OHIO RIVER	STREAM

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387514		07/12/2015	MARKS JR	OPS BSHIFT	DOCUMENTED	01/13/2013	LACK OF	UNAUTHORIZED	07/12/15 11:40	
DISCHARGE					WEST			SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	3,075 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	SEE WORK ORDER #23889737
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0078956 (Cont'd)MSD0277DEREK R. GUTHRIEOHIO RIVERWEST

WO # **Disch Status Event Date** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Problem** Result Completed 2388937 **SINGLETON** DOCUMENTED LACK OF : DISREVRAIN EVENT 7/14/2015 **OPS BSHIFT** 01/13/2013 UNAUTHORIZED 07/14/15 10:00 SYSTEM 7:28:00AM WEST DISCHARGE DISCHAGE - WATERS AM CAPACITY

Discharge Reporting:

Discharge Amount:	3,800 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE, SOLIDS, PERSONAL HYGIENE PRODUCTS & DEBRIS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS FOUND IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	26752	3317 BROWNSBORO RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387584		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	04/04/2008	LACK OF	UNAUTHORIZED	07/13/15 11:02	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388669
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27007	1013 ALTA CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387484		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	02/05/2014	LACK OF	UNAUTHORIZED	07/15/15 07:39	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388175
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27116	10304 CAVEN AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2383615		07/07/2015	DAVIS	TELLMAN	DOCUMENTED	11/15/2011	LACK OF	UNAUTHORIZED	07/07/15 10:50	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	3,125 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO HEAVY RAINS
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	SEWAGE AND DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/4/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/4/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956 (Cont'd)	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2387241		7/12/2015	BLANFORD	DAVIS	DOCUMENTED	11/15/2011	LACK OF	UNAUTHORIZED	07/12/15 02:15	
DISCHARGE			8:30:00AM					SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	10,125 GAL
Cause:	HEAVY RAIN CAUSED LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	SEWAGE
Repair:	INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0078956 (Cont'd)MSD0277DEREK R. GUTHRIEOHIO RIVERWEST

WO# **Disch Status** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Event Date Problem** Result Completed 2389054 **DAVIS** DOCUMENTED LACK OF : DISREVRAIN EVENT 7/14/2015 DAVIS 11/15/2011 UNAUTHORIZED 07/14/15 02:30 SYSTEM 7:00:00AM DISCHARGE **DISCHAGE - WATERS** PM CAPACITY

Discharge Reporting:

Discharge Amount:	10,500 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS, NOTIFIED CUSTOMER ON SITE

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28173	3258 RUCKRIEGEL PKY		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387474		07/12/2015	FISHER	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	07/14/15 06:50	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387788
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28249	3500 ST EDWARDS DR		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387459		07/12/2015	FISHER	GRIFFITH	DOCUMENTED	03/12/2006	LACK OF	UNAUTHORIZED	07/12/15 05:45	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387778
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28250	3506 CHARLANE PKY		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387457		07/12/2015	FISHER	GRIFFITH	DOCUMENTED	01/03/2005	LACK OF	UNAUTHORIZED	07/14/15 06:35	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387776
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28340	3620 CHARLANE PKY		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387467		07/12/2015	FISHER	GRIFFITH	DOCUMENTED	01/03/2005	LACK OF	UNAUTHORIZED	07/14/15 06:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387782
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28415	3406 DELL RD		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387447		07/12/2015	FISHER	GRIFFITH	DOCUMENTED	12/19/2002	LACK OF	UNAUTHORIZED	07/14/15 09:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	15,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387602
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28416	3501 MARLIN DR		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387449		07/12/2015	FISHER	GRIFFITH	DOCUMENTED	04/04/2008	LACK OF	UNAUTHORIZED	07/14/15 09:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	15,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387605
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28417	3506 DELL RD		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387452		07/12/2015	FISHER	GRIFFITH	DOCUMENTED	04/04/2008	LACK OF	UNAUTHORIZED	07/14/15 09:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	15,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387606
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28451	3406 CHARLANE PKY		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387455		07/12/2015	FISHER	GRIFFITH	BEYOND	04/27/2011	LACK OF	UNAUTHORIZED	07/14/15 06:30	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	7,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387774
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28551	11401 GRAND AVE		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387573		07/12/2015	FISHER	GRIFFITH	DOCUMENTED	11/22/2011	LACK OF	UNAUTHORIZED	07/13/15 05:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	27,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387695
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28711	9514 TAYLORSVILLE RD		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387445		07/12/2015	FISHER	GRIFFITH	BEYOND	04/27/2011	LACK OF	UNAUTHORIZED	07/14/15 06:45	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	27,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387601
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28984	5410 SPRIGWOOD LN		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387239		07/12/2015	DAVIS	BLANFORD	DOCUMENTED	01/24/2002	LACK OF	UNAUTHORIZED	07/12/15 11:48	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	9,650 GAL
Cause:	HEAVY RAIN CAUSED LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	SEWAGE
Repair:	INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28998	5600 HOFELICH CT		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387255		07/12/2015	DAVIS	BLANFORD	DOCUMENTED	01/24/2002	LACK OF	UNAUTHORIZED	07/12/15 10:00	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	6,750 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE TEMP SIGNS
Impact:	SEWAGE
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	29948	6810 SANDSTONE BLVD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387298		07/12/2015	DAVIS	BOND JR	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	07/12/15 12:25	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	6,650 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	SEWAGE DISCOORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0078956 (Cont'd)MSD0277DEREK R. GUTHRIEOHIO RIVERWEST

WO # **Disch Status Event Date** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Problem** Result Completed 2389050 **DAVIS** DOCUMENTED LACK OF : DISREVRAIN EVENT 7/14/2015 BOND JR 03/04/2008 UNAUTHORIZED 07/14/15 08:01 SYSTEM 7:00:00AM DISCHARGE DISCHAGE - WATERS AM CAPACITY

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE
Impact:	PERSONAL HYGIENE PRODUCTS
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS ADVISED CUSTOMERS ON SITE

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	30376	8113 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387534		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	11/29/2011	LACK OF	UNAUTHORIZED	07/14/15 04:20	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388645
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	31074	6808 SANDSTONE BLVD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387302		07/12/2015	DAVIS	BOND JR	DOCUMENTED	02/24/2011	LACK OF	UNAUTHORIZED	07/12/15 12:31	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	6,800 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CONES AND CAUTION TAPE
Impact:	SEWAGE AND DEBRIS
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	31733	2711 GRASSLAND DR		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387444		07/12/2015	FISHER	GRIFFITH	DOCUMENTED	03/09/2011	LACK OF	UNAUTHORIZED	07/15/15 05:25	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	90,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387755
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	33003	815 TUCKER STATION RD		FLOYDS FORK	STREAM

Activity Code / Description	<u>WO #</u>	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387166		07/12/2015	DAVIS	BLANFORD	DOCUMENTED	03/09/2011	LACK OF	UNAUTHORIZED	07/12/15 12:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	5,250 GAL
Cause:	HEAVY RAIN
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	SEWAGE
Repair:	AREA INCLUDED IN IOAP
Public Notification:	SIGNS AND DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	40471	1552 CHEROKEE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387595		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	07/18/2015	LACK OF	UNAUTHORIZED	07/15/15 07:45	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388672
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# **Assigned To Disch Status Activity Code / Description** Ref No Initiated Initiated By **Event Date Problem** Result Completed Condition 2391495 **GRIFFITH FIELDS** DOCUMENTED LACK OF : DISREVRAIN EVENT 7/18/2015 07/18/2015 UNAUTHORIZED 07/19/15 11:18 SYSTEM 2:40:00AM DISCHARGE DISCHAGE - WATERS AM CAPACITY

Discharge Reporting:

Discharge Amount:	21,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391582
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	40870	2120 INDIAN HILLS TRL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387548		07/12/2015	MARKS JR	OPS CSHIFT	DOCUMENTED	09/27/2002	LACK OF	UNAUTHORIZED	07/13/15 12:00	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	30,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	NO IMPACT OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	41374	300 MOCKINGBIRD VALLEY RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387582		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/27/2008	LACK OF	UNAUTHORIZED	07/14/15 05:35	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388666
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	41416	3343 BROWNSBORO RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387583		07/12/2015	FIELDS	GRIFFITH	BEYOND	05/03/2011	LACK OF	UNAUTHORIZED	07/13/15 11:09	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388667
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	42680	4640 BARBOUR LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2389120		07/14/2015	SINGLETON	OPS BSHIFT	DOCUMENTED	03/19/2008	LACK OF	UNAUTHORIZED	07/15/15 12:57	
DISCHARGE					EAST			SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	143,500 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGN
Impact:	SEWAGE & DEBRIS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE LOCATION

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	43726	1108 DUPONT CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387586		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/23/2011	LACK OF	UNAUTHORIZED	07/14/15 06:06	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388670
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	45214-AG	3700 CYPRESS SPRINGS PL		HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER	2431706		09/18/2015	BRAZEL	HUBER	REPAIRED -	09/18/2015	STRUCTURAL	UNAUTHORIZED	09/18/15 07:30	
DISCHARGE						ISSUE		FAILURE	DISCHAGE - WATERS	PM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	10,250 GAL
Cause:	STRUCTURAL FAILURE OF FORCE MAIN
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND ON THE GROUND
Repair:	CONTRACTOR REPAIRED THE FORCE MAIN
Public Notification:	ADVISED CUSTOMER ON SITE

9/14/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/14/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45796	1011 ALTA CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387488		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	05/10/2014	LACK OF	UNAUTHORIZED	07/15/15 07:39	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388624
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Initiated Jul 01, 2015 12:00 AM thru Sep 30, 2015 11:59 PM

Report Selections: Period: 07/01/2015 00:00 thru 09/30/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO # **Assigned To Disch Status Event Date Activity Code / Description** Ref No Initiated Initiated By **Problem** Result Completed Condition 2391490 **GRIFFITH FIELDS** DOCUMENTED LACK OF : DISREVRAIN EVENT 7/18/2015 05/10/2014 UNAUTHORIZED 07/19/15 11:05 SYSTEM 2:33:00AM DISCHARGE DISCHAGE - WATERS AM CAPACITY

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391578
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45835	1132 ROSTREVOR CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387494		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	09/02/2003	LACK OF	UNAUTHORIZED	07/15/15 07:28	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388628
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

CAPACITY



Report Selections: Period: 07/01/2015 00:00 thru 09/30/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# **Assigned To Disch Status Event Date Activity Code / Description** Ref No Initiated Initiated By **Problem** Result Completed Condition 2391491 **GRIFFITH FIELDS** DOCUMENTED LACK OF : DISREVRAIN EVENT 7/18/2015 09/02/2003 UNAUTHORIZED 07/19/15 10:35 SYSTEM 2:26:00AM DISCHARGE DISCHAGE - WATERS AM

Discharge Reporting:

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391579
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45900	1122 ROSTREVOR CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387597		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/27/2011	LACK OF	UNAUTHORIZED	07/14/15 03:14	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388674
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	46623	4801 CASSIA CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387590		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	04/03/2015	LACK OF	UNAUTHORIZED	07/16/15 09:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2390679
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	46627	1910 CHARBDIN PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387593		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/15/15 06:00	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	4,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391322
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47034	232 STONEHENGE DR		OHIO RIVER	STREAM

Activity Code / Description	<u>WO #</u>	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387542		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	11/22/2011	LACK OF	UNAUTHORIZED	07/14/15 04:28	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388650
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47582	201 BULLITT LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387496		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF	UNAUTHORIZED	07/13/15 07:49	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388631
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2391493		7/18/2015	GRIFFITH	FIELDS	DOCUMENTED	12/05/2011	LACK OF	UNAUTHORIZED	07/19/15 11:40	
DISCHARGE			3:23:00AM					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	19,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391581
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47583	202 OXMOOR LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387495		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	02/06/2008	LACK OF	UNAUTHORIZED	07/15/15 06:03	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391310
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# Initiated **Assigned To Disch Status Event Date** Condition **Activity Code / Description** Ref No Initiated By **Problem** Result Completed 2391492 **GRIFFITH FIELDS** DOCUMENTED LACK OF : DISREVRAIN EVENT 7/18/2015 02/06/2008 UNAUTHORIZED 07/19/15 01:00 SYSTEM 3:23:00AM DISCHARGE **DISCHAGE - WATERS** PM

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391580
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

CAPACITY

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47593	8021 CHRISTIAN CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387519		07/13/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF	UNAUTHORIZED	07/15/15 06:18	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388638
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47603	8016 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387522		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	07/14/15 04:13	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388640
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47604	8016 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387524		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF	UNAUTHORIZED	07/13/15 08:09	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388641
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	49445	2216 FAIRLAND AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387565		07/12/2015	MITCHELL	GRIFFITH	BEYOND	10/06/2013	LACK OF	UNAUTHORIZED	07/12/15 06:02	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	15,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387662
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# Initiated **Disch Status Event Date Activity Code / Description** Ref No Initiated By **Assigned To Problem** Result Completed Condition 2389037 **GRIFFITH** MITCHELL 10/06/2013 LACK OF : DISREVRAIN EVENT 7/14/2015 **BEYOND** UNAUTHORIZED 07/14/15 09:12 **APPROVED** SYSTEM 7:07:00AM DISCHARGE **DISCHAGE - WATERS** PM **DESIGN STORM** CAPACITY

Discharge Reporting:

Discharge Amount:	400 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389804
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	49446	2219 RICHLAND AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387566		07/12/2015	MITCHELL	GRIFFITH	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/12/15 06:03	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	6,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387667
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2389041		7/14/2015	GRIFFITH	MITCHELL	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/14/15 09:13	
DISCHARGE			7:08:00AM			APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389805
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	51160	3305 INDIAN CREEK CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387557		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	04/04/2008	LACK OF	UNAUTHORIZED	07/15/15 01:27	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387948
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	51594	1418 TREVILIAN WAY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387043		07/10/2015	MITCHELL	GRIFFITH	DOCUMENTED	09/12/2006	LACK OF	UNAUTHORIZED	07/10/15 01:40	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387116
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

7/10/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'

10/6/2015 Page 91 of 152 5:02:47 PM



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO # **Disch Status Event Date Activity Code / Description** Ref No Initiated Initiated By **Assigned To Problem** Result Completed Condition 2387560 **GRIFFITH** MITCHELL DOCUMENTED LACK OF : DISREVRAIN EVENT 7/12/2015 09/12/2006 UNAUTHORIZED 07/12/15 11:35 SYSTEM 7:30:00AM DISCHARGE DISCHAGE - WATERS AM CAPACITY

Discharge Reporting:

Discharge Amount:	14,400 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387656
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

CAPACITY



Report Selections: Period: 07/01/2015 00:00 thru 09/30/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# **Disch Status Event Date** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Problem** Result Completed 2389101 **GRIFFITH** MITCHELL DOCUMENTED LACK OF : DISREVRAIN EVENT 7/14/2015 09/12/2006 UNAUTHORIZED 07/14/15 09:07 SYSTEM 5:48:00AM DISCHARGE DISCHAGE - WATERS AM

Discharge Reporting:

Discharge Amount:	500 GAL	
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.	
Clean Up:	WO# 2389102	
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.	
Impact:	LIGHT DEBRIS OBSERVED.	
Repair:	LOCATION INCLUDED IN IOAP	
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.	

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO # **Disch Status Event Date** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Problem** Result Completed 2391504 **GRIFFITH** MITCHELL DOCUMENTED LACK OF : DISREVRAIN EVENT 7/18/2015 09/12/2006 UNAUTHORIZED 07/18/15 08:45 SYSTEM 1:45:00AM DISCHARGE DISCHAGE - WATERS AM CAPACITY

Discharge Reporting:

Discharge Amount:	4,500 GAL	
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.	
Clean Up:	WO# 2391505	
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.	
Impact:	LIGHT DEBRIS OBSERVED.	
Repair:	LOCATION INCLUDED IN IOAP	
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.	

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2418030		8/19/2015	GRIFFITH	MITCHELL	DOCUMENTED	09/12/2006	LACK OF	UNAUTHORIZED	08/19/15 07:30	
DISCHARGE			6:10:00PM					SYSTEM	DISCHAGE - WATERS	PM	

Discharge Reporting:

Discharge Amount:	1,500 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	DISCLN WO# 2418032
Control Zone:	CAUTION TAPE AND TEMP SIGNS PLACED
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN THE IOAP
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMP SIGNS

CAPACITY

8/17/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	60679	9114 CINDERELLA LN		OHIO RIVER	STREAM

Activity Code / Description	WO# Re	ef No Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387517	07/12/2015	MARKS JR	OPS BSHIFT	DOCUMENTED	12/15/2007	LACK OF	UNAUTHORIZED	07/12/15 11:50	
DISCHARGE				WEST			SYSTEM	DISCHAGE - WATERS	AM	
							CAPACITY			

Discharge Reporting:

Discharge Amount:	2,925 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	SEE WORK ORDER #2388940
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0078956 (Cont'd)MSD0277DEREK R. GUTHRIEOHIO RIVERWEST

WO # **Disch Status Event Date** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Problem** Result Completed 2388940 **SINGLETON** DOCUMENTED LACK OF : DISREVRAIN EVENT 7/14/2015 **OPS BSHIFT** 12/15/2007 UNAUTHORIZED 07/14/15 01:20 SYSTEM 7:43:00AM WEST DISCHARGE **DISCHAGE - WATERS** PM CAPACITY

Discharge Reporting:

Discharge Amount:	8,425 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE, SOLIDS, PERSONAL HYGIENE PRODUCTS & DEBRIS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS FOUND IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	63094	9517 PLUMWOOD RD		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387215		07/12/2015	DAVIS	BLANFORD	DOCUMENTED	04/04/2008	LACK OF	UNAUTHORIZED	07/12/15 10:28	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	5,850 GAL
Cause:	HEAVY RAIN CAUSED LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	SEWAGE
Repair:	INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	63095	9300 HAYES AVE		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387214		07/12/2015	DAVIS	BLANFORD	DOCUMENTED	04/04/2008	LACK OF	UNAUTHORIZED	07/12/15 12:05	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	11,500 GAL
Cause:	HEAVY RAIN CAUSED LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	SEWAGE
Repair:	INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	63357	332 STONEHENGE DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387577		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/27/2011	LACK OF	UNAUTHORIZED	07/14/15 04:32	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388663
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center		
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST	

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65531	12400 BRIERLY HILL PL		FLOYDS FORK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387170		07/12/2015	DAVIS	BLANFORD	BEYOND	04/27/2011	LACK OF	UNAUTHORIZED	07/12/15 12:00	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	5,250 GAL
Cause:	HEAVY RAIN
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE TEMP SIGNS
Impact:	SEWAGE
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES # Facility ID		Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65606	1910 CHARBDIN PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387579		07/12/2015	FIELDS	GRIFFITH	BEYOND	10/06/2013	LACK OF	UNAUTHORIZED	07/15/15 06:03	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	5,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391316
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65610	1802 ROUND RIDGE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387594		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/15/15 06:00	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	6,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391329
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65623	1804 ROUND RIDGE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387580		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	06/23/2011	LACK OF	UNAUTHORIZED	07/16/15 09:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2390677
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65633	4640 BARBOUR LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2389121		07/14/2015	SINGLETON	OPS BSHIFT	DOCUMENTED	04/04/2008	LACK OF	UNAUTHORIZED	07/15/15 12:57	
DISCHARGE					EAST			SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	95,700 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE & DEBRIS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65635	4640 BARBOUR LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2389119		07/14/2015	SINGLETON	OPS BSHIFT	DOCUMENTED	04/04/2008	LACK OF	UNAUTHORIZED	07/15/15 12:57	
DISCHARGE					EAST			SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	95,700 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE & DEBRIS OBSERVE
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE LOCATION

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	66349	3726 FINCASTLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387555		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	07/12/15 11:28	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,400 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387635
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO # **Disch Status Event Date** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Problem** Result Completed 2389025 **GRIFFITH** MITCHELL DOCUMENTED LACK OF : DISREVRAIN EVENT 7/14/2015 03/04/2008 UNAUTHORIZED 07/14/15 04:58 SYSTEM 5:50:00AM DISCHARGE **DISCHAGE - WATERS** PM CAPACITY

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389800
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2391498		7/18/2015	GRIFFITH	FIELDS	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	07/18/15 08:30	
DISCHARGE			1:35:00AM					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	3,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391500
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	67535	9 MUIRFIELD PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387531		07/12/2015	FIELDS	GRIFFITH	BEYOND	03/26/2015	LACK OF	UNAUTHORIZED	07/13/15 08:21	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388643
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	70158	5600 HOFELICH CT		CEDAR CREEK	GROUND

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387210		07/12/2015	DAVIS	BLANFORD	DOCUMENTED	01/24/2002	LACK OF	UNAUTHORIZED	07/12/15 10:00	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	6,750 GAL
Cause:	HEAVY RAIN CAUSED LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	SEWAGE
Repair:	INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	72289	1700 SULGRAVE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387477		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	05/29/2012	LACK OF	UNAUTHORIZED	07/13/15 07:10	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388161
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

CAPACITY



Report Selections: Period: 07/01/2015 00:00 thru 09/30/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO# Initiated **Assigned To Disch Status Event Date Activity Code / Description** Ref No Initiated By **Problem** Result Completed Condition 2391487 **GRIFFITH FIELDS** DOCUMENTED LACK OF : DISREVRAIN EVENT 7/18/2015 05/29/2012 UNAUTHORIZED 07/19/15 11:12 SYSTEM 2:40:00AM DISCHARGE DISCHAGE - WATERS AM

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391574
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/15/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/15/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	74513	1106 BROADFIELDS DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387588		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/14/15 05:50	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388671
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	83011	7702 CEDAR CREEK RD		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387314		07/12/2015	DAVIS	BOND JR	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/12/15 11:48	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	AM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	5,000 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

7/11/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/11/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	84155	7913 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387537		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/10/2011	LACK OF	UNAUTHORIZED	07/15/15 06:23	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388646
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	90700	8021 CHRISTIAN CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387504		07/12/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF	UNAUTHORIZED	07/15/15 06:15	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388636
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	96673	3920 DUTCHMANS LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387599		07/12/2015	FIELDS	GRIFFITH	BEYOND	04/27/2011	LACK OF	UNAUTHORIZED	07/14/15 06:12	
DISCHARGE						APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388675
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Initiated Jul 01, 2015 12:00 AM thru Sep 30, 2015 11:59 PM

Report Selections: Period: 07/01/2015 00:00 thru 09/30/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	96911A-V	912 EASTWOOD FISHERVILLE RD		FLOYDS FORK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER	2420006		08/25/2015	SPENCER	OPS BSHIFT	REPAIRED -	09/24/2010	STRUCTURAL	UNAUTHORIZED	08/25/15 04:00	
DISCHARGE					CENTRAL	ISSUE		FAILURE	DISCHAGE - WATERS	PM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	5,000 GAL
Cause:	16" FM BREAK.
Clean Up:	AFFECTED AREA WAS RAKED.
Control Zone:	AREA WAS REMOTE IN THE FM EASEMENT. LIMITED ACCESS.
Impact:	SEWAGE ON GROUND
Repair:	CHEROKEE CONSTRUCTION - 16" FM WAS REPAIRED.
Public Notification:	CONTACTED CUSTOMER SERVICE AND INFORMED THEM OF THE SITUATION. SPOKE TO PROPERTY OWNER. SPOKE TO DAN FRENCH AND INFORMED HIM OF THE STATUS.

8/20/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
8/20/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	BU05074039	3305 BENT CREEK CT		OHIO RIVER	STREAM

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387562		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/24/2011	LACK OF	UNAUTHORIZED	07/14/15 09:25	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2388661
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411MSD0278MORRIS FORMANOHIO RIVERWEST

Facility Type Facility ID Facility Address If Pump Station, Name of Pump Station: Receiving Stream Discharge to SSL Sewer Service Line BU05091039 3303 TROUT CREEK DR OHIO RIVER STREAM

WO# Assigned To **Activity Code / Description** Ref No Initiated Initiated By **Disch Status Event Date Problem** Result Completed Condition MITCHELL UNAUTHORIZED 07/12/15 04:09 : DISREV: RAIN EVENT 2387568 07/12/2015 **GRIFFITH** DOCUMENTED 02/24/2011 LACK OF DISCHARGE SYSTEM DISCHAGE - WATERS PM CAPACITY

Discharge Reporting:

Discharge Amount:	9,900 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387686
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	CSO113	1215 ELLISON AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISDW: DRY WEATHER	2429237		09/14/2015	MARDIS	BRIGHT	REPAIRED -	09/14/2015	OBSTRUCTION-N	UNAUTHORIZED	09/14/15 08:30	
DISCHARGE						ISSUE		OT GREASE /	DISCHAGE - WATERS	AM	
						RESOLVED		ROOTS			

Discharge Reporting:

Discharge Amount:	450 GAL
Cause:	OBSTRUCTION IN MAIN SEWR
Clean Up:	FLUSHED THE LINE
Control Zone:	N/A
Impact:	NONE
Repair:	OPENED BY FLUSHING THE LINE
Public Notification:	N/A

9/3/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/3/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	KK14815019	4108 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387567		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	07/29/2009	LACK OF	UNAUTHORIZED	07/12/15 11:12	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	100 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387673
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

CAPACITY



Report Selections: Period: 07/01/2015 00:00 thru 09/30/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO # **Disch Status Event Date** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Problem** Result Completed 2389053 **GRIFFITH** MITCHELL DOCUMENTED LACK OF : DISREVRAIN EVENT 7/14/2015 07/29/2009 UNAUTHORIZED 07/14/15 08:43 SYSTEM 5:41:00AM DISCHARGE DISCHAGE - WATERS AM

Discharge Reporting:

Discharge Amount:	500 GAL	
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.	
Clean Up:	WO# 2389056	
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.	
Impact:	LIGHT DEBRIS OBSERVED.	
Repair:	LOCATION INCLUDED IN IOAP	
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.	

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	KK14855239	4107 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387570		07/12/2015	MITCHELL	GRIFFITH	DOCUMENTED	05/15/2008	LACK OF	UNAUTHORIZED	07/12/15 11:15	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	1,100 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2387681
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2389065		7/14/2015	GRIFFITH	MITCHELL	DOCUMENTED	05/15/2008	LACK OF	UNAUTHORIZED	07/14/15 08:40	
DISCHARGE			5:39:00AM					SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389081
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
-----------------	--------	---



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

WO # **Disch Status** Condition **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Event Date Problem** Result Completed 2391506 **GRIFFITH** MITCHELL DOCUMENTED LACK OF : DISREVRAIN EVENT 7/18/2015 05/15/2008 UNAUTHORIZED 07/18/15 08:35 SYSTEM 1:39:00AM DISCHARGE DISCHAGE - WATERS AM

Discharge Reporting:

Discharge Amount:	1,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2391507
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

CAPACITY

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD0040-PS	7404 ARROWWOOD RD	DEVONDALE	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2388693		07/13/2015	SINGLETON	OPS BSHIFT	DOCUMENTED	01/26/2012	LACK OF	UNAUTHORIZED	07/15/15 08:05	
DISCHARGE					EAST			SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	157,875 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS PLACED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD0057-LS	806 PINE WAY	ANCHOR ESTATES #2	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387530		07/12/2015	MARKS JR	OPS CSHIFT	DOCUMENTED	12/16/2000	LACK OF	UNAUTHORIZED	07/13/15 02:05	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	4,850 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	SEE WORK ORDER #2388619
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AT THIS LOCATION

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD0186-PS	2120 INDIAN HILLS TRL	MUDDY FORK	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387520		07/12/2015	MARKS JR	OPS BSHIFT	DOCUMENTED	01/27/2012	LACK OF	UNAUTHORIZED	07/13/15 12:00	
DISCHARGE					EAST			SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	300,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	NO IMPACT OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0202	5500 HITT RD		HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2387485		07/12/2015	MARKS JR	OPS BSHIFT	REPAIRED -	09/27/2015	BYPASS AT	UNAUTHORIZED	07/12/15 01:15	
DISCHARGE					EAST	ISSUE		WQTC	DISCHAGE - WATERS	PM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	157,500 GAL
Cause:	RAIN EVENT CAUSED CREEK TO FLOOD WET WELL
Clean Up:	MSD CLEANED & SANITIZED
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO VISUAL IMPACT
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420 (Cont'd)	MSD0202	HITE CREEK	HITE CREEK	EAST

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2388696		7/14/2015	OPS BSHIFT	SINGLETON	REPAIRED -	09/27/2015	BYPASS AT	UNAUTHORIZED	07/14/15 07:20	
DISCHARGE			5:42:00AM	EAST		ISSUE		WQTC	DISCHAGE - WATERS	AM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	49,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED AREA
Control Zone:	TEMPORARY SIGNS PLACED
Impact:	NO VISUAL IMPACT
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420 (Cont'd)	MSD0202	HITE CREEK	HITE CREEK	EAST

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISDWDRY WEATHER	2434538		9/26/2015	OPS BSHIFT	MARKS JR	REPAIRED -	09/27/2015	BYPASS AT	UNAUTHORIZED	09/27/15 12:45	
DISCHARGE			10:59:00PM	EAST		ISSUE		WQTC	DISCHAGE - WATERS	AM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	49,074 GAL
Cause:	COMMUNICATION FAILURE OF UV SYSTEM
Clean Up:	NO CLEAN UP REQUIRED MOSTLY TREATED FLOW DISCHARGED AT PLANT EFFLUENT
Control Zone:	PERMANENT SIGNS POSTED ALONG IMPACTED STREAM
Impact:	MOSTLY TREATED FLOW DISCHARGED AT PLANT EFFLUENT - NO UV DISINFECTION OCCURRED
Repair:	OPERATOR INSTALLED SLIDE GATE UNTIL ELETRICAL REPAIRS WERE COMPLETED
Public Notification:	PUBLIC NOTIFIED WITH PERMANENT SIGNS POSTED AT TREATMENT PLANT OUTFALL

9/19/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO
		DISCHARGENOTICE@LOUISVILLEMSD.ORG,SAYRE.DENNIS@EPAMAIL.EPA.GOV,EPPC.ERT@KY.GOV,CHARLIE.ROTH@KY.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0036501	MSD0209	BERRYTOWN	FLOYDS FORK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0209	1203 HEAFER RD		FLOYDS FORK	STREAM

Activity Code / Description	<u>WO #</u> R	Ref No Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387497	07/12/2015	MARKS JR	OPS BSHIFT	DOCUMENTED	02/02/2011	BYPASS AT	UNAUTHORIZED	07/13/15 01:40	
DISCHARGE				CENTRAL			WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	38,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SOLIDS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AT THIS LOCATION

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0036501 (Cont'd)MSD0209BERRYTOWNFLOYDS FORKCENT

WO # **Activity Code / Description** Ref No Initiated Initiated By **Assigned To Disch Status Event Date Problem** Result Completed Condition 2389577 **SINGLETON** DOCUMENTED BYPASS AT : DISREVRAIN EVENT 7/14/2015 **OPS BSHIFT** 02/02/2011 UNAUTHORIZED 07/14/15 05:45 CENTRAL WQTC 1:30:00PM DISCHARGE **DISCHAGE - WATERS** PM

Discharge Reporting:

Discharge Amount:	1,425 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS LOCATED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/14/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0029416	MSD0228	MCNEELY LAKE	PENNSYLVANIA RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0228	10300 ROD N REEL RD		PENNSYLVANIA RUN	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISDW: DRY WEATHER	2391494		07/18/2015	MARKS JR	OPS BSHIFT	REPAIRED -	07/18/2015	BYPASS AT	UNAUTHORIZED	07/18/15 01:30	
DISCHARGE					CENTRAL	ISSUE		WQTC	DISCHAGE - WATERS	PM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	8,000 GAL
Cause:	LOST POWER DUE TO POWER LINES BEING ON FIRE.
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE AND SOLIDS OBSERVED
Repair:	INSTALLED GENERATOR TO STOP BYPASS
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0255	10725 OLD TAYLORSVILLE RD		CHENOWETH RUN	STREAM

Activity Code / Description	WO # Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2382474	07/03/2015	GREEN	OPS BSHIFT	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	07/04/15 01:28	
DISCHARGE				CENTRAL			JTOWN WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	359,280 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED
	DURING WET WEATHER.
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

Plant Details:

DAILY TOTAL PLANT FLOW	13,665,000 GAL
PEAK PLANT FLOW WHEN BLENDING	12,070,000 GPD

Notifications:

6/30/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
6/30/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

10/6/2015 Page 137 of 152 5:02:47 PM





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2387007		7/10/2015	OPS BSHIFT	SINGLETON	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	07/11/15 12:50	
DISCHARGE			12:03:00PM	CENTRAL				JTOWN WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	564,375 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED AT THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER.
Public Notification:	PERMANENT SIGNS HAVE BEEN POSTED AT THIS LOCATION

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	12,917,000 GPD
DAILY TOTAL PLANT FLOW	13,595,000 GAL

7/8/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/8/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2387491		7/12/2015	OPS BSHIFT	MARKS JR	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	07/13/15 03:06	
DISCHARGE			7:39:00AM	CENTRAL				JTOWN WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	3,425,126 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	NO CLEANUP- PIPE DISCHARGE SUBMERGED
Control Zone:	PERMANENT SIGN POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED AT THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER.
Public Notification:	PERMANENT SIGNS HAVE BEEN POSTED AT THIS LOCATION.

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	16,306,000 GPD
DAILY TOTAL PLANT FLOW	19,257,000 GAL

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2388137		7/13/2015	OPS CSHIFT	MARKS JR	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	07/15/15 07:53	
DISCHARGE			3:44:00PM					JTOWN WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	3,870,550 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED AT THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER
Public Notification:	PERMANENT SIGNS POSTED AT THIS LOCATION

Plant Details:

DAILY TOTAL PLANT FLOW	28,262,000 GAL
PEAK PLANT FLOW WHEN BLENDING	14,537,000 GPD

7/13/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/13/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2391429		7/18/2015	OPS ASHIFT	MARKS JR	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	07/18/15 05:23	
DISCHARGE			2:21:00AM					JTOWN WQTC	DISCHAGE - WATERS	AM	

Discharge Reporting:

Discharge Amount:	107,109 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER
Public Notification:	PERMANENT SIGNS ARE POSTED AT THIS LOCATION

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	13,621,000 GPD
DAILY TOTAL PLANT FLOW	7,511,000 GAL

7/15/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/15/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREVRAIN EVENT	2436657		9/29/2015	OPS BSHIFT	SINGLETON	DOCUMENTED	01/14/2007	BLENDING AT	UNAUTHORIZED	09/29/15 04:40	
DISCHARGE			11:03:00AM	CENTRAL				JTOWN WQTC	DISCHAGE - WATERS	PM	

Discharge Reporting:

Discharge Amount:	382,797 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED AT THIS PLANT
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET
	WEATHER
Public Notification:	PERMANENT SIGNS ARE POSTED AROUND THE AFFECTED AREA

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	15,507,000 GPD
DAILY TOTAL PLANT FLOW	5,956,000 GAL

9/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPI Sewer Treatment Plant	MSD0289	8605 CEDAR CREEK RD		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387653		07/12/2015	SINGLETON	OPS BSHIFT	REPAIRED -	07/12/2015	BYPASS AT	UNAUTHORIZED	07/12/15 09:00	
DISCHARGE					CENTRAL	ISSUE		WQTC	DISCHAGE - WATERS	PM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	FILTER BYPASS GATE FAILED TO OPEN IN AUTO
Clean Up:	NO DEBRIS
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED
Repair:	OPERATOR OPENED BYPASS GATE MANUALLY
Public Notification:	PERMANENT SIGNS POSTED AT THIS LOCATION

7/1:	3/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
			SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0291	9810 U S HIGHWAY 42		HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387500		07/12/2015	MARKS JR	OPS BSHIFT	REPAIRED -	12/24/2013	BYPASS AT	UNAUTHORIZED	07/13/15 12:15	
DISCHARGE					EAST	ISSUE		WQTC	DISCHAGE - WATERS	AM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	1,325,490 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SOLIDS OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD1010-PS	5006 LEA ANN WAY	LEA ANN WAY	OHIO RIVER	STREAM

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2387525		07/12/2015	MARKS JR	OPS BSHIFT	DOCUMENTED	12/15/2007	PUMPED	UNAUTHORIZED	07/12/15 03:00	
DISCHARGE					WEST			OVERFLOW	DISCHAGE - WATERS	PM	

Discharge Reporting:

Discharge Amount:	1,207,500 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	REFERENCE #2388818
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

7/12/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/12/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0078956 (Cont'd)MSD0277DEREK R. GUTHRIEOHIO RIVERWEST

WO# **Disch Status Activity Code / Description** Ref No Initiated Initiated By **Assigned To Event Date Problem** Result Completed Condition 2388818 **SINGLETON** DOCUMENTED **PUMPED** : DISREVRAIN EVENT 7/14/2015 **OPS BSHIFT** 12/15/2007 UNAUTHORIZED 07/14/15 02:05 **OVERFLOW** 6:44:00AM WEST DISCHARGE **DISCHAGE - WATERS** PM

Discharge Reporting:

Discharge Amount:	1,278,900 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD1018-PS	3700 CYPRESS SPRINGS PL	CYPRESS SPRINGS	HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISDW: DRY WEATHER	2431709		09/18/2015	BRAZEL	HUBER	REPAIRED -	09/18/2015	STRUCTURAL	UNAUTHORIZED	09/18/15 11:30	
DISCHARGE						ISSUE		FAILURE	DISCHAGE - WATERS	PM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	700 GAL
Cause:	STRUCTURAL FAILURE - FORCE MAIN BREAK
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND AROUND WET WELL
Repair:	HAULED SEWAGE UNTIL REPAIRS MADE- CONTRACTOR REPAIRED THE FORCE MAIN
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON

9/14/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/14/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD1063-PS	6210 DEEP CREEK CT	DEEP CREEK	HITE CREEK	STREAM

Activity Code / Description	<u>WO #</u>	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2388160		07/13/2015	MARKS JR	OPS CSHIFT	DOCUMENTED	12/16/2000	LACK OF	UNAUTHORIZED	07/13/15 06:06	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	PM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	2,750 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEANUP
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA

7/13/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/13/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD1064-PS	8619 WESTOVER DR	WESTOVER	HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2388841		07/14/2015	SINGLETON	OPS BSHIFT	BEYOND	04/03/2015	LACK OF	UNAUTHORIZED	07/14/15 03:15	
DISCHARGE					EAST	APPROVED		SYSTEM	DISCHAGE - WATERS	PM	
						DESIGN STORM		CAPACITY			

Discharge Reporting:

Discharge Amount:	23,400 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS PLACED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS LOCATED IN THE IOAP
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD1085-PS	7520 KAVANAUGH RD	KAVANAUGH ROAD	HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2389008		07/14/2015	SINGLETON	OPS BSHIFT	DOCUMENTED	05/11/2003	LACK OF	UNAUTHORIZED	07/14/15 07:30	
DISCHARGE					CENTRAL			SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

Discharge Reporting:

Discharge Amount:	150 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	MSD1203-PS	4005 KIRBY LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER	2397937		07/23/2015	SINGLETON	OPS ASHIFT	REPAIRED -	04/02/2015	STRUCTURAL	UNAUTHORIZED	07/24/15 10:15	
DISCHARGE						ISSUE		FAILURE	DISCHAGE - WATERS	AM	
						RESOLVED					

Discharge Reporting:

Discharge Amount:	50 GAL
Cause:	FORCE MAIN BREAK
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TAPE AND TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	CONTRACTOR TO REPAIR FORCE MAIN
Public Notification:	TAPE AND TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

7/19/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/19/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'





KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411MSD0278MORRIS FORMANOHIO RIVERWEST

Facility Type Facility ID Facility Address If Pump Station, Name of Pump Station: Receiving Stream Discharge to SSL Sewer Service Line Z18284029 3928 DUTCHMANS LN OHIO RIVER STREAM

WO# Assigned To **Activity Code / Description** Ref No Initiated Initiated By **Disch Status Event Date Problem** Result Completed Condition **GRIFFITH** UNAUTHORIZED : DISREV: RAIN EVENT 2389125 07/14/2015 **FIELDS** DOCUMENTED 03/19/2008 LACK OF 07/14/15 06:07 DISCHARGE **SYSTEM** DISCHAGE - WATERS PM CAPACITY

Discharge Reporting:

Discharge Amount:	200 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2389798
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

7/14/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
7/14/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 115

Total Work Orders Printed: 152

10/6/2015 Page 152 of 152 5:02:47 PM