

Appendix A-1 - Discharge Work Orders – Dry Weather CSOs

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	CSO113	1215 ELLISON AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2456311		11/02/2015	BRIGHT	BRIGHT	REPAIRED - ISSUE RESOLVED	09/14/2015	OBSTRUCTION-N OT GREASE / ROOTS	UNAUTHORIZED DISCHAGE - WATERS	11/02/15 10:37 AM	

Discharge Reporting:

Discharge Amount:	9 GAL
Cause:	UNKNOWN OBSTRUCTION IN LOW FLOW LINE
Clean Up:	FLUSHED LINE TO MITIGATE. NO CLEAN-UP NECESSARY
Control Zone:	N/A
Impact:	NONE
Repair:	FLUSHED THE LINE TO MITIGATE
Public Notification:	N/A

Notifications:

10/28/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDWDRY WEATHER DISCHARGE	2464186		11/23/2015 10:16:00AM	BRIGHT	BRIGHT	REPAIRED - ISSUE RESOLVED	09/14/2015	OBSTRUCTION- NOT GREASE / ROOTS	UNAUTHORIZED DISCHARGE - WATERS	11/23/15 11:38 AM	

Discharge Reporting:

Discharge Amount:	82 GAL
Cause:	HEAVY LEAVES (BUILD UP AT REDUCER/LOW-FLOW
Clean Up:	NONE NOTED. OVERFLOWS DIRECTLY INTO CREEK
Control Zone:	NONE NEEDED
Impact:	NONE NOTED. DISCHARGE DIRECTLY INTO CREEK
Repair:	FLUSHED LINE AND RELIEVED OBSTRUCTION
Public Notification:	INFORMED CONTRACTORS WORKING IN CREEK IN PERSON

Notifications:

11/19/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---

Appendix A-2 - Discharge Work Orders – Bypass

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Prob Code: BYPAS, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0029416	MSD0228	MCNEELY LAKE	PENNSYLVANIA RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0228	10300 ROD N REEL RD		PENNSYLVANIA RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2467155		12/01/2015	THOMPSON	OPS BSHIFT CENTRAL	REPAIRED - ISSUE RESOLVED	12/01/2015	BYPASS AT WQTC	UNAUTHORIZED DISCHAGE - WATERS	12/01/15 09:10 AM	

Discharge Reporting:

Discharge Amount:	31,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	DUE TO HIGH FLOW IN CREEK NO CLEAN UP
Control Zone:	SIGNS
Impact:	SOLIDS
Repair:	OPERATOR TURNED AIR OFF PLANT TO STOP SOLIDS FROM GOING OVER WEIR
Public Notification:	SIGNS

Notifications:

11/23/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/23/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Prob Code: BYPAS, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0031712	MSD0247	STARVIEW	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0247	423 BERMUDA WAY		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2467165		12/01/2015	THOMPSON	OPS BSHIFT CENTRAL	REPAIRED - ISSUE RESOLVED	12/01/2015	BYPASS AT WQTC	UNAUTHORIZED DISCHAGE - WATERS	12/01/15 10:00 AM	

Discharge Reporting:

Discharge Amount:	17,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	DUE TO HIGH FLOW IN CREEK NO CLEAN UP NEEDED
Control Zone:	SIGNS
Impact:	SOLIDS
Repair:	OPERATOR TURNED AIR OFF TO STOP BYPASSING OVER WEIR
Public Notification:	SIGNS

Notifications:

11/23/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/23/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Prob Code: BYPAS, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0278	4522 ALGONQUIN PKY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2439679		10/05/2015	BURCH	BURCH	REPAIRED - ISSUE RESOLVED	10/05/2015	BYPASS AT WQTC	UNAUTHORIZED DISCHARGE - WATERS	10/05/15 10:00 AM	

Discharge Reporting:

Discharge Amount:	300 GAL
Cause:	VALVING NOT SET UP CORRECTLY
Clean Up:	MSD CLEANED AND SANITIZED AREA
Control Zone:	CONES AND BARRICADES
Impact:	SEWAGE
Repair:	SUMP PUMP WAS TURNED OFF
Public Notification:	NONE

Notifications:

9/29/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/29/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 3

Total Work Orders Printed: 3

Appendix A-3 - Discharge Work Orders – Blending

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Prob Code: BLEND, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0255	10725 OLD TAYLORSVILLE RD		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2452977		10/27/2015	HUBER	OPS CSHIFT	DOCUMENTED	01/14/2007	BLENDING AT JTOWN WQTC	UNAUTHORIZED DISCHARGE - WATERS	10/28/15 06:27 PM	

Discharge Reporting:

Discharge Amount:	2,514,321 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED AT THIS PLANT
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET WEATHER
Public Notification:	PERMANENT SIGNS ARE POSTED AROUND THE AFFECTED AREA

Plant Details:

DAILY TOTAL PLANT FLOW	15,281,000 GAL
PEAK PLANT FLOW WHEN BLENDING	13,656,000 GPD

Notifications:

10/24/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
10/24/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Prob Code: BLEND, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2462919		11/18/2015 11:54:00AM	OPS BSHIFT CENTRAL	BROOKS	DOCUMENTED	01/14/2007	BLENDING AT JTOWN WQTC	UNAUTHORIZED DISCHAGE - WATERS	11/19/15 01:10 AM	

Discharge Reporting:

Discharge Amount:	1,940,645 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED AT THIS LOCATION WHEN FLOW HAS BEEN OPTIMIZED DURING WET WEATHER.
Public Notification:	PERMANENT SIGNS POSTED AT THIS LOCATION

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	16,911,000 GPD
DAILY TOTAL PLANT FLOW	13,585,000 GAL

Notifications:

11/2/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/2/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Prob Code: BLEND, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRain EVENT DISCHARGE	2467069		12/1/2015 4:12:00AM	OPS BSHIFT CENTRAL	THOMPSON	DOCUMENTED	01/14/2007	BLENDING AT JTOWN WQTC	UNAUTHORIZED DISCHARGE - WATERS	12/01/15 02:02 PM	

Discharge Reporting:

Discharge Amount:	407,810 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	SIGNS AT CREEK
Impact:	NO IMPACT OBSERVED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET WEATHER
Public Notification:	PERMANENT SIGNS ARE POSTED

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	13,344,000 GPD
DAILY TOTAL PLANT FLOW	8,938,000 GAL

Notifications:

11/23/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/23/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 1

Total Work Orders Printed: 3

Appendix A-4 - Discharge Work Orders – Waters of the United States

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	00056-W	804 N ARBOR DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476693		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 06:00 AM	

Discharge Reporting:

Discharge Amount:	58,950 GAL
Cause:	RAIN EVENT CAUSED LACK OF SYSTEM CAPACITY
Clean Up:	MSD CLEANED AND SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS USED TO WARN PUBLIC

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	0057-W	806 PINE WAY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476687		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	03/09/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:11 AM	

Discharge Reporting:

Discharge Amount:	21,525 GAL
Cause:	RAIN EVENT CAUSED LACK OF SYSTEM CAPACITY
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS USED TO WARN PUBLIC

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	00746	804 N ARBOR DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463107		11/18/2015	HUBER	OPS CSHIFT	DOCUMENTED	12/16/2000	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/19/15 12:10 AM	

Discharge Reporting:

Discharge Amount:	3,080 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED AND SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476688		12/27/2015 2:42:00PM	OPS BSHIFT CENTRAL	MARKS JR	DOCUMENTED	12/16/2000	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/29/15 06:00 AM	

Discharge Reporting:

Discharge Amount:	58,950 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS USED TO WARN PUBLIC

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	02933	7900 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476739		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:31 AM	

Discharge Reporting:

Discharge Amount:	162,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479655
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	02935	7900 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476738		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:29 AM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479634
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08426	4315 PRUITT CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476723		12/27/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/25/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 10:26 AM	

Discharge Reporting:

Discharge Amount:	2,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479570
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08427	4313 PRUITT CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476722		12/27/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/25/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 10:25 AM	

Discharge Reporting:

Discharge Amount:	2,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479568
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08717	3726 FINCASTLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463122		11/18/2015	MITCHELL	GRIFFITH	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 07:20 PM	

Discharge Reporting:

Discharge Amount:	10,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463152
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476082		12/23/2015 8:18:00PM	GRIFFITH	MITCHELL	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 09:37 AM	

Discharge Reporting:

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476226
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476726		12/27/2015 11:50:00AM	GRIFFITH	MITCHELL	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 12:50 PM	

Discharge Reporting:

Discharge Amount:	2,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479862
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08935-SM	1001 BRECKENRIDGE LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463115		11/18/2015	FISHER	GRIFFITH	DOCUMENTED	11/29/2001	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 10:37 PM	

Discharge Reporting:

Discharge Amount:	712,477 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476093		12/23/2015 9:03:00PM	GRIFFITH	MITCHELL	DOCUMENTED	11/29/2001	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 11:01 PM	

Discharge Reporting:

Discharge Amount:	342,732 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476714		12/27/2015 11:38:00AM	GRIFFITH	MITCHELL	DOCUMENTED	11/29/2001	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 09:21 PM	

Discharge Reporting:

Discharge Amount:	14,161,636 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	102339	9114 CINDERELLA LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463087		11/18/2015	ROTTET JR	OPS BSHIFT WEST	DOCUMENTED	07/14/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 09:12 PM	

Discharge Reporting:

Discharge Amount:	7,750 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED AND SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AROUND THE AFFECTED AREA

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	104223	4103 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476084		12/23/2015	MITCHELL	GRIFFITH	DOCUMENTED	05/20/2005	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/23/15 09:55 PM	

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476243
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2476719		12/27/2015 11:37:00AM	GRIFFITH	MITCHELL	DOCUMENTED	05/20/2005	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 11:00 AM	

Discharge Reporting:

Discharge Amount:	15,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479564
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	105936	7713 WESTPORT RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476749		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 09:04 AM	

Discharge Reporting:

Discharge Amount:	162,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479692
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	10793	4716 BURKLEY AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476743		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	12/27/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:44 AM	

Discharge Reporting:

Discharge Amount:	27,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479674
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	116106	10801 FAIRMOUNT RD		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476682		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	12/28/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 11:00 AM	

Discharge Reporting:

Discharge Amount:	456,000 GAL
Cause:	RAIN EVENT CAUSED LACK OF SYSTEM CAPACITY
Clean Up:	DISCLN #2480336
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAG OBSERVED
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR
Public Notification:	TEMPORARY SIGNS USED TO WARN PUBLIC

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	11777A	973 SWAN ST		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2473390		12/16/2015	DAVIS	WINCHELL	REPAIRED - ISSUE RESOLVED	12/16/2015	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE - WATERS	12/16/15 02:35 PM	

Discharge Reporting:

Discharge Amount:	200 GAL
Cause:	CONTRACTOR HIT SIPHON WHILE WORKING IN AREA
Clean Up:	CONTRACTOR TO CLEAN AND SANITIZE AREA
Control Zone:	TEMP SIGNS
Impact:	SEWAGE
Repair:	LOCATION PUT ON BYPASS WHILE CONTRACTOR REPAIRS LINE
Public Notification:	DOOR CARDS

Notifications:

12/15/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	11877A	5500 HITT RD		HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476584		12/27/2015	KESSEL	OPS BSHIFT EAST	DOCUMENTED	12/27/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 06:00 PM	

Discharge Reporting:

Discharge Amount:	17,750 GAL
Cause:	RAIN EVENT, LACK OF CAPACITY AT HITE CREEK
Clean Up:	MSD CLEANED AND SANITIZED
Control Zone:	NO CONTROL ZONE, MANHOLE IS FLOODED BY CREEK
Impact:	SEWAGE, SOLIDS
Repair:	UNABLE TO STOP DUE TO RAIN STILL IN THE AREA
Public Notification:	PIPE DISCHARGE SUBMERGED- NO CONTROL ZONE

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	13946	1600 BELMAR DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476088		12/23/2015	MITCHELL	GRIFFITH	DOCUMENTED	10/30/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/23/15 09:52 PM	

Discharge Reporting:

Discharge Amount:	2,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476255
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476717		12/27/2015 11:34:00AM	GRIFFITH	MITCHELL	DOCUMENTED	10/30/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 11:04 AM	

Discharge Reporting:

Discharge Amount:	27,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479561
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	16649	1726 FRASER DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476720		12/27/2015	MITCHELL	GRIFFITH	DOCUMENTED	01/24/2002	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 09:00 PM	

Discharge Reporting:

Discharge Amount:	218,305 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479566
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	21628-W	7404 ARROWWOOD RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2479181		12/28/2015	SINGLETON	OPS BSHIFT CENTRAL	DOCUMENTED	12/16/2000	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 05:45 AM	

Discharge Reporting:

Discharge Amount:	2,850 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	BARRICADES PLACED
Impact:	DEBRIS AND SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	BARRICADES PLACED AROUND THE AFFECTED AREA

Notifications:

12/28/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/28/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	23211	3302 TROUT CREEK DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476765		12/27/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/22/2000	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 10:36 AM	

Discharge Reporting:

Discharge Amount:	129,600 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479752
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	25484	9317 LANTANA DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463081		11/18/2015	ROTTET JR	OPS BSHIFT WEST	DOCUMENTED	01/13/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 05:30 PM	

Discharge Reporting:

Discharge Amount:	1,350 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	NO DEBRIS
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED AT THIS LOCATION

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956 (Cont'd)	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476651		12/27/2015 1:42:00PM	OPS BSHIFT CENTRAL	MARKS JR	DOCUMENTED	01/13/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/28/15 07:40 AM	

Discharge Reporting:

Discharge Amount:	10,780 GAL
Cause:	RAIN EVENT CASUED A LACK OF SYSTEM CAPAITY
Clean Up:	MSD CLEANED & SANITIZED
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE ON THE GROUND
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS POSTED TO WARN THE PUBLIC.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	26752	3317 BROWNSBORO RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476756		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	04/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 09:48 AM	

Discharge Reporting:

Discharge Amount:	67,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479735
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27007	1013 ALTA CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463110		11/18/2015	FIELDS	GRIFFITH	DOCUMENTED	02/05/2014	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 06:13 AM	

Discharge Reporting:

Discharge Amount:	144,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463209
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476096		12/23/2015 1:33:00PM	GRIFFITH	FIELDS	DOCUMENTED	02/05/2014	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 10:46 AM	

Discharge Reporting:

Discharge Amount:	6,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476267
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476730		12/27/2015 1:21:00PM	GRIFFITH	FIELDS	DOCUMENTED	02/05/2014	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 11:16 AM	

Discharge Reporting:

Discharge Amount:	5,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479826
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27116	10304 CAVEN AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2452992		10/27/2015	DAVIS	TELLMAN	DOCUMENTED	11/15/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	10/29/15 12:30 PM	

Discharge Reporting:

Discharge Amount:	49,200 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	SIGNS
Impact:	SEWAGE, DISCOLORATION
Repair:	AREA INCLUDED IN IOAP
Public Notification:	TEMP SIGNS AND DOOR CARDS

Notifications:

10/24/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
10/24/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956 (Cont'd)	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2462984		11/18/2015 1:00:00PM	TELLMAN	DAVIS	DOCUMENTED	11/15/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	11/19/15 07:30 AM	

Discharge Reporting:

Discharge Amount:	27,750 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN SANITIZE AFFECTED AREA
Control Zone:	TEMP SIGNS AND CAUTION TAPE
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956 (Cont'd)	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2467174		12/1/2015 7:03:00AM	MATTHEWS	DAVIS	DOCUMENTED	11/15/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/01/15 10:25 PM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND BARRICADES
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

Notifications:

11/23/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/23/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956 (Cont'd)	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476629		12/27/2015 1:50:00PM	SMITH	DAVIS	DOCUMENTED	11/15/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/29/15 04:00 AM	

Discharge Reporting:

Discharge Amount:	36,000 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS AND SIGNS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28173	3258 RUCKRIEGEL PKY		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463116		11/18/2015	FISHER	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 06:25 PM	

Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463143
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28249	3500 ST EDWARDS DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463117		11/18/2015	FISHER	GRIFFITH	DOCUMENTED	03/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 06:34 PM	

Discharge Reporting:

Discharge Amount:	6,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463150
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476712		12/27/2015 2:50:00PM	GRIFFITH	FISHER	DOCUMENTED	03/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 07:45 AM	

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479823
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28250	3506 CHARLANE PKY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463119		11/18/2015	FISHER	GRIFFITH	DOCUMENTED	01/03/2005	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 05:59 AM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463170
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476711		12/27/2015 2:40:00PM	GRIFFITH	FISHER	DOCUMENTED	01/03/2005	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 07:45 AM	

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479817
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28336	9707 WILLOWWOOD WAY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2479745		12/27/2015	FISHER	GRIFFITH	DOCUMENTED	08/30/2005	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 05:35 AM	

Discharge Reporting:

Discharge Amount:	34,500 GAL
Cause:	LACK OF SYSTEM CAPACITY- HEAVY RAIN
Clean Up:	DISCLN WO# 2479751
Control Zone:	CONES AND TEMP SIGNS PLACED
Impact:	LIGHT DEBRIS OBSERVED
Repair:	LOCATION INCLUDED IN THE IOAP
Public Notification:	PUBLIC NOTIFIED THROUGH DOOR HANGERS AND TEMP SIGNS TO AVOID CONTACT WITH DISCHARGED CONTENT

Notifications:

12/29/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28415	3406 DELL RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476686		12/27/2015	FISHER	GRIFFITH	DOCUMENTED	12/19/2002	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 07:30 AM	

Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479796
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28451	3406 CHARLANE PKY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2454325		10/28/2015	FISHER	GRIFFITH	DOCUMENTED	10/28/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	10/28/15 12:45 PM	

Discharge Reporting:

Discharge Amount:	10,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2454548
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

10/28/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
10/28/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2463118		11/18/2015 2:03:00PM	GRIFFITH	FISHER	DOCUMENTED	10/28/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 06:05 AM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463169
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476709		12/27/2015 2:35:00PM	GRIFFITH	FISHER	DOCUMENTED	10/28/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 07:35 AM	

Discharge Reporting:

Discharge Amount:	2,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479810
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28453	3402 CHARLANE PKY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2454328		10/28/2015	FISHER	GRIFFITH	DOCUMENTED	10/28/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	10/28/15 12:45 PM	

Discharge Reporting:

Discharge Amount:	10,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO#2454553
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

10/28/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
10/28/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476706		12/27/2015 2:30:00PM	GRIFFITH	FISHER	DOCUMENTED	10/28/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 05:20 AM	

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 24799801
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28551	11401 GRAND AVE		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463120		11/18/2015	FISHER	GRIFFITH	DOCUMENTED	11/22/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 05:45 AM	

Discharge Reporting:

Discharge Amount:	48,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463189
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	29948	6810 SANDSTONE BLVD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476624		12/27/2015	DAVIS	BOND JR	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 03:00 PM	

Discharge Reporting:

Discharge Amount:	1,875 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	NOTIFIED CUSTOMER ON SITE DOOR CARDS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	30376	8113 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476747		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	11/29/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:52 AM	

Discharge Reporting:

Discharge Amount:	153,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479678
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	31073	6808 SANDSTONE BLVD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476617		12/27/2015	DAVIS	BOND JR	DOCUMENTED	03/09/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 03:00 PM	

Discharge Reporting:

Discharge Amount:	1,875 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	31074	6808 SANDSTONE BLVD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476621		12/27/2015	DAVIS	BOND JR	DOCUMENTED	02/24/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 03:00 PM	

Discharge Reporting:

Discharge Amount:	1,875 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE AND TEMP SIGNS
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	33003	815 TUCKER STATION RD		FLOYDS FORK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476632		12/27/2015	DAVIS	BLANFORD	DOCUMENTED	03/09/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 05:00 PM	

Discharge Reporting:

Discharge Amount:	900 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	CAUTION TAPE, TEMP SIGNS
Impact:	SEWAGE AND DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS NOTIFIED

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	40471	1552 CHEROKEE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463114		11/18/2015	FIELDS	GRIFFITH	DOCUMENTED	07/18/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 06:30 AM	

Discharge Reporting:

Discharge Amount:	48,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463251
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476105		12/23/2015 9:59:00PM	GRIFFITH	FIELDS	DOCUMENTED	07/18/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 11:01 AM	

Discharge Reporting:

Discharge Amount:	10,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476285
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	40559	1012 ALTA CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476728		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	01/26/2012	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 09:51 PM	

Discharge Reporting:

Discharge Amount:	144,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479613
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	41374	300 MOCKINGBIRD VALLEY RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476755		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	03/27/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 09:48 AM	

Discharge Reporting:

Discharge Amount:	22,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479730
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	43726	1108 DUPONT CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476759		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	12/27/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 10:33 AM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479739
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45796	1011 ALTA CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463111		11/18/2015	FIELDS	GRIFFITH	DOCUMENTED	05/10/2014	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 06:13 AM	

Discharge Reporting:

Discharge Amount:	288,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463229
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476098		12/23/2015 9:47:00PM	GRIFFITH	FIELDS	DOCUMENTED	05/10/2014	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 10:46 AM	

Discharge Reporting:

Discharge Amount:	28,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476274
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476731		12/27/2015 1:21:00PM	GRIFFITH	FIELDS	DOCUMENTED	05/10/2014	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 11:16 AM	

Discharge Reporting:

Discharge Amount:	540,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479830
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45835	1132 ROSTREVOR CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463112		11/18/2015	FIELDS	GRIFFITH	DOCUMENTED	09/02/2003	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 05:21 PM	

Discharge Reporting:

Discharge Amount:	13,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463139
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476100		12/23/2015 9:32:00PM	GRIFFITH	FIELDS	DOCUMENTED	09/02/2003	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 01:57 PM	

Discharge Reporting:

Discharge Amount:	6,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476276
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476734		12/27/2015 1:16:00PM	GRIFFITH	FIELDS	DOCUMENTED	09/02/2003	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 03:15 PM	

Discharge Reporting:

Discharge Amount:	384,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479992
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45900	1122 ROSTREVOR CIR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476106		12/23/2015	FIELDS	GRIFFITH	DOCUMENTED	12/27/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 11:01 AM	

Discharge Reporting:

Discharge Amount:	10,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476288
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	46623	4801 CASSIA CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476751		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	04/03/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 09:38 AM	

Discharge Reporting:

Discharge Amount:	270,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479726
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47582	201 BULLITT LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476103		12/23/2015	FIELDS	GRIFFITH	DOCUMENTED	12/05/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 11:30 AM	

Discharge Reporting:

Discharge Amount:	10,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476282
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47583	202 OXMOOR LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463113		11/11/2015	FIELDS	GRIFFITH	DOCUMENTED	02/06/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 06:45 AM	

Discharge Reporting:

Discharge Amount:	28,800 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463250
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476101		12/23/2015 10:14:00PM	GRIFFITH	FIELDS	DOCUMENTED	02/06/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 11:30 AM	

Discharge Reporting:

Discharge Amount:	18,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476278
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476735		12/27/2015 2:04:00PM	GRIFFITH	FIELDS	DOCUMENTED	02/06/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 12:25 PM	

Discharge Reporting:

Discharge Amount:	576,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479849
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47593	8021 CHRISTIAN CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476741		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:36 AM	

Discharge Reporting:

Discharge Amount:	108,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479663
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47603	8016 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476742		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:38 AM	

Discharge Reporting:

Discharge Amount:	108,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479667
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	51160	3305 INDIAN CREEK CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476764		12/27/2015	MITCHELL	GRIFFITH	DOCUMENTED	04/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 12:45 PM	

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479863
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	51594	1418 TREVILIAN WAY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2452991		10/27/2015	MITCHELL	GRIFFITH	DOCUMENTED	09/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	10/27/15 09:09 PM	

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2454452
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

10/24/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
10/24/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2463123		11/18/2015 1:12:00PM	GRIFFITH	MITCHELL	DOCUMENTED	09/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 06:00 PM	

Discharge Reporting:

Discharge Amount:	3,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463130
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476085		12/23/2015 7:50:00PM	GRIFFITH	MITCHELL	DOCUMENTED	09/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/23/15 09:40 PM	

Discharge Reporting:

Discharge Amount:	5,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476246
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476721		12/27/2015 11:45:00AM	GRIFFITH	MITCHELL	DOCUMENTED	09/12/2006	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 10:55 AM	

Discharge Reporting:

Discharge Amount:	22,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479567
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	60679	9114 CINDERELLA LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476648		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	12/15/2007	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:40 AM	

Discharge Reporting:

Discharge Amount:	22,000 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE ON THE GROUND
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	MSD USED TEMPORARY SIGNS TO WARN THE PUBLIC

Notifications:

12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	61266	4005 KIRBY LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476656		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	01/13/2013	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 06:00 AM	

Discharge Reporting:

Discharge Amount:	53,750 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	MSD CLEANED & SANITIZED THE AREA
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	MSD USED TEMPORARY SIGNS TO WARN PUBLIC

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	63095	9300 HAYES AVE		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476615		12/27/2015	DAVIS	BLANFORD	DOCUMENTED	04/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 04:05 PM	

Discharge Reporting:

Discharge Amount:	3,150 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	TEMP SIGNS AND CAUTION TAPE
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS AND SIGNS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	63531	6810 GLENDALE RD		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476633		12/27/2015	DAVIS	BLANFORD	DOCUMENTED	12/27/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 05:00 PM	

Discharge Reporting:

Discharge Amount:	900 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	TEMP SIGNS TAPE
Impact:	SEWAGE AND DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65516	12400 BRIERLY HILL PL		FLOYDS FORK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476636		12/27/2015	DAVIS	BLANFORD	DOCUMENTED	12/27/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 05:00 PM	

Discharge Reporting:

Discharge Amount:	900 GAL
Cause:	LACK OF SYSTEM CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	TAPE AND SIGNS
Impact:	SEWAGE
Repair:	AREA INCLUDED IN IOAP
Public Notification:	DOOR CARDS

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	65623	1804 ROUND RIDGE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476750		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	06/23/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/29/15 09:38 AM	

Discharge Reporting:

Discharge Amount:	45,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479719
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	66349	3726 FINCASTLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463121		11/18/2015	MITCHELL	GRIFFITH	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 06:12 PM	

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463151
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/18/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476081		12/23/2015 8:15:00PM	GRIFFITH	MITCHELL	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/24/15 09:38 AM	

Discharge Reporting:

Discharge Amount:	3,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476221
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476724		12/27/2015 11:51:00AM	GRIFFITH	MITCHELL	DOCUMENTED	03/04/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 11:15 AM	

Discharge Reporting:

Discharge Amount:	21,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479571
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	67535	9 MUIRFIELD PL		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476745		12/27/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	03/26/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:44 AM	

Discharge Reporting:

Discharge Amount:	27,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479676
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	69305	15026 BIRCHAM RD		FLOYDS FORK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476697		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	12/17/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 07:40 AM	

Discharge Reporting:

Discharge Amount:	24,375 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	NO DEBRIS
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	TEMPORARY SIGNS USED TO WARN PUBLIC

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	72289	1700 SULGRAVE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2463109		11/18/2015	FIELDS	GRIFFITH	DOCUMENTED	05/29/2012	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	11/18/15 05:31 PM	

Discharge Reporting:

Discharge Amount:	13,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2463125
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

11/18/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476727		12/27/2015 1:26:00PM	GRIFFITH	FIELDS	DOCUMENTED	05/29/2012	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 11:03 AM	

Discharge Reporting:

Discharge Amount:	33,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479589
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	73111	3705 BARDSTOWN RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2473300		12/16/2015	BIVIN	BIVIN	REPAIRED - ISSUE RESOLVED	12/16/2015	GREASE BLOCKAGE	UNAUTHORIZED DISCHARGE - WATERS	12/16/15 11:45 AM	

Discharge Reporting:

Discharge Amount:	250 GAL
Cause:	GREASE IN THE MAIN SEWER
Clean Up:	MSD CLEANED AREA
Control Zone:	TRUCK AND MSD EMPLOYEES & CONES
Impact:	OBSERVED MH DISCHARGEING INTO CATCHBASIN
Repair:	REFERRED TO IWD
Public Notification:	ON SITE

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	74513	1106 BROADFIELDS DR		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476760		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	12/27/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 10:26 AM	

Discharge Reporting:

Discharge Amount:	45,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479746
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	84155	7913 SHELBYVILLE RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476748		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	03/10/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:57 AM	

Discharge Reporting:

Discharge Amount:	153,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479679
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	89791	37 ARROWHEAD RD		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476754		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	06/23/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 09:39 AM	

Discharge Reporting:

Discharge Amount:	24,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479714
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	90700	8021 CHRISTIAN CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476740		12/27/2015	FIELDS	GRIFFITH	DOCUMENTED	03/19/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 08:33 AM	

Discharge Reporting:

Discharge Amount:	54,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479660
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	96673	3920 DUTCHMANS LN		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476762		12/27/2015	FIELDS	GRIFFITH	BEYOND APPROVED DESIGN STORM	04/27/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 10:31 AM	

Discharge Reporting:

Discharge Amount:	45,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479750
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	96911A-V	912 EASTWOOD FISHERVILLE RD		FLOYDS FORK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2451472		10/23/2015	HUBER	OPS CSHIFT	REPAIRED - ISSUE RESOLVED	10/23/2015	STRUCTURAL FAILURE	UNAUTHORIZED DISCHARGE - WATERS	10/23/15 08:30 PM	

Discharge Reporting:

Discharge Amount:	500 GAL
Cause:	FM BREAK
Clean Up:	MSD CLEAN AND SANITIZE AREA AFTER CONTRACTOR REPAIRS
Control Zone:	TEMP SIGNS
Impact:	SEWAGE
Repair:	CLOSED 16" FM OPENED 24" FM DISCHARGE STOPPED
Public Notification:	DISDW PAGE SENT OUT

Notifications:

10/23/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
10/23/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	97363	10800 FAIRMOUNT RD		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476685		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	12/28/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 11:00 AM	

Discharge Reporting:

Discharge Amount:	172,800 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	DISCLN #2480332
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR & EVALUATE FOR REPAIR
Public Notification:	TEMPORARY SIGNS USED TO WARN PUBLIC

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0098540	MSD0289	CEDAR CREEK	CEDAR CREEK	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	97365	10800 FAIRMOUNT RD		CEDAR CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476557		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	12/30/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/30/15 08:09 AM	

Discharge Reporting:

Discharge Amount:	450,225 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	DISCLN #2480333
Control Zone:	TEMPORARY SIGNS POSTED
Impact:	SEWAGE OBSERVED
Repair:	SITE FOUND DURING RAIN EVENT RECON- WILL MONITOR AND EVALUATE FOR REPAIR
Public Notification:	SIGNS USED TO WARN PUBLIC

Notifications:

12/24/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/24/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center			Receiving Stream of Treatment Center			Region			
KY0098540 (Cont'd)	MSD0289	CEDAR CREEK			CEDAR CREEK			CENT			
<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2480711		12/30/2015 3:30:00PM	FELDKAMP	DAVIS	DOCUMENTED	12/30/2015	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHAGE - WATERS	12/31/15 08:00 AM	

Discharge Reporting:

Discharge Amount:	99,000 GAL
Cause:	LACK OF CAPACITY
Clean Up:	MSD TO CLEAN AND SANITIZE AFFECTED AREA
Control Zone:	SIGN BARRICADES
Impact:	DISCOLORATION IN STREAM
Repair:	AREA INCLUDED IN IOAP
Public Notification:	CARDS

Notifications:

12/29/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/29/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	BU05074039	3305 BENT CREEK CT		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476766		12/27/2015	MITCHELL	GRIFFITH	DOCUMENTED	02/24/2011	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 10:37 AM	

Discharge Reporting:

Discharge Amount:	54,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479756
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	CSO113	1215 ELLISON AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2456311		11/02/2015	BRIGHT	BRIGHT	REPAIRED - ISSUE RESOLVED	09/14/2015	OBSTRUCTION-N OT GREASE / ROOTS	UNAUTHORIZED DISCHAGE - WATERS	11/02/15 10:37 AM	

Discharge Reporting:

Discharge Amount:	9 GAL
Cause:	UNKNOWN OBSTRUCTION IN LOW FLOW LINE
Clean Up:	FLUSHED LINE TO MITIGATE. NO CLEAN-UP NECESSARY
Control Zone:	N/A
Impact:	NONE
Repair:	FLUSHED THE LINE TO MITIGATE
Public Notification:	N/A

Notifications:

10/28/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISDWDRY WEATHER DISCHARGE	2464186		11/23/2015 10:16:00AM	BRIGHT	BRIGHT	REPAIRED - ISSUE RESOLVED	09/14/2015	OBSTRUCTION- NOT GREASE / ROOTS	UNAUTHORIZED DISCHARGE - WATERS	11/23/15 11:38 AM	

Discharge Reporting:

Discharge Amount:	82 GAL
Cause:	HEAVY LEAVES (BUILD UP AT REDUCER/LOW-FLOW
Clean Up:	NONE NOTED. OVERFLOWS DIRECTLY INTO CREEK
Control Zone:	NONE NEEDED
Impact:	NONE NOTED. DISCHARGE DIRECTLY INTO CREEK
Repair:	FLUSHED LINE AND RELIEVED OBSTRUCTION
Public Notification:	INFORMED CONTRACTORS WORKING IN CREEK IN PERSON

Notifications:

11/19/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
------------------	--------	---



Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	KK14815019	4108 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476087		12/23/2015	MITCHELL	GRIFFITH	DOCUMENTED	07/29/2009	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/23/15 09:50 PM	

Discharge Reporting:

Discharge Amount:	1,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476246
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2476716		12/27/2015 11:32:00AM	GRIFFITH	MITCHELL	DOCUMENTED	07/29/2009	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 11:03 AM	

Discharge Reporting:

Discharge Amount:	27,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479559
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SSL Sewer Service Line	KK14855239	4107 LEE AVE		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476090		12/23/2015	MITCHELL	GRIFFITH	DOCUMENTED	05/15/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/23/15 09:53 PM	

Discharge Reporting:

Discharge Amount:	2,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2476263
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/17/15 1:01 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/17/15 1:01 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2476718		12/27/2015 11:33:00AM	GRIFFITH	MITCHELL	DOCUMENTED	05/15/2008	LACK OF SYSTEM CAPACITY	UNAUTHORIZED DISCHARGE - WATERS	12/28/15 11:00 AM	

Discharge Reporting:

Discharge Amount:	5,400 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2479563
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	LOCATION INCLUDED IN IOAP
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD0022-PS	1800 NIGHTINGALE RD	NIGHTINGALE	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2481317		12/31/2015	MARKS JR	OPS BSHIFT CENTRAL	REPAIRED - ISSUE RESOLVED	12/31/2015	STRUCTURAL FAILURE	UNAUTHORIZED DISCHAGE - WATERS	12/31/15 11:40 PM	

Discharge Reporting:

Discharge Amount:	621,132 GAL
Cause:	FAILURE OF FORCE MAIN ON PHILLIPS LANE STATION HAD TO BE SHUT DOWN FOR REPAIR CAUSING WET WELL TO OVERFLOW
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEANUP
Control Zone:	SIGNS AND TEMPORARY SIGNS AND MSD CUSTOMER CARE AND CHAIN OF COMMAND NOTIFIED
Impact:	SEWAGE , DEBRIS OBSERVED
Repair:	CONTRACTOR REPAIRED FORCE MAIN AND STATION PLACED BACK IN SERVICE @ 2330 HRS 12/31/15
Public Notification:	SIGNS AND MSD CUSTOMER CARE USED TO WARN PUBLIC

Notifications:

12/31/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/31/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0029416	MSD0228	MCNEELY LAKE	PENNSYLVANIA RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0228	10300 ROD N REEL RD		PENNSYLVANIA RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2467155		12/01/2015	THOMPSON	OPS BSHIFT CENTRAL	REPAIRED - ISSUE RESOLVED	12/01/2015	BYPASS AT WQTC	UNAUTHORIZED DISCHAGE - WATERS	12/01/15 09:10 AM	

Discharge Reporting:

Discharge Amount:	31,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	DUE TO HIGH FLOW IN CREEK NO CLEAN UP
Control Zone:	SIGNS
Impact:	SOLIDS
Repair:	OPERATOR TURNED AIR OFF PLANT TO STOP SOLIDS FROM GOING OVER WEIR
Public Notification:	SIGNS

Notifications:

11/23/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/23/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0031712	MSD0247	STARVIEW	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0247	423 BERMUDA WAY		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2467165		12/01/2015	THOMPSON	OPS BSHIFT CENTRAL	REPAIRED - ISSUE RESOLVED	12/01/2015	BYPASS AT WQTC	UNAUTHORIZED DISCHAGE - WATERS	12/01/15 10:00 AM	

Discharge Reporting:

Discharge Amount:	17,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	DUE TO HIGH FLOW IN CREEK NO CLEAN UP NEEDED
Control Zone:	SIGNS
Impact:	SOLIDS
Repair:	OPERATOR TURNED AIR OFF TO STOP BYPASSING OVER WEIR
Public Notification:	SIGNS

Notifications:

11/23/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/23/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0025194	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0255	10725 OLD TAYLORSVILLE RD		CHENOWETH RUN	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2452977		10/27/2015	HUBER	OPS CSHIFT	DOCUMENTED	01/14/2007	BLENDING AT JTOWN WQTC	UNAUTHORIZED DISCHARGE - WATERS	10/28/15 06:27 PM	

Discharge Reporting:

Discharge Amount:	2,514,321 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS ARE POSTED AT THIS PLANT
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET WEATHER
Public Notification:	PERMANENT SIGNS ARE POSTED AROUND THE AFFECTED AREA

Plant Details:

DAILY TOTAL PLANT FLOW	15,281,000 GAL
PEAK PLANT FLOW WHEN BLENDING	13,656,000 GPD

Notifications:

10/24/15 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
10/24/15 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

<u>Activity Code / Description</u>	<u>WO #</u>	<u>Ref No</u>	<u>Initiated</u>	<u>Initiated By</u>	<u>Assigned To</u>	<u>Disch Status</u>	<u>Event Date</u>	<u>Problem</u>	<u>Result</u>	<u>Completed</u>	<u>Condition</u>
: DISREVRAIN EVENT DISCHARGE	2462919		11/18/2015 11:54:00AM	OPS BSHIFT CENTRAL	BROOKS	DOCUMENTED	01/14/2007	BLENDING AT JTOWN WQTC	UNAUTHORIZED DISCHAGE - WATERS	11/19/15 01:10 AM	

Discharge Reporting:

Discharge Amount:	1,940,645 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	PERMANENT SIGNS POSTED
Impact:	NO IMPACT OBSERVED- PIPE DISCHARGE SUBMERGED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED AT THIS LOCATION WHEN FLOW HAS BEEN OPTIMIZED DURING WET WEATHER.
Public Notification:	PERMANENT SIGNS POSTED AT THIS LOCATION

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	16,911,000 GPD
DAILY TOTAL PLANT FLOW	13,585,000 GAL

Notifications:

11/2/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/2/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0025194 (Cont'd)	MSD0255	JEFFERSONTOWN	CHENOWETH RUN	CENT

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREVRAIN EVENT DISCHARGE	2467069		12/1/2015 4:12:00AM	OPS BSHIFT CENTRAL	THOMPSON	DOCUMENTED	01/14/2007	BLENDING AT JTOWN WQTC	UNAUTHORIZED DISCHAGE - WATERS	12/01/15 02:02 PM	

Discharge Reporting:

Discharge Amount:	407,810 GAL
Cause:	LACK OF SYSTEM CAPACITY DUE TO RAIN EVENT
Clean Up:	PIPE DISCHARGE SUBMERGED- NO CLEAN UP
Control Zone:	SIGNS AT CREEK
Impact:	NO IMPACT OBSERVED
Repair:	TEMPORARY BLENDING HAS BEEN NEGOTIATED FOR THIS LOCATION WHEN FLOW THROUGH THE PLANT HAS BEEN OPTIMIZED DURING WET WEATHER
Public Notification:	PERMANENT SIGNS ARE POSTED

Plant Details:

PEAK PLANT FLOW WHEN BLENDING	13,344,000 GPD
DAILY TOTAL PLANT FLOW	8,938,000 GAL

Notifications:

11/23/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/23/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0278	4522 ALGONQUIN PKY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2439679		10/05/2015	BURCH	BURCH	REPAIRED - ISSUE RESOLVED	10/05/2015	BYPASS AT WQTC	UNAUTHORIZED DISCHAGE - WATERS	10/05/15 10:00 AM	

Discharge Reporting:

Discharge Amount:	300 GAL
Cause:	VALVING NOT SET UP CORRECTLY
Clean Up:	MSD CLEANED AND SANITIZED AREA
Control Zone:	CONES AND BARRICADES
Impact:	SEWAGE
Repair:	SUMP PUMP WAS TURNED OFF
Public Notification:	NONE

Notifications:

9/29/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/29/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SLS Sewer Lift Station	MSD1010-PS	5006 LEA ANN WAY	LEA ANN WAY	OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT DISCHARGE	2476660		12/27/2015	MARKS JR	OPS BSHIFT CENTRAL	DOCUMENTED	12/15/2007	PUMPED OVERFLOW	UNAUTHORIZED DISCHARGE - WATERS	12/27/15 09:45 PM	

Discharge Reporting:

Discharge Amount:	1,990,000 GAL
Cause:	RAIN EVENT CAUSED A LACK OF SYSTEM CAPACITY
Clean Up:	MSD CLEANED AND SANITIZED THE AREA
Control Zone:	PERMANENT SIGNS POSTED
Impact:	SEWAGE PUMPED TO DITCH
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP
Public Notification:	PERMANENT SIGNS POSTED

Notifications:

12/27/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/27/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Report Selections: Period: 10/01/2015 00:00 thru 12/31/2015 23:59, Excluding PPI Excluding CSO Excluding LAT, Result: WUS, Act Code: DISDW, DISREV

KPDES #	Facility ID	Water Quality Treatment Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	MSD1064-PS	8619 WESTOVER DR		HITE CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER DISCHARGE	2472955		12/15/2015	SINGLETON	OPS BSHIFT CENTRAL	REPAIRED - ISSUE RESOLVED	12/15/2015	STRUCTURAL FAILURE	UNAUTHORIZED DISCHAGE - WATERS	12/15/15 11:42 AM	

Discharge Reporting:

Discharge Amount:	25 GAL
Cause:	FORCE MAIN BREAK
Clean Up:	NO CLEAN UP- THIS IS AN ACTIVE CONSTRUCTION SITE.
Control Zone:	NO CONTROL ZONE- THIS IS AN ACTIVE CONSTRUCTION SITE
Impact:	SEWAGE OBSERVED
Repair:	CONTRACTOR REPAIRED THE FORCE MAIN
Public Notification:	NO PUBLIC NOTIFICATION- THIS IS AN ACTIVE CONSTRUCTION SITE

Notifications:

12/1/15 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/1/15 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 81

Total Work Orders Printed: 118