

Appendix A-1 Discharge Work Orders - Dry Weather CSOs



Appendix A-1 Discharge Work Orders - Dry Weather CSOs

# No Dry Weather CSOs Occurred During the Reporting Period



Appendix A-2 Discharge Work Orders – Bypass



KPDES #	Facility ID Water Quality Treatement Center		Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0278	4522 ALGONQUIN PKY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2649740		11/28/2016	BURCH	BURCH	REPAIRED -	01/20/2017	BYPASS AT	UNAUTHORIZED	11/28/16 09:15	
DISCHARGE						ISSUE		WQTC	DISCHAGE - WATERS	PM	
						RESOLVED					

## Discharge Reporting:

Discharge Amount:	150.000 GAL
Discharge Amount.	
Cause:	MECHANICAL FAILURE WEST HEADWORKS.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP.
Impact:	WEST HEADWORKS OVERFLOWED TO STREET, CATCH BASINS NEAR SECONDARY FLOW TO THE RIVER.
Repair:	DIVERTED FLOW FROM WEST HEADWORKS.
Public Notification:	PERMANENT SIGN AT DISCHARGE POINT.

#### Notifications:

11/20/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'

3/23/2017 Page 1 of 2 3:05:06 PM



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411 (Cont'd)MSD0278MORRIS FORMANOHIO RIVERWEST

**WO**# Ref No <u>Initiated</u> Initiated By **Assigned To Disch Status Event Date Problem** Completed Condition **Activity Code / Description** Result **BURCH** BYPASS AT 2657831 12/17/2016 **BURCH** REPAIRED -01/20/2017 : DISREVRAIN EVENT UNAUTHORIZED 12/17/16 09:05 6:27:00PM ISSUE WQTC DISCHARGE **DISCHAGE - WATERS** PM **RESOLVED** 

#### Discharge Reporting:

Discharge Amount:	50,000 GAL
Cause:	ELECTRICAL FAULT. EAST HEADWORKS ELECTRICAL ROOM DAMAGED BY STORM AND ROOF FAILURE.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	NO CONTROL ZONE ESTABLISHED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Impact:	NO VISUAL IMPACT – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Repair:	POWER TEMPORARILY RE-ROUTED UNTIL PERMANENT REPAIRS ARE COMPLETE.
Public Notification:	PERMANENT SIGN AT DISCHARGE POINT

#### Notifications:

12/13/16 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,	
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'	

**Total Facilities Printed: 1** 

Total Work Orders Printed: 2

3/23/2017 Page 2 of 2 3:05:08 PM



Appendix A-3 Discharge Work Orders – Unauthorized Discharges



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411MSD0278MORRIS FORMANOHIO RIVERWEST

Facility Type Facility ID Facility Address If Pump Station, Name of Pump Station: Receiving Stream Discharge to
SMH Sewer Manhole 02933 7900 SHELBYVILLE RD MIDDLE FORK BEARGRASS CREEK STREAM

WO # **Activity Code / Description** Ref No Initiated Initiated By Assigned To **Disch Status Event Date Problem** Result Completed Condition : DISREV: RAIN EVENT 2657928 12/18/2016 **BAILEY** MITCHELL DOCUMENTED 03/04/2008 LACK OF UNAUTHORIZED 12/18/16 10:06 DISCHARGE SYSTEM DISCHAGE - WATERS CAPACITY

#### Discharge Reporting:

Discharge Amount:	63,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657963
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE

#### Notifications:

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

3/23/2017 Page 1 of 28 3:02:07 PM



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	02935	7900 SHELBYVILLE RD		MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657927		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	03/19/2008	LACK OF	UNAUTHORIZED	12/18/16 10:03	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	12,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657962
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewe	Main 06940D-AG	3706 NOBEL CT		MILL CREEK	GROUND

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER	2655257		12/13/2016	ROTTET JR	CHESSER	REPAIRED -	12/13/2016	STRUCTURAL	UNAUTHORIZED	12/13/16 08:30	
DISCHARGE						ISSUE		FAILURE	DISCHAGE - WATERS	AM	
						RESOLVED					

## Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	FORCE MAIN BREAK.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	TEMPORARY SIGNS SET UP
Impact:	SOLIDS, PERSONAL HYGIENE PRODUCTS, SEWAGE
Repair:	SHUT OFF PUMPS, B&H HAULED STATION WHILE CHEROKEE CONSTRUCTION MADE REPAIRS TO FORCE MAIN.
Public Notification:	PAGE SENT OUT FOR DRY WEATHER DISCHARGE

12/13/16 1:00 am	DIS	SNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
			SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08717	3726 FINCASTLE RD		SOUTH FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657884		12/18/2016	AYO II	MITCHELL	DOCUMENTED	12/15/2007	LACK OF	UNAUTHORIZED	12/18/16 04:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	9,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657960
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	08935-SM	1001 BRECKENRIDGE LN		MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657856		12/17/2016	MITCHELL	MITCHELL	DOCUMENTED	11/29/2001	LACK OF	UNAUTHORIZED	12/18/16 10:50	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	1,833,191 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/13/16 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/13/16 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	113063	6126 SPRINGHOUSE FAR	RM LN	GOOSE CREEK	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2655074		12/12/2016	SINGLETON	CPSM	REPAIRED -	12/12/2016	STRUCTURAL	UNAUTHORIZED	12/12/16 07:40	
DISCHARGE						ISSUE		FAILURE	DISCHAGE - WATERS	PM	
						RESOLVED					

## Discharge Reporting:

Discharge Amount:	1,240 GAL
Cause:	DRAINAGE UNDERMINED SANITARY SEWER LINE, RESULTING IN COLLAPSE AND OVERFLOW.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	TEMPORARY SIGNS PLACED.
Impact:	SEWAGE OBSERVED.
Repair:	CONTRACTOR TO REPAIR THE LINE.
Public Notification:	TEMPORARY SIGNS PLACED AROUND THE AFFECTED AREA.

# Notifications:

11/29/16 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/29/16 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

3/23/2017 Page 6 of 28 3:02:18 PM



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	116490	9810 U S HIGHWAY 42		HUNTING CREEK	DITCH

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657894		12/18/2016	ROTTET JR	<b>HUDGINS JR</b>	REPAIRED -	12/18/2016	MECHANICAL	UNAUTHORIZED	12/18/16 04:53	
DISCHARGE						ISSUE		FAILURE	DISCHAGE - WATERS	AM	
						RESOLVED					

## Discharge Reporting:

Discharge Amount:	3,150 GAL
Cause:	MOTOR FAILURE ON ONE PUMP, THE OTHER STOPPED UP WITH DEBRIS.
Clean Up:	NO CLEAN UP PERFORMED - PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	TEMPORARY SIGNS
Impact:	SEWAGE
Repair:	PULLED GOOD PUMP AND REMOVED DEBRIS.
Public Notification:	TEMPORARY SIGNS UP

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	15195	1700 SULGRAVE RD		MIDDLE FORK BEARGRASS CREEK	STREAM

<b>Activity Code / Description</b>	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657882		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	07/12/2015	LACK OF	UNAUTHORIZED	12/18/16 09:27	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657955
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	16649	1726 FRASER DR		SOUTH FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657926		12/17/2016	AYO II	MITCHELL	DOCUMENTED	01/24/2002	LACK OF	UNAUTHORIZED	12/18/16 05:45	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	10,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657943
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27005	1012 ALTA CIR		MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657877		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	09/02/2003	LACK OF	UNAUTHORIZED	12/18/16 09:21	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657950
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	27007	1013 ALTA CIR		MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657874		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	02/05/2014	LACK OF	UNAUTHORIZED	12/18/16 09:18	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	10,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657948
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES#	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	28249	3500 ST EDWARDS DR		CHENOWETH RUN	DITCH

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	<u>Condition</u>
: DISREV: RAIN EVENT	2657930		12/18/2016	AYO II	MITCHELL	DOCUMENTED	03/12/2006	LACK OF	UNAUTHORIZED	12/18/16 10:15	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	11,250 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657965
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	40559	1012 ALTA CIR		MIDDLE FORK BEARGRASS CREEK	STREAM

<b>Activity Code / Description</b>	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657881		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	01/26/2012	LACK OF	UNAUTHORIZED	12/18/16 09:24	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657954
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45796	1011 ALTA CIR		MIDDLE FORK BEARGRASS CREEK	DITCH

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657876		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	05/10/2014	LACK OF	UNAUTHORIZED	12/18/16 09:19	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657949
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45829	2002 MILLVALE RD		MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657873		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	03/09/2011	LACK OF	UNAUTHORIZED	12/18/16 09:15	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	12,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657947
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

# Notifications:

12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

3/23/2017 Page 15 of 28 3:02:18 PM



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	45835	1132 ROSTREVOR CIR		MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657872		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	09/02/2003	LACK OF	UNAUTHORIZED	12/18/16 09:10	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	48,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657946
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	47583	202 OXMOOR LN		MIDDLE FORK BEARGRASS CREEK	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657925		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	02/06/2008	LACK OF	UNAUTHORIZED	12/18/16 09:50	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	10,500 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657961
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	66349	3726 FINCASTLE RD		CAMP TAYLOR DITCH	GROUND

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	<u>Condition</u>
: DISREV: RAIN EVENT	2657883		12/18/2016	AYO II	MITCHELL	DOCUMENTED	03/04/2008	LACK OF	UNAUTHORIZED	12/18/16 04:30	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	1000 CAL
Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657956
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	66847H-CO	7106 COVERED COVE WAY		HUNTING CREEK	DITCH

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	<u>Condition</u>
: DISDW: DRY WEATHER	2647186		11/19/2016	DUNLAP	GRAY JR	REPAIRED -	11/19/2016	UTILITY	UNAUTHORIZED	11/19/16 03:45	
DISCHARGE						ISSUE		DAMAGED MSD	DISCHAGE - WATERS	PM	
						RESOLVED		ASSET			

## Discharge Reporting:

Discharge Amount:	25 GAL
Cause:	CONTRACTOR DAMAGED FORCE MAIN.
Clean Up:	CONTRACTOR CLEANED AND SANITIZED THE AREA.
Control Zone:	PLACED DISCHARGE SIGNS.
Impact:	WATER FLOWING INTO CREEK.
Repair:	REFERRED TO AREA SUPERVISOR FOR REPAIRS.
Public Notification:	ADVISED CUSTOMER ON-SITE.

9/26/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/26/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022420	MSD0202	HITE CREEK	HITE CREEK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	68562-AG	7104 COVERED COVE WAY		HUNTING CREEK	DITCH

<b>Activity Code / Description</b>	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	Completed	Condition
: DISDW: DRY WEATHER	2647172		11/19/2016	BRAZEL	GRAY JR	REPAIRED -	11/19/2016	UTILITY	UNAUTHORIZED	11/19/16 03:45	
DISCHARGE						ISSUE		DAMAGED MSD	DISCHAGE - WATERS	PM	
						RESOLVED		ASSET			

## Discharge Reporting:

Discharge Amount:	800 GAL
Cause:	CONTRACTOR HIT SEWAGE FORCE MAIN WHILE EXCAVATING.
Clean Up:	CONTRACTOR CLEANED AND SANITIZED THE AREA.
Control Zone:	PLACED TEMPORARY SIGNS AROUND THE IMPACTED AREA.
Impact:	SEWAGE/DEBRIS/SOLIDS/PERSONAL HYGIENE PRODUCTS FOUND IN THE STREAM.
Repair:	SHUT OFF PUMPS, HAUL STATION WHILE REPAIRS MADE.
Public Notification:	ADVISED ALL POSSIBLE IMPACTED PROPERTIES IN THE SURROUNDING AREA IN PERSON.

9/26/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
9/26/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411MSD0278MORRIS FORMANOHIO RIVERWEST

Facility Type Facility ID Facility Address If Pump Station, Name of Pump Station: Receiving Stream Discharge to
SMH Sewer Manhole 72288 1604 CHEROKEE RD MIDDLE FORK BEARGRASS CREEK GROUND

WO # **Activity Code / Description** Ref No Initiated Initiated By Assigned To **Disch Status Event Date Problem** Result Completed Condition LACK OF 12/18/16 09:22 : DISREV: RAIN EVENT 2657879 12/18/2016 **BAILEY** MITCHELL DOCUMENTED 11/28/2011 UNAUTHORIZED DISCHARGE SYSTEM DISCHAGE - WATERS CAPACITY

#### Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657951
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	72289	1700 SULGRAVE RD		MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	<u>WO #</u>	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	<u>Problem</u>	Result	<u>Completed</u>	<u>Condition</u>
: DISREV: RAIN EVENT	2657880		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	05/29/2012	LACK OF	UNAUTHORIZED	12/18/16 09:23	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	1,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657953
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0102784	MSD0294	FLOYDS FORK	FLOYDS FORK	EAST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMN Sewer Main	80351C-AG	14307 WAKEFIELD PL		CHENOWETH RUN	CATCH BASIN

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	Event Date	Problem	Result	Completed	Condition
: DISDW: DRY WEATHER	2655123		12/12/2016	BRAZEL	GOODWIN	REPAIRED -	12/12/2016	STRUCTURAL	UNAUTHORIZED	12/12/16 11:25	
DISCHARGE						ISSUE		FAILURE	DISCHAGE - WATERS	PM	
						RESOLVED					

## Discharge Reporting:

Discharge Amount:	2,200 GAL
Cause:	FORCE MAIN BREAK.
Clean Up:	MSD PERSONNEL CLEANED AND SANITIZED THE IMPACTED AREA.
Control Zone:	TEMPORARY SIGNS WERE PLACED.
Impact:	SEWAGE OBSERVED ON THE GROUND.
Repair:	CONTRACTOR REPAIRED THE FORCE MAIN.
Public Notification:	CUSTOMER SERVICE WAS CONTACTED.

# Notifications:

11/29/16 1:00 pm	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
11/29/16 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

3/23/2017 Page 23 of 28 3:02:18 PM



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	84155	7913 SHELBYVILLE RD		MIDDLE FORK BEARGRASS CREEK	GROUND

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2657929		12/18/2016	BAILEY	MITCHELL	DOCUMENTED	03/10/2011	LACK OF	UNAUTHORIZED	12/18/16 10:20	
DISCHARGE								SYSTEM	DISCHAGE - WATERS	AM	
								CAPACITY			

## Discharge Reporting:

Discharge Amount:	63,000 GAL
Cause:	LACK OF SYSTEM CAPACITY-HEAVY RAIN.
Clean Up:	WO# 2657964
Control Zone:	CAUTION TAPE AND TEMPORARY SIGNS PLACED.
Impact:	LIGHT DEBRIS OBSERVED.
Repair:	A SOLUTION FOR THIS LOCATION IS INCLUDED IN THE IOAP.
Public Notification:	PUBLIC WAS NOTIFIED THROUGH DOOR HANGERS AND/OR TEMPORARY SIGNS TO AVOID CONTACT WITH DISCHARGE.

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0078956	MSD0277	DEREK R. GUTHRIE	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SMH Sewer Manhole	84926	5007 LEA ANN WAY		NORTHERN DITCH	STREAM

Activity Code / Description	WO #	Ref No	Initiated	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	Problem	Result	Completed	Condition
: DISREV: RAIN EVENT	2657902		12/18/2016	ROTTET JR	PAULEY	REPAIRED -	12/18/2016	MECHANICAL	UNAUTHORIZED	12/18/16 04:45	
DISCHARGE						ISSUE		FAILURE	DISCHAGE - WATERS	AM	
						RESOLVED					

## Discharge Reporting:

Discharge Amount:	10,000 GAL
Cause:	LACK OF SYSTEM CAPACITY DURING RAIN EVENT, ONE PUMP OUT OF SERVICE FOR LEA ANN WAY SYSTEM IMPROVEMENTS.
Clean Up:	MSD TO CLEAN AND SANITIZE IMPACTED AREA.
Control Zone:	TEMPORARY SIGNS SET UP ALONG CREEK.
Impact:	SEWAGE.
Repair:	PUMPED OUT OF MANHOLE WITH ONE 6" DISCHARGE PUMP TO PREVENT BASEMENT FLOODING IN SURROUNDING
	NEIGHBORHOODS.
Public Notification:	TEMPORARY SIGNS.

#### Notifications:

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'

3/23/2017 Page 25 of 28 3:02:18 PM



KPDES #Facility IDWater Quality Treatement CenterReceiving Stream of Treatment CenterRegionKY0022411MSD0278MORRIS FORMANOHIO RIVERWEST

Facility Type Facility ID Facility Address If Pump Station, Name of Pump Station: Receiving Stream Discharge to

SMH Sewer Manhole CS0018 1800 NIGHTINGALE RD SOUTH FORK BEARGRASS CREEK STREAM

WO # **Activity Code / Description** Ref No Initiated Initiated By Assigned To **Disch Status Event Date Problem** Result Completed Condition : DISREV: RAIN EVENT 2657914 12/17/2016 BRAZEL BOUTIN REPAIRED -12/18/2016 **MECHANICAL UNAUTHORIZED** 12/20/16 05:06 **ISSUE** DISCHARGE **FAILURE** DISCHAGE - WATERS AM **RESOLVED** 

#### Discharge Reporting:

Discharge Amount:	1,354,990 GAL
Cause:	PUMPS WERE SHUT OFF AT NIGHTINGALE PS TO REDUCE THE VOLUME BEHIND THE SWGS TO PREVENT SEWER RELATED FLOODING.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGES UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PIPE DISCHARGE SUBMERGED - NO CONTROL ZONE ESTABLISHED.
Impact:	PIPE DISCHARGE SUBMERGED - NO VISUAL IMPACT OBSERVED.
Repair:	PUMPS RESTARTED WHEN SYSTEM RECOVERED.
Public Notification:	WEBSITE OVERFLOW ADVISORY AND PERMANENT OVERFLOW WARNING SIGNS POSTED.

#### Notifications:

12/18/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG, SAYRE.DENNIS@EPAMAIL.EPA.GOV'
12/18/16 1:00 am	DISSNO	SUPPLEMENTAL EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE HAS BEEN SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
12/10/10 1:00 alli	DISSINO	SAYRE.DENNIS@EPAMAIL.EPA.GOV'

3/23/2017 Page 26 of 28 3:02:18 PM



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

Facility Type	Facility ID	Facility Address	If Pump Station, Name of Pump Station:	Receiving Stream	Discharge to
SPL Sewer Treatment Plant	MSD0278	4522 ALGONQUIN PKY		OHIO RIVER	STREAM

Activity Code / Description	WO #	Ref No	<u>Initiated</u>	Initiated By	Assigned To	Disch Status	<b>Event Date</b>	<u>Problem</u>	Result	Completed	Condition
: DISREV: RAIN EVENT	2649740		11/28/2016	BURCH	BURCH	REPAIRED -	01/20/2017	BYPASS AT	UNAUTHORIZED	11/28/16 09:15	
DISCHARGE						ISSUE		WQTC	DISCHAGE - WATERS	PM	
						RESOLVED					

## Discharge Reporting:

Discharge Amount:	150,000 GAL
Cause:	MECHANICAL FAILURE WEST HEADWORKS.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	PERMANENT SIGN IN PLACE – NO ADDITIONAL CONTROL ZONE SET UP.
Impact:	WEST HEADWORKS OVERFLOWED TO STREET, CATCH BASINS NEAR SECONDARY FLOW TO THE RIVER.
Repair:	DIVERTED FLOW FROM WEST HEADWORKS.
Public Notification:	PERMANENT SIGN AT DISCHARGE POINT.

11/20/16 1:00 am	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'



KPDES #	Facility ID	Water Quality Treatement Center	Receiving Stream of Treatment Center	Region
KY0022411 (Cont'd)	MSD0278	MORRIS FORMAN	OHIO RIVER	WEST

**WO**# Ref No <u>Initiated</u> Initiated By **Assigned To Disch Status Event Date Problem** Completed Condition **Activity Code / Description** Result **BURCH** BYPASS AT 2657831 12/17/2016 BURCH REPAIRED -01/20/2017 UNAUTHORIZED : DISREVRAIN EVENT 12/17/16 09:05 6:27:00PM **ISSUE** WQTC DISCHARGE **DISCHAGE - WATERS** PM **RESOLVED** 

#### Discharge Reporting:

Discharge Amount:	50,000 GAL
Cause:	ELECTRICAL FAULT. EAST HEADWORKS ELECTRICAL ROOM DAMAGED BY STORM AND ROOF FAILURE.
Clean Up:	NO CLEAN UP PERFORMED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Control Zone:	NO CONTROL ZONE ESTABLISHED – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Impact:	NO VISUAL IMPACT – PIPE DISCHARGING UNDERWATER, DIRECTLY INTO STREAM.
Repair:	POWER TEMPORARILY RE-ROUTED UNTIL PERMANENT REPAIRS ARE COMPLETE.
Public Notification:	PERMANENT SIGN AT DISCHARGE POINT

#### Notifications:

12/13/16 1:00 pm	DISNOT	EMAIL NOTIFICATION OF UNAUTHORIZED DISCHARGE SENT TO 'DISCHARGENOTICES@LOUISVILLEMSD.ORG,
		SAYRE.DENNIS@EPAMAIL.EPA.GOV'

Total Facilities Printed: 27

Total Work Orders Printed: 28

3/23/2017 Page 28 of 28 3:02:18 PM