



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

April 10, 2013

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

Re: MSD Metro Operations
McNeely Lake WQTC; KPDES No.: KY0029416
Discharge Monitoring Reports – March 2013.

Dear Ms. Cheryl Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the McNeely Lake WQTC, KPDES No.: KY0029416 for the month of March 2013.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMRs, please contact me at (502) 540-6031.

Sincerely,

A handwritten signature in black ink that reads "Duane V. Wright". The signature is fluid and cursive, with the first name "Duane" being the most prominent.

Duane V. Wright
Process Supervisor, Central region

JMK/McNeely Lake 03.13

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit

Permit #:

KY0029416

Major:

No

Permittee:

MCNEELY LAKE WQTC MSD

Permittee Address:

10300 ROD N REEL RD
LOUISVILLE, KY 40229

Facility:

MCNEELY LAKE WQTC MSD

Facility Location:

10300 ROD N REEL RD
LOUISVILLE, KY 40229

Permitted Feature:

001
External Outfall

Discharge:

001-1
SANITARY WASTEWATER

Report Dates & Status

Monitoring Period:

From 03/01/13 to 03/31/13

DMR Due Date:

04/28/13

Status:

NetDMR Validated

Considerations for Form Completion

Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

Principal Executive Officer

First Name:

Greg

Last Name:

Heitzman

Title:

Exec. Dir

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
201303McneelyWQTC_COVER.pdf	pdf	16790
201303McNeely_MOR.pdf	pdf	24052

Report Last Saved By

MCNEELY LAKE WQTC MSD

User:

wrightd

Name:

Duane Wright

E-Mail:

duane.wright@louisvillemسد.org

Date/Time:

2013-04-24 13:13 (Time Zone: -04:00)

McNeely Lake		Report for		Mar-13		Tot. Exc.=		0				
Tot. Flow=		4.06802		Concentrations				Pounds				
Date	Flow	TSS	BOD	NH3	Fecal	TSS	BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC
3/1/13	0.098									8.3	7.6	<0.010
3/2/13	0.109									8.3	7.5	<0.010
3/3/13	0.117	18	9	0.39		17.49	8.75	0.38	2.17	8.2	7.1	<0.010
3/4/13	0.104				78					8.3	7	<0.010
3/5/13	0.112									8.1	7.1	<0.010
3/6/13	0.118									7.4	7.5	<0.010
3/7/13	0.109									7.5	7.3	<0.010
3/8/13	0.098									7.4	7.2	<0.010
3/9/13	0.104									8	7.2	<0.010
3/10/13	0.105	11	6	0.9		9.60	5.24	0.79	3.3	7.5	7.1	<0.010
3/11/13	0.267				145					7.2	7.5	<0.010
3/12/13	0.187									7.9	7.7	<0.010
3/13/13	0.140									8.7	7	<0.010
3/14/13	0.111									7.7	7.6	<0.010
3/15/13	0.103									8	7.6	<0.010
3/16/13	0.106									7.3	6.9	<0.010
3/17/13	0.138									8.2	7	<0.010
3/18/13	0.349									7.9	7	<0.010
3/19/13	0.208									7.3	7.3	<0.010
3/20/13	0.152	3	4	0.45		3.81	5.07	0.57	1.44	8.6	7.6	<0.010
3/21/13	0.124				11					8.6	7.7	<0.010
3/22/13	0.103									8.8	7.3	<0.010
3/23/13	0.100									8.4	7	<0.010
3/24/13	0.139	3	3	0.45		3.47	3.47	0.52	2.95	8.9	7.2	<0.010
3/25/13	0.140				10					8.6	7.1	<0.010
3/26/13	0.115									8.8	7.2	<0.010
3/27/13	0.106									8.2	6.7	<0.010
3/28/13	0.105									8	7	<0.010
3/29/13	0.102									7.6	6	<0.010
3/30/13	0.100									7.2	6.3	<0.010
3/31/13	0.100									7.1	7	<0.010
Average	0.131	9	6	0.5	33	9	5.63	0.56	2.5	8.0	7	0.00
Maximum	0.349	18	9	0.9	145	17	8.75	0.8	3.3	8.9	8	0.00