



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

October 15, 2014

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

Re: MSD Metro Operations
McNeely Lake WQTC; KPDES No.: KY0029416
Discharge Monitoring Reports – September 2014.

Dear Ms. Cheryl Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the McNeely Lake WQTC, KPDES No.: KY0029416 for the month of September 2014.

There were no exceedences, bypasses or overflow reports for the month of September.

If you have any questions concerning the attached DMRs, please contact me at (502) 540-6031.

Sincerely,

A handwritten signature in black ink, appearing to read "John Kessel", with a stylized flourish at the end.

John Kessel
Process Supervisor, West region

JMK/McNeely Lake 0914

Enclosures

cc: T. Singleton
R. Shaw
C. Roth



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit

Permit #:

KY0029416

Major:

No

Permittee:

MCNEELY LAKE WQTC MSD

Permittee Address:

10300 ROD N REEL RD
LOUISVILLE, KY 40229

Facility:

MCNEELY LAKE WQTC MSD

Facility Location:

10300 ROD N REEL RD
LOUISVILLE, KY 40229

Permitted Feature:

001
External Outfall

Discharge:

001-1
SANITARY WASTEWATER

Report Dates & Status

Monitoring Period:

From 09/01/14 to 09/30/14

DMR Due Date:

10/28/14

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

Greg

Last Name:

Hetizman

Title:

Exec Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
Mcneely_Cover_092014.pdf	pdf	16773
Mcneely_MOR__092014.pdf	pdf	9120

Report Last Saved By


MCNEELY LAKE WQTC MSD

User:

kevin.ries@louisvillemsd.org

Date/Time:

2014-10-17 08:30 (Time Zone: -04:00)



McNeely Lake		Report for		Sep-14		Tot. Exc.=		0							
Tot. Flow=		2.54374		Concentrations				Pounds							
Date	Flow	TSS	BOD	NH3	Ecoli	TSS	BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC	Tot.N		
9/1/14	0.100	13	5	0.22		10.893	4.190	0.184	3.29	7.1	6.4	0.01	27.71		
9/2/14	0.088				1					7.2	6.5	0.01			
9/3/14	0.084									7.2	6.5	0.01			
9/4/14	0.085									7.2	6.4	0.01			
9/5/14	0.079									7.8	6.5	0.01			
9/6/14	0.082									7.3	6.3	0.01			
9/7/14	0.087									7.5	6.4	0.01			
9/8/14	0.077	11	3	0.28		7.093	1.935	0.181	3.76	7.6	6.1	0.01	29.11		
9/9/14	0.077				1					7.5		0.01			
9/10/14	0.078									7.5		0.01			
9/11/14	0.127									7.4		0.01			
9/12/14	0.099									7.2		0.01			
9/13/14	0.095									7.3		0.01			
9/14/14	0.096									7.1		0.01			
9/15/14	0.079	12	2	0.22		7.933	1.322	0.145	3.53	7.2		0.01	26.31		
9/16/14	0.080				2					8.3		0.01			
9/17/14	0.078									8.3		0.01			
9/18/14	0.076									8.1		0.01			
9/19/14	0.075									7.9	6	0.01			
9/20/14	0.085									7.6	6.5	0.01			
9/21/14	0.092									7	6.1	0.01			
9/22/14	0.080	13	4	0.22		8.645	2.660	0.146	3.595	8.4	6.4	0.01	32.11		
9/23/14	0.078				17					8.2	6.2	0.01			
9/24/14	0.077									7.3		0.01			
9/25/14	0.077									8.1		0.01			
9/26/14	0.099									8.1		0.01			
9/27/14	0.078									7	6.2	0.01			
9/28/14	0.085									7.3	6	0.01			
9/29/14	0.079									7.1		0.01			
9/30/14	0.073									7.3		0.01			
10/1/14															
Average	0.085	12	4	0.2	2.41	9	2.527	0.16	3.5	7.54	6	0.01	28.81		
Maximum	0.127	13	5	0.3	17.00	11	4.190	0.2	3.8	8.40	7	0.01	32.11		
Exceed.	0	0	0	0	0	0	0	0							