



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

April 21, 2014

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
McNeely Lake WQTC; KPDES No.: KY0029416
Discharge Monitoring Reports –March 2014.**

Dear Ms. Cheryl Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the McNeely Lake WQTC, KPDES No.: KY0029416 for the month of March 2014.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMRs, please contact me at (502) 540-6031.

Sincerely,

A handwritten signature in cursive script that reads "Duane V. Wright".

Duane V. Wright
Process Supervisor, Central region

JMK/McNeely Lake 03.14

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit			
Permit #:	KY0029416	Permittee:	MCNEELY LAKE WQTC MSD
Major:	No	Permittee Address:	10300 ROD N REEL RD LOUISVILLE, KY 40229
Permitted Feature:	001 External Outfall	Discharge:	001-1 SANITARY WASTEWATER
Facility:		Facility Location:	MCNEELY LAKE WQTC MSD 10300 ROD N REEL RD LOUISVILLE, KY 40229

Report Dates & Status			
Monitoring Period:	From 03/01/14 to 03/31/14	DMR Due Date:	04/28/14
Status:	NetDMR Validated		

Considerations for Form Completion
Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

Principal Executive Officer			
First Name:	Greg	Title:	Exec. Dir.
Last Name:	Heitzman	Telephone:	502-540-6000

No Data Indicator (NODI)
Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type				
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units		
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	8											01/01 - Daily	GR - GRAB		
					Permit Req.	>=	7 INST MIN													01/07 - Weekly	GR - GRAB
					Value NODI																
00400	pH	1 - Effluent Gross	0	--	Sample	=	6				=	8						23/30 - 23 Per Month	GR - GRAB		
					Permit Req.	>=	6 MINIMUM			<=	9 MAXIMUM								01/07 - Weekly	GR - GRAB	
					Value NODI																
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	5	=	9	26 - lb/d	=	7	=	11	19 - mg/L			01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	51 30DA AVG	<=	103 DAILY MX	26 - lb/d	<=	30 30DA AVG	<=	60 DAILY MX	19 - mg/L				01/07 - Weekly	CP - COMPOS	
					Value NODI																
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	2	--	Sample	=	0.4	=	0.6	26 - lb/d	=	0.5	=	0.7	19 - mg/L			01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	17 30DA AVG	<=	34 DAILY MX	26 - lb/d	<=	10 30DA AVG	<=	20 DAILY MX	19 - mg/L				01/07 - Weekly	CP - COMPOS	
					Value NODI																
00665	Phosphorus, total [as P]	1 - Effluent Gross	0	--	Sample						=	3.3	=	4.3	19 - mg/L			01/07 - Weekly	CP - COMPOS		
					Permit Req.							Req Mon 30DA AVG			Req Mon DAILY MX	19 - mg/L			01/30 - Monthly	CP - COMPOS	
					Value NODI																
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.106	=	0.228	03 - MGD								99/99 - Continuous	CN - CONTIN		
					Permit Req.		Req Mon 30DA AVG		Req Mon INST MAX	03 - MGD									99/99 - Continuous	CN - CONTIN	
					Value NODI																
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample						<	0.01	<	0.01	19 - mg/L			01/01 - Daily	GR - GRAB		
					Permit Req.						<=	.011 30DA AVG	<=	.019 DAILY MX	19 - mg/L			01/07 - Weekly	GR - GRAB		
					Value NODI																
74055	Coliform, fecal general	1 - Effluent Gross	0	--	Sample						=	31	=	93	13 - #/100mL			01/07 - Weekly	GR - GRAB		
					Permit Req.						<=	200 30DA GEO	<=	400 7 DA GEO	13 - #/100mL	0		01/07 - Weekly	GR - GRAB		
					Value NODI																
80082	BOD, carbonaceous, 05 day, 20 C	1 - Effluent Gross	0	--	Sample	=	6	=	8	26 - lb/d	=	7	=	9	19 - mg/L			01/07 - Weekly	CP - COMPOS		
					Permit Req.	<=	26 30DA AVG	<=	51 DAILY MX	26 - lb/d	<=	15 30DA AVG	<=	30 DAILY MX	19 - mg/L			01/07 - Weekly	CP - COMPOS		
					Value NODI																

Submission Note
If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
No errors.

Comments

Attachments		
Name	Type	Size
McNeely032014_MOR.pdf	pdf	24325
McNeely032014_COVER.pdf	pdf	17076

Report Last Saved By
MCNEELY LAKE WQTC MSD

User: wrightd | Date/Time: 2014-04-24 12:58 (Time Zone: -04:00)
Name: Duane Wright
E-Mail: duane.wright@louisvillemtd.org

McNeely Lake		Report for Mar-14			Tot. Exc.= 0							
Tot. Flow=	3.27951	Concentrations					Pounds					
Date	Flow	TSS	BOD	NH3	Fecal	TSS	BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC
3/1/14	0.099									9.6	6.5	0.01
3/2/14	0.120									10	6.8	0.01
3/3/14	0.119									9	6.5	0.01
3/4/14	0.116	5	8	0.22		4.831	7.729	0.213	2.69	9.5	6.3	0.01
3/5/14	0.111				74					8.1	6.1	0.01
3/6/14	0.118									8.5	6.3	0.01
3/7/14	0.104									9	7.1	0.01
3/8/14	0.113									9.5	6.8	0.01
3/9/14	0.111	4	5	0.22		3.706	4.632	0.204	2.54	9.3	6.9	0.01
3/10/14	0.103				93					9.1	6.5	0.01
3/11/14	0.100									8.3	6.7	0.01
3/12/14	0.096									9.1	6.7	0.01
3/13/14	0.087									8.7	7	0.01
3/14/14	0.083									8.7	7	0.01
3/15/14	0.084									8.1	7.3	0.01
3/16/14	0.091	6	5	0.7		4.537	3.781	0.529	3.83	8.9	7.5	0.01
3/17/14	0.084				34					9.1	7.3	0.01
3/18/14	0.082									8.1	7.3	0.01
3/19/14	0.083									8.2		0.01
3/20/14	0.079									9.1	6.3	0.01
3/21/14	0.077									8.7	6.1	0.01
3/22/14	0.080									10	6	0.01
3/23/14	0.093	11	9	0.73		8.549	6.995	0.567	4.27	9.8	6.1	0.01
3/24/14	0.092				4					8.3		0.01
3/25/14	0.108									8.9		0.01
3/26/14	0.105									9.7		0.01
3/27/14	0.106									9.7		0.01
3/28/14	0.228									8.5		0.01
3/29/14	0.168									9.1	6.3	0.01
3/30/14	0.135									8.7	6.4	0.01
3/31/14	0.103									8.3	6.5	0.01
Average	0.106	7	7	0.5	31.10	5	5.784	0.38	3.3	8.95	7	0.01
Maximum	0.228	11	9	0.7	93.00	9	7.729	0.6	4.3	10.00	8	0.01
Exceed.	1	0	0	0	0	0	0	0				