



700 West Liberty Street | Louisville, KY 40203-1911
Phone: 502.540.6000 | LouisvilleMSD.org

April 11, 2016

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
McNeely Lake WQTC; KPDES No.: KY0029416
Discharge Monitoring Reports –March 2016.**

Dear Ms. Cheryl Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the McNeely Lake WQTC, KPDES No.: KY0029416 for the month of March 2016.

There were no exceedances, overflows or bypasses for this month.

If you have any questions concerning the attached DMRs, please contact me at (502) 715-2789.

Sincerely,

Staci Huber
Process Supervisor

SMH/McNeely Lake 3/16

Enclosures

cc: T. Singleton
R. Shaw

DMR Copy of Record

Permit

Permit #:

KY0029416

Major:

No

Permittee:

MCNEELY LAKE WQTC MSD

Permittee Address:

10300 ROD N REEL RD
LOUISVILLE, KY 40229

Facility:

MCNEELY LAKE WQTC MSD

Facility Location:

10300 ROD N REEL RD
LOUISVILLE, KY 40229

Permitted Feature:

001
External Outfall

Discharge:

001-1
SANITARY WASTEWATER

Report Dates & Status

Monitoring Period:

From 03/01/16 to 03/31/16

DMR Due Date:

04/28/16

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

James A.

Last Name:

Parrott

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
201603_McNeely_coverletter.pdf	pdf	394048
201603_McNeely_MOR.pdf	pdf	388512

Report Last Saved By


MCNEELY LAKE WQTC MSD

User:

kevin.ries@louisvillemsd.org

Date/Time:

2016-04-15 12:48 (Time Zone: -04:00)



McNeely Lake		Report for		Mar-16		Tot. Exc.=		0						
Tot. Flow=		3.48349		Concentrations				Pounds						
Date	Flow	TSS	BOD	NH3	Ecoli	TSS	BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC	Tot.N	
3/1/16	0.101	8	3	0.45		6.735	2.526	0.379	1.9	9.3	6.5	0.01	15.95	
3/2/16	0.094				4					8.8	6.4	0.01		
3/3/16	0.093									8.7	6.3	0.01		
3/4/16	0.088									8.6	6.3	0.01		
3/5/16	0.096									9.1	6.3	0.01		
3/6/16	0.097									8.8	6.2	0.01		
3/7/16	0.084									9	6.9	0.01		
3/8/16	0.082	4	3	0.39		2.750	2.062	0.268	2.09	9.1	6.9	0.01	17.75	
3/9/16	0.082				14					8.4	7.3	0.01		
3/10/16	0.147									9	6.6	0.01		
3/11/16	0.206									9.3	6.8	0.01		
3/12/16	0.170									8.2	6.4	0.01		
3/13/16	0.272									8.4	6.3	0.01		
3/14/16	0.259									7	6.7	0.01		
3/15/16	0.170									7.1	6.9	0.01		
3/16/16	0.128	7	9	0.22		7.499	9.641	0.236	0.444	7.8	6.8	0.01	11.74	
3/17/16	0.099				52					10	6.8	0.01		
3/18/16	0.088									9	6.6	0.01		
3/19/16	0.094									9.6	6.6	0.01		
3/20/16	0.094									11	7.1	0.01		
3/21/16	0.080									9.9	6.8	0.01		
3/22/16	0.080	4	3	0.34		2.656	1.992	0.226	3.11	10	6.9	0.01	20.85	
3/23/16	0.077				1					9.4	6.6	0.01		
3/24/16	0.085									9.3	6.4	0.01		
3/25/16	0.086									9.1	6.3	0.01		
3/26/16	0.083									9.3	6.3	0.01		
3/27/16	0.090									8.8	6	0.01		
3/28/16	0.095									9	6.6	0.01		
3/29/16	0.078									9.5	6.5	0.01		
3/30/16	0.078									9.4	6.6	0.01		
3/31/16	0.107									10	6.5	0.01		
Average	0.112	6	5	0.4	7.35	5	4.055	0.28	1.9	9.03	7	0.01	16.57	
Maximum	0.272	8	9	0.5	52.00	7	9.641	0.4	3.1	11.00	7	0.01	20.85	
Exceed.	3	0	0	0	0	0	0	0						