



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

May 20, 2013

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane
Frankfort, Kentucky 40601

**Re: MSD Metro Operations
Silver Heights WQTC; KPDES No.: KY0028801
Discharge Monitoring Reports – April 2013.**

Dear Ms. Cheryl Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the Silver Heights WQTC, KPDES No.: KY0028801 for the month of April 2013.

There were no exceedences, bypasses or overflow reports during the month of April for the Silver Heights WQTC.

If you have any questions concerning the attached DMRs, please contact me at (502) 540-6031.

Sincerely,

A handwritten signature in black ink, appearing to read "J. Kessel", with a stylized flourish at the end.

John Kessel
Process Supervisor, West region

JMK/Silver Heights 0413

Enclosures

cc: T. Singleton
R. Shaw



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CEDAR CREEK WQTC
ADDRESS: 8405 CEDAR CREEK RD
LOUISVILLE, KY 40211

FACILITY: SILVER HEIGHTS WQTC MSD

LOCATION: 9418 SLAYTON CT
LOUISVILLE, KY 40229

ATTN: KEVIN RIES

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

Form Approved

OMB No. 2040-0004

KY0028801	001-2
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
4/1/2013	4/30/2013

DMR Mailing ZIP CODE:

40211

MINOR


(SUBR LV) JEFFE

SANITARY WASTEWATER

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen, dissolved (DO)	SAMPLE MEASUREMENT	*****	*****	*****	7	*****	*****		0	01/01	GR
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	7 INST MIN	*****	*****	mg/L		Weekly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7	*****	9		0	01/01	GR
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6 MINIMUM	*****	9 MAXIMUM	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	12	21		*****	5	10		0	01/07	CP
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	125 30DA AVG	250 DAILY MX	lb/d	*****	30 30DA AVG	60 DAILY MX	mg/L		Weekly	COMPOS
Nitrogen, ammonia total (as N)	SAMPLE MEASUREMENT	0.8	0.8		*****	0.3	0.3		0	01/07	CP
00610 1 2 Effluent Gross	PERMIT REQUIREMENT	41.7 30DA AVG	83.4 DAILY MX	lb/d	*****	10 30DA AVG	20 DAILY MX	mg/L		Weekly	COMPOS
Phosphorus, total (as P)	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.7	2.3		0	01/07	CP
00665 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Weekly	COMPOS
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.343	0.645		*****	*****	*****	*****	0	CN	CN
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. 30DA AVG	Req. Mon. INST MAX	MGD	*****	*****	*****	*****		Continuous	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.010	<0.010		0	01/01	GR
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	.011 30DA AVG	.019 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
EXEC DIR Green Hesterman TYPED OR PRINTED			562-540-6666	05/20/2013
			AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: CEDAR CREEK WQTC
ADDRESS: 8405 CEDAR CREEK RD
LOUISVILLE, KY 40211

FACILITY: SILVER HEIGHTS WQTC MSD

LOCATION: 9418 SLAYTON CT
LOUISVILLE, KY 40229

ATTN: KEVIN RIES

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)


Form Approved
OMB No. 2040-0004

KY028801	001-2
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
4/1/2013	4/30/2013

DMR Mailing ZIP CODE: 40211
MINOR
(SUBR LV) JEFFE
SANITARY WASTEWATER
External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Coliform, fecal general	SAMPLE MEASUREMENT	*****	*****	*****	*****	4	7		0	01/07	GR
74055 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	200 30DA GEO	400 DAILY MX	#/100mL		Weekly	GRAB
BOD, carbonaceous, 05 day, 20 C	SAMPLE MEASUREMENT	9.1	11		*****	4	4		0	01/07	CP
80082 1 0 Effluent Gross	PERMIT REQUIREMENT	62.6 30DA AVG	125 DAILY MX	lb/d	*****	15 30DA AVG	30 DAILY MX	mg/L		Weekly	COMPOS

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, to the best of my knowledge and belief, true, accurate, and complete, and I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
Eric Dir Greg Hedeman TYPED OR PRINTED			502-540-6000	05/20/2013
			AREA Code	NUMBER
			MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
USE MO AVG FOR BOD/TSS REMV; REPT IN MINIMUM COLUMN.

Silver Heights		Report for	Apr-13		Tot. Exc.=	#REF!	Pounds							
Tot. Flow= 10.30342			Concentrations				BOD							
Date	Flow	TSS	BOD	NH3	Fecal	TSS	BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC		
4/1/13	0.297	2	3	0.34		4.950	7.424	0.841	1.53	8.4	8.1			
4/2/13	0.277				7					8	8.1			
4/3/13	0.262									8.7	8.2			
4/4/13	0.263									7.3	8			
4/5/13	0.254									8	7.8			
4/6/13	0.261									8	8.4			
4/7/13	0.269									8	8.3			
4/8/13	0.250	10	4	0.34		20.886	8.354	0.710	2.34	7.4	7.8			
4/9/13	0.233				2					7.5	7.9			
4/10/13	0.252									7.4	7.7			
4/11/13	0.355									7.1	7.9			
4/12/13	0.453									7	7.7			
4/13/13	0.352									7.3	8.5			
4/14/13	0.326									7.5	7.9			
4/15/13	0.284	2	4	0.34		4.740	9.481	0.806	1.55	7.7	7			
4/16/13	0.281				3					7.8	7.2			
4/17/13	0.304									7.6	7.4			
4/18/13	0.298									7.6	7.6			
4/19/13	0.645									7.7	7.5			
4/20/13	0.460									7.4	7.2			
4/21/13	0.385									7.8	7.4			
4/22/13	0.339	6	4	0.28		16.944	11.296	0.791	1.19	7.9	7.4			
4/23/13	0.327				4					7.9	7.5			
4/24/13	0.497									7.4	7			
4/25/13	0.425									8.4	7.6			
4/26/13	0.347									8.4	7.9			
4/27/13	0.345									7.9	7.9			
4/28/13	0.488									7.1	7.8			
4/29/13	0.410									7.4	7.9			
4/30/13	0.363									8.2	8.1			
Average	0.343	5	4	0.3	3.60	12	9.139	0.79	1.7	7.73	8	0.00		
Maximum	0.645	10	4	0.3	7.00	21	11.296	0.8	2.3	8.70	9	0.00		