



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

April 10, 2013

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

Re: MSD Metro Operations
Starview WQTC; KPDES No.: KY0031712
Discharge Monitoring Report – March 2013.

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the Starview WQTC, KPDES No.: KY0031712 for the month of March 2013.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMRs, please contact me at (502)239-7574.

Sincerely,

A handwritten signature in black ink that reads "Duane V. Wright". The signature is written in a cursive style with a large, stylized "D" and "W".

Duane V. Wright
Process Supervisor Central Region

DVW/Starview 3.13

Enclosures

cc: R. Shaw
T. Singleton



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit

Permit #:

KY0031712

Major:

No

Permittee:

STARVIEW WQTC MSD

Permittee Address:

423 BERMUDA WAY
LOUISVILLE, KY 40243

Facility:

STARVIEW WQTC MSD

Facility Location:

423 BERMUDA WAY
LOUISVILLE, KY 40243

Permitted Feature:

001
External Outfall

Discharge:

001-1
SANITARY WASTEWATER

Report Dates & Status

Monitoring Period:

From 03/01/13 to 03/31/13

DMR Due Date:

04/28/13

Status:

NetDMR Validated

Considerations for Form Completion

Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

Principal Executive Officer

First Name:

Greg

Last Name:

Heitzman

Title:

Exec. Dir.

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
201303StarviewWQTC_cover.pdf	pdf	16664
201303Starview_MOR.pdf	pdf	24032

Report Last Saved By

STARVIEW WQTC MSD

User:

wrightd

Name:

Duane Wright

E-Mail:

duane.wright@louisvillemسد.org

Date/Time:

2013-04-24 13:00 (Time Zone: -04:00)

Starview	Report for	Mar-13										
Tot. Flow=	4.35049	Tot. Exc.= 0										
Date	Flow	TSS	BOD	NH3	Fecal	TSS	Pounds BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC
3/1/13	0.114									11	7.1	< 0.010
3/2/13	0.116									9.3	7.7	< 0.010
3/3/13	0.100	2	2	0.06		1.66	1.66	0.05	1.64	9.5	8	< 0.010
3/4/13	0.084				3					10	7.4	< 0.010
3/5/13	0.109									11	7.3	< 0.010
3/6/13	0.134									11	7.5	< 0.010
3/7/13	0.125									11	7.3	< 0.010
3/8/13	0.113									9.4	7.6	< 0.010
3/9/13	0.117									10	7.3	< 0.010
3/10/13	0.103	2	2	0.62		1.72	1.72	0.53	1.79	9	7.1	< 0.010
3/11/13	0.264				215					9.6	7.2	< 0.010
3/12/13	0.212									9.3	7.4	< 0.010
3/13/13	0.159									9.9	7.1	< 0.010
3/14/13	0.126									10	7	< 0.010
3/15/13	0.124									9.6	7.8	< 0.010
3/16/13	0.118									9.6	7.2	< 0.010
3/17/13	0.173									9	7	< 0.010
3/18/13	0.353									8.1	7.3	< 0.010
3/19/13	0.227									8.9	7.1	< 0.010
3/20/13	0.169	2	2	0.39		2.82	2.82	0.55	0.751	9.6	7	< 0.010
3/21/13	0.138				11					9.9	6.8	< 0.010
3/22/13	0.119									10	6.9	< 0.010
3/23/13	0.114									11	7.1	< 0.010
3/24/13	0.142	2	2	0.34		2.37	2.37	0.40	1.32	11	7.2	< 0.010
3/25/13	0.144				3					10	7.3	< 0.010
3/26/13	0.135									9.8	8.2	< 0.010
3/27/13	0.124									10	7.4	< 0.010
3/28/13	0.108									11	7.3	< 0.010
3/29/13	0.097									10	7.3	< 0.010
3/30/13	0.098									9.9	7.2	< 0.010
3/31/13	0.093									7.9	6.9	< 0.010
Average	0.140	2	2	0.4	12	2.14	2.14	0.38	1.4	9.8	7	0.00
Maximum	0.353	2	2	0.6	215	2.82	2.82	0.55	1.8	11.0	8	0.00