



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

June 20, 2013

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

Re: MSD Metro Operations
Starview WQTC; KPDES No.: KY0031712
Discharge Monitoring Report – May 2013.

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the Starview WQTC, KPDES No.: KY0031712 for the month of May 2013.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMRs, please contact me at (502)239-7574.

Sincerely,

A handwritten signature in cursive script that reads "Duane V. Wright".

Duane V. Wright
Process Supervisor Central Region

DVW/Starview 5.13

Enclosures

cc: R. Shaw
T. Singleton



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit

Permit #:

KY0031712

Major:

No

Permittee:

STARVIEW WQTC MSD

Permittee Address:

423 BERMUDA WAY
LOUISVILLE, KY 40243

Facility:

STARVIEW WQTC MSD

Facility Location:

423 BERMUDA WAY
LOUISVILLE, KY 40243

Permitted Feature:

001
External Outfall

Discharge:

001-1
SANITARY WASTEWATER

Report Dates & Status

Monitoring Period:

From 05/01/13 to 05/31/13

DMR Due Date:

07/28/13

Status:

NetDMR Validated

Considerations for Form Completion

Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

Principal Executive Officer

First Name:

Greg

Last Name:

Heitzman

Title:

Executive director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
Strview052013_cover.pdf	pdf	17114
STARVIEW052013_MOR.pdf	pdf	16692

Report Last Saved By

STARVIEW WQTC MSD

User:

kevin.ries@louisvillemsd.org

Name:

kevin ries

E-Mail:

kevin.ries@louisvillemsd.org

Date/Time:

2013-06-27 11:03 (Time Zone: -04:00)

Starview	Report for	May-13		Tot. Exc.= 0					
Tot. Flow=	2.94141	Concentrations		Pounds					
Date	Flow	TSS	BOD	NH3	Fecal	TSS	BOD	NH3	Tot. Phos.
5/1/13	0.062	2	2	0.34		1.0	1.0	0.18	Scratched
5/2/13	0.058				2				
5/3/13	0.059								
5/4/13	0.063								
5/5/13	0.191								3.33
5/6/13	0.158								
5/7/13	0.136								
5/8/13	0.104	3	3	0.39		2.6	2.6	0.34	0.778
5/9/13	0.077				10				
5/10/13	0.188								
5/11/13	0.300								
5/12/13	0.186								
5/13/13	0.136								
5/14/13	0.101								
5/15/13	0.088	2	2	0.28		1.5	1.5	0.21	0.909
5/16/13	0.106				2				
5/17/13	0.101								
5/18/13	0.084								
5/19/13	0.075								
5/20/13	0.067								
5/21/13	0.057								
5/22/13	0.063	2	2	0.39		1.1	1.1	0.21	2.22
5/23/13	0.079				2				
5/24/13	0.053								
5/25/13	0.052								
5/26/13	0.049								
5/27/13	0.052								
5/28/13	0.047								
5/29/13	0.044								
5/30/13	0.048								
5/31/13	0.058								
Average	0.095	2	2	0.4	2.99	1.5	1.5	0.23	1.8
Maximum	0.300	3	3	0.4	10.00	2.6	2.6	0.34	3.3
Exceed.	11	0	0	0	0	0.0	0.0	0	