



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

December 17, 2013

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

Re: MSD Metro Operations
Starview WQTC; KPDES No.: KY0031712
Discharge Monitoring Report – November 2013.

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the Starview WQTC, KPDES No.: KY0031712 for the month of November 2013.

There were no exceedences, bypasses or overflows to report.

If you have any questions concerning the attached DMRs, please contact me at (502)239-7574.

Sincerely,

A handwritten signature in black ink, appearing to read "Duane V. Wright", is written over a horizontal line.

Duane V. Wright
Process Supervisor Central Region

DVW/Starview 11.13

Enclosures

cc: R. Shaw
T. Singleton



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit

Permit #:

KY0031712

Major:

No

Permittee:

STARVIEW WQTC MSD

Permittee Address:

423 BERMUDA WAY
LOUISVILLE, KY 40243

Facility:

STARVIEW WQTC MSD

Facility Location:

423 BERMUDA WAY
LOUISVILLE, KY 40243

Permitted Feature:

001
External Outfall

Discharge:

001-1
SANITARY WASTEWATER

Report Dates & Status

Monitoring Period:

From 11/01/13 to 11/30/13

DMR Due Date:

01/28/14

Status:

NetDMR Validated

Considerations for Form Completion

Parameter 00610 - Use Season 1 for summer months (May, June, July, August, September, and October) and Season 2 for winter months (November, December, January, February March, and April); enter NODI=9 for the Season not needed.

Principal Executive Officer

First Name:

Greg

Last Name:

Heitzman

Title:

Exec. Dir.

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI: --

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
Strview112013_cover.pdf	pdf	16428
Strview112013_MOR.pdf	pdf	24434

Report Last Saved By

STARVIEW WQTC MSD

User:

kevin.thompson@louisvillemsd.org

Name:

Kevin Thompson

E-Mail:

kevin.thompson@louisvillemsd.org

Date/Time:

2013-12-26 13:07 (Time Zone: -05:00)

Starview	Report for	Nov-13		Tot. Exc.= 0								
Tot. Flow=	2.7845	Concentrations										
Date	Flow	TSS	BOD	NH3	Fecal	TSS	Pounds BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC
11/1/13	0.183									9.8	7.1	0.01
11/2/13	0.135									9.8	7	0.01
11/3/13	0.101	2	2	0.06		1.683	1.683	0.050	1.32	9.4	6.8	0.01
11/4/13	0.083				3					9.9	6.9	0.01
11/5/13	0.072									10	6.8	0.01
11/6/13	0.074									9.8	7	0.01
11/7/13	0.110									10	7	0.01
11/8/13	0.081									9.6	6.9	0.01
11/9/13	0.075									9.3	7	0.01
11/10/13	0.067	2	3	0.34		1.114	1.671	0.189	1.54	8	7.2	0.01
11/11/13	0.063				5					8.4	7.3	0.01
11/12/13	0.054									9.5	7.3	0.01
11/13/13	0.053									9.2	7.1	0.01
11/14/13	0.054									9	7.1	0.01
11/15/13	0.056									9.3	7.5	0.01
11/16/13	0.070									8.8	7.3	0.01
11/17/13	0.197									9.2	7.5	0.01
11/18/13	0.249									7.1	7.4	0.01
11/19/13	0.149	5	3	0.34		6.222	3.733	0.423	0.913	8.6	7.3	0.01
11/20/13	0.123				11					10	7	0.01
11/21/13	0.108									9.9	7.1	0.01
11/22/13	0.093									10	7	0.01
11/23/13	0.081									9.8	7.9	0.01
11/24/13	0.073	2	2	0.45		1.222	1.222	0.275	1.08	10	7.9	0.01
11/25/13	0.064				2					9.6	7.2	0.01
11/26/13	0.062									9.9	7	0.01
11/27/13	0.066									10	7	0.01
11/28/13	0.059									9.7	7.3	0.01
11/29/13	0.060									10	7.6	0.01
11/30/13	0.068									11	7.4	0.01
12/1/13												
Average	0.093	3	3	0.3	4.26	3	2.077	0.23	1.2	9.49	7	0.01
Maximum	0.249	5	3	0.5	11.00	6	3.733	0.4	1.5	11.00	8	0.01
Exceed.	9	0	0	0	0	0	0	0				