



Louisville and Jefferson County Metropolitan Sewer District
700 West Liberty Street
Louisville Kentucky 40203-1911
502-540-6000
www.msdlouky.org

February 10, 2015

Ms. Cheryl Edwards
Kentucky Division of Water
200 Fair Oaks Lane, 4th Floor
Frankfort, Kentucky 40601

Re: MSD Metro Operations
Starview WQTC; KPDES No.: KY0031712
Discharge Monitoring Report – January 2015.

Dear Ms. Edwards:

Attached are the Discharge Monitoring Reports (DMRs) and the Monthly Operating Report (MOR) for the Starview WQTC, KPDES No.: KY0031712 for the month of January 2015.

There were no exceedences, overflow or bypasses to report.

If you have any questions concerning the attached DMRs, please contact me at (502)239-7574.

Sincerely,

A handwritten signature in black ink, appearing to read "Kevin Thompson", is written over a horizontal line.

Kevin Thompson
Process Supervisor Central Region

KLT/Starview 01.15

Enclosures

cc: R. Shaw
T. Singleton



Beneficial Use of Louisville's Biosolids
www.louisvillegreen.com

DMR Copy of Record

Permit

Permit #:

KY0031712

Major:

No

Permittee:

STARVIEW WQTC MSD

Permittee Address:

423 BERMUDA WAY
LOUISVILLE, KY 40243

Facility:

STARVIEW WQTC MSD

Facility Location:

423 BERMUDA WAY
LOUISVILLE, KY 40243

Permitted Feature:

001
External Outfall

Discharge:

001-1
DOMESTIC

Report Dates & Status

Monitoring Period:

From 01/01/15 to 01/31/15

DMR Due Date:

02/28/15

Status:

NetDMR Validated

Considerations for Form Completion

Principal Executive Officer

First Name:

Greg

Last Name:

Heitzman

Title:

Executive Director

Telephone:

502-540-6000

No Data Indicator (NODI)

Form NODI:

--

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Attachments

Name	Type	Size
012015_Starview_MOR.pdf	pdf	9255
012015_Starview_COVERLETTER.pdf	pdf	16831

Report Last Saved By

STARVIEW WQTC MSD

User:

kevin.thompson@louisvillemsd.org

Date/Time:

2015-02-20 08:47 (Time Zone: -05:00)

Starview	Report for	Jan-15		Tot. Exc.= 0									
Tot. Flow=	2.24538	Concentrations											
Date	Flow	TSS	BOD	NH3	Ecoli	TSS	Pounds BOD	NH3	Tot. Phos.	D.O.	p.H.	TRC	Tot. N
1/1/15	0.074									9.2	7.4	0.01	
1/2/15	0.074									9.5	7.5	0.01	
1/3/15	0.103									9.3	7.3	0.01	
1/4/15	0.061	2	2	0.5		1.017	1.017	0.254	1.66	9	7	0.01	18.61
1/5/15	0.090				1					9.1	7.2	0.01	
1/6/15	0.083									9.4	7.4	0.01	
1/7/15	0.066									9.3	7.1	0.01	
1/8/15	0.079									8.9	7.3	0.01	
1/9/15	0.068									9.1	7.6	0.01	
1/10/15	0.084									8.8	7.2	0.01	
1/11/15	0.072									9.6	7.4	0.01	
1/12/15	0.086									9.8	7.2	0.01	
1/13/15	0.074									10	7.5	0.01	
1/14/15	0.062									9.8	7.5	0.01	
1/15/15	0.065									10	7.1	0.01	
1/16/15	0.065									10	7	0.01	
1/17/15	0.069									9.7	7.2	0.01	
1/18/15	0.075									9.9	7.3	0.01	
1/19/15	0.068									10	7.1	0.01	
1/20/15	0.063									8.7	6.3	0.01	
1/21/15	0.057									8.8	6.4	0.01	
1/22/15	0.068									9	6.6	0.01	
1/23/15	0.063									9.3	6.4	0.01	
1/24/15	0.079									9.9	6.2	0.01	
1/25/15	0.090									10	6.8	0.01	
1/26/15	0.078									10	7.1	0.01	
1/27/15	0.065									9.8	7	0.01	
1/28/15	0.068									9.9	7.1	0.01	
1/29/15	0.071									10	7.3	0.01	
1/30/15	0.058									9.8	7	0.01	
1/31/15	0.067									10	6.6	0.01	
Average	0.072	2	2	0.5	1.00	1	1.017	0.25	1.7	9.54	7	0.01	18.61
Maximum	0.103	2	2	0.5	1.00	1	1.017	0.3	1.7	10.00	8	0.01	18.61
Exceed.	1	0	0	0	0	0	0	0					